

Scott Hemingway

Draft Reclaimed Water Facilities Manual

Section 7.7.1 Operator Certifications

If you are going to require that Distributors have a BAT you should also require that Generators have a BAT also. Generators are going to have a number of backflow assemblies within their facility to protect the reclaimed water from lower quality water and to protect the potable water system from reclaimed water.

The level of protection at the source of the reclaimed water (Generator) should be equal to the distribution system.