

## City of Kirkland

MR #7 (Flow Control) and MR #8 (Wetlands Protection) conflict with each other, causing confusion on which minimum requirement should govern especially in urban where redevelopment projects often occur (parcel has large amounts of impervious area but very minimal flow control with a wetland on the parcel is redeveloping and now needs to meet stream protection requirements and wetland protection requirements). Please update the minimum requirement to provide guidance on which minimum requirement supersedes when this situation occurs.