

# Washington State Department of Health

For consistency with the horizontal separations requirements in WAC 246-272A and WAC 246-272B, subsurface infiltration systems on page 33 (Section S7.C.2.e.i.D.) must be located at least 100 feet from surface water. Amend to read:

D. Not be located within one hundred (100) of a surface water or within one hundred (100) feet of a potable water supply well.