

Comments on the Draft 2019 SWMMWW		
Draft 2019 SWMMWW Section (select from drop down)	Comment	Comment Made By
I-D.4 Using Regional Facilities to Meet Minimum Requirements	We have an existing regional facilities program that meets MR7. The facilities include a large detention vault (constructed) a large infiltration vault (constructed) and a second large infiltration vault (in design), and flow splitters helping to manage the flow. These facilities work together to meet flow control standards at the point of compliance prior to discharge to a receiving water. The language of disallowing flow splitters is too limiting.	Steve Hitch
Appendix I-D: Regional Facilities	The regional facility definition is overly broad. Redmond has tried to define regional facilities on its webpage: <a href="http://redmond.gov/cms/one.aspx?portalId=169&amp;pageId=27022">http://redmond.gov/cms/one.aspx?portalId=169&amp;pageId=27022</a> .	Steve Hitch
Appendix I-D: Regional Facilities	We suggest a work group of agencies with regional facilities to help support this new language and join forces to best understand how the language will apply to existing facilities.	Steve Hitch