

| Comments on the Draft 2019 SWMMWW | | |
|--|--|---------------------------------------|
| | | |
| Draft 2019 SWMMWW Section (select from drop down) | Comment | Comment Made By |
| I-4.2 How UIC Wells are Regulated | <p>Section I-4.2 How UIC wells are regulated contains the following language (at the end of the second paragraph): "New UIC wells are defined as UIC wells that were constructed on or after February 3, 2006. For new UIC wells, designers must apply Construction Stormwater BMPs in accordance with Volume II and permanent Stormwater BMPs in accordance with Volume V." A few lines further down (second bullet point) it also states: "New UIC wells must be constructed according to the specifications in this section."</p> <p>As I-4 is a new section within the SWMMWW, all requirements are therefore new. The language provided would appear to require that all wells constructed after 2/3/2006 would need to conform to the current UIC requirements of the 2019 SWMMWW, even though all those requirements are new to the 2019 version. Presumably, Ecology doesn't expect all wells constructed since 2/3/2006 to be retrofitted to meet 2019 SWMMWW requirements, so likely there should be some language added specifying WHEN the UIC requirements listed in the 2019 SWMMWW shall apply to new UIC wells. A follow-up question is does Ecology intent to apply these requirements to UIC wells constructed after a date "x" or following a jurisdiction's adoption of the 2019 SWMMWW, etc.?</p> | John Featherstone, City of Shoreline |
| S440 BMPs for Pet Waste | One of the methods of disposal to choose from is to bury it. Due to the issues with fecal coliform in our receiving waters, burying pet waste should not be an option for disposal. | Melissa Ivancevich, City of Shoreline |