

Seattle-Tacoma International Airport

Language on page 18 in HFC Proposed Rule Informational Guidebook is not clear.

As currently written, it notes -1-Beginning January 1, 2024, all owners/operators of all sized systems must maintain, at a minimum, the following records for a minimum of 5 years:-1-

I assume this applies to all sized systems with a full charge greater than or equal to 50 pounds of a high-GWP refrigerant per WAC language.

Per this Guidebook language, it is unclear whether rulemaking requires no recordkeeping for systems with a full charge less than 50 pounds of a high-GWP refrigerant.