

# City of Port Angeles

Comment on Draft NPDES Permit

WA0029556\_2ndDraftPermit\_2020-06-10\_BirchBayWWTP.pdf

Table 7: Effluent Characterization ♦ Final Wastewater Effluent

Reference calculation "C" below the table indicates flow as "CFS" for the TIN calculation. It appears this flow unit should be in the units of "mgd" to make this formula work properly.

Comment on Fact Sheet WA0029556\_2ndDraftFS\_2020-06-10\_BirchBayWWTP .pdf

Table 4: Wastewater Effluent Characterization

The "Ammonia" and "Nitrate/Nitrite" parameter does not specify the value as nitrogen or show the method. Could you please clarify if this value is reported as "N".

Thank you,