

## ROGER WILLIAMS

In reviewing the draft Upland Finfish Hatching and Rearing General Permit, there was no requirement to test the hatcher discharge water for PCBs. Since the discharge ends up in the Spokane River which is listed for PCBs, all discharges to the Spokane River should be tested for PCBs. The Upland Finfish Hatching and Rearing General Permit needs to include at least quarterly testing for PCBs using EPA Methods 8082 A and 1668.