

City of Arlington Public Works (Mike Wolanek)

No significant concerns. Effluent temperature and flow are sufficient as monitoring parameters. Fact sheet not immediately clear (unless I missed it) as to: 1) range of effluent temperatures prior to treatment; 2) seasonal range of temperatures in basin that might be released under upset or bypass conditions; 3) results of RPA with respect to receiving water quality standards--likely or unlikely to exceed? Also, please assure City of Arlington is party of record to receive notification if/when permit is discontinued. Thanks for the opportunity to comment!