

Eric Lanser

18 AAC 72.100 states cleanouts need 100' separation distances from domestic water source. I like to put my wells in the house and the clean out right where the sewer line leaves the house. I will not be able to do that anymore under this constraint.

18 AAC 72.511 As home prices escalate beyond some buyers ability to pay, I think adding the additional expense of paying for soil classification is excessive and unnecessary for certified installers.