

Jade Berube

The updates to Section 10.1 Dewatering and Basin Draining needs further clarification. The new permit will create undue burden for underground utility contractors if implemented as currently drafted. The permit does not clarify the difference between basin dewatering or groundwater dewatering and as written would require the contractor to photograph dewatering activities every four hours, in the night, when dewatering is used for lowering groundwater levels during the installation of underground utilities. Separation within the permit between dewatering activities related to underground utility construction and stormwater basin dewatering needs further clarification.