



Instrumental Research, Inc.
7800 Main Street NE
Fridley, MN 55432.
Ph. 763-571-3698 Fax. 763-571-3372

LABORATORY ANALYSIS REPORT 758-19

Wednesday, July 31, 2019

MDH CERTIFIED LABORATORY 027-003-130 EPA LAB CODE MN 00076

Attn: Jim Dropps

Date Collected: 7/29/2019

9783 122nd St. N

Date Received: 7/29/2019

Hugo, MN

Collected By: Client

Parameter/Method	Sample ID	Results	Units	MDL	Reporting Limit	Analysis Date
Nitrate SM 4500-NO3 E-00	Kitchen Faucet (758-19-01)	7.50	mg/L	0.0025	0.030	7/31/2019

MDL = Method detection level Temp Blank >4.0 degrees C

Sample was collected on 7/29/19 at 12:00, received by IRI on 7/29/19 at 15:22 and analyzed on 7/29/19 at 11:30 for nitrate. Sample DOES meet MDH and EPA guidelines for safe drinking water for analytes tested. The results are only indicative for the sample tested from the sample point on the date collected.

All analyses were performed using Minnesota Department of Health approved methodologies.

Report submitted by,

SUZANNE MELCHIOR, LABORATORY MANAGER

SM/kg

The results in this report apply only to the samples analyzed in accordance with the chain of custody document. This report must be reproduced in its entirety.