

William Barton

I assume the greensand filters are designed to remove chlorine from the waste water discharge to Nine Mile Creek. I assume this chlorine is used to prevent biological fouling in non contact equipment or to regenerate the greensand filters or both . It would seem prudent to require monitoring and reporting of chlorine concentration in discharge to public waters. Continuous monitoring & alarming instrumentation is available for this purpose.