

Alex Smith

do not build this bullshit. A fuel cell can continue to generate electricity or maintain operating temperatures while experiencing catalyst degradation which causes a massive spike in the release of carbon monoxide or Volatile Organic Compounds (VOCs). This project would need to centralize the 2,275 individual stack emissions into an exponentially smaller number of exhaust systems so that Continuous Emissions Monitoring Systems (CEMS) installed on these central exhaust systems can provide real-time, accurate data about operational compliance. As it is, this design plan completely fails to provide monitoring conditions that are "practically enforceable" under 20.2.70.302.B NMAC.