

Edgar Bolch

285.32(c)(1) Rule concerning equalization tank states that designer should use flows on Table III. Should clarify that using flows for total number of bedrooms rather than bedrooms per dwelling unit. e.g. 3 br house + 2 br house = $180+240=420$ gal or 5 br = 360 gal.