



09/10/2026

Jim Davies  
Meggitt Aircraft Braking Systems Corp.  
1204 Massillon Rd.  
Akron, OH 44306

**RE: DRAFT AIR POLLUTION PERMIT-TO-INSTALL AND OPERATE**

Facility ID: 1677010999  
Permit Number: P0141227  
Permit Type: Administrative Modification  
County: Summit

|     |                                     |
|-----|-------------------------------------|
| No  | TOXIC REVIEW                        |
| No  | SYNTHETIC MINOR TO AVOID MAJOR NSR  |
| No  | CEMS                                |
| No  | MACT/GACT                           |
| No  | NSPS                                |
| No  | NESHAPS                             |
| No  | NETTING                             |
| No  | MODELING SUBMITTED                  |
| Yes | SYNTHETIC MINOR TO AVOID TITLE V    |
| Yes | FEDERALLY ENFORCEABLE PTIO (FEPTIO) |
| No  | SYNTHETIC MINOR TO AVOID MAJOR GHG  |

Dear Permit Holder:

A draft of the Ohio Administrative Code (OAC) Chapter 3745-31 Air Pollution Permit-to-Install and Operate (PTIO) for the referenced facility has been issued for the emissions unit(s) listed in the Authorization section of the enclosed draft permit. This draft action is not an authorization to begin construction or modification of your emissions unit(s). The purpose of this draft is to solicit public comments on the permit. A public notice will appear in the Ohio Environmental Protection Agency Weekly Review and Public Notices website, [Weekly Review and Public Notices](#). A copy of the public notice and the draft permit are enclosed. This permit can be accessed electronically on the Ohio EPA document search webpage: [eDocument Search | Ohio Environmental Protection Agency](#). Comments will be accepted as a marked-up copy of the draft permit or in narrative format. Any comments must be sent to the following:

Andrea Moore  
Permit Review/Development Section  
Ohio EPA, DAPC  
50 West Town Street Suite 700  
PO Box 1049  
Columbus, Ohio 43216-1049

and

Akron Regional Air Quality Management  
District  
1867 West Market St.  
Akron, OH 44313

Comments and/or a request for a public hearing will be accepted within 30 days of the date the notice appears on the Ohio EPA Weekly Review and Public Notices website, [Weekly Review and Public Notices | Ohio Environmental Protection Agency](#). You will be notified if a public hearing is scheduled. A decision on issuing a final permit-to-install will be made after consideration of comments received and oral testimony if a public hearing is conducted. Any permit fee that will be due upon issuance of a final Permit-to-Install is indicated in the Authorization section. Please do not submit any payment now. If you have any questions, please contact Akron Regional Air Quality Management District at (330)375-2480.

Sincerely,

Robert Hodanbosi  
Chief, Division of Air Pollution Control

cc: U.S. EPA Region 5 Via E-Mail Notification  
ARAQMD; Pennsylvania; West Virginia; Canada

# PUBLIC NOTICE

The following matters are the subject of this public notice by the Ohio Environmental Protection Agency. The complete public notice, including any additional instructions for submitting comments, requesting information, a public hearing, or filing an appeal may be obtained at: [Weekly Review and Public Notices | Ohio Environmental Protection Agency](#) or Hearing Clerk, Ohio EPA, 50 W. Town St., Columbus, Ohio 43215. Ph: 614-644-3037 email: [HClerk@epa.ohio.gov](mailto:HClerk@epa.ohio.gov)

Draft Air Pollution Permit-to-Install and Operate Administrative Modification

Meggitt Aircraft Braking Systems Corp.  
1204 Massillon Rd.  
Akron, OH 44306

ID#: P0141227

Date of Action: 09/10/2026

Permit Desc: Facility-initiated administrative modification to incorporate RACT standards. Pursuant to Part D of Title I of the Clean Air Act (CAA), Ohio EPA is required to establish a State Implementation Plan (SIP) for the attainment and maintenance of the NAAQS. The above-mentioned permit is a part of Ohio's SIP for attainment and maintenance of the 2015 ozone NAAQS and will be submitted to United States Environmental Protection Agency (U.S. EPA) as a modification of the SIP.

The permit can be accessed electronically and comments may be submitted at: <https://ohioepa.commentinput.com> - Search by entering the permit # P0141227 in the "Search Projects" search box.

The public comment period will run until 10/12/2026 at 11:59 PM.

## Permit Strategy Write-Up

1. Check all that apply:

☐ Synthetic Minor Determination **N/A**

☐ Netting Determination **N/A**

2. Source Description:

Emissions units P036, P037, P038, P039, P041, P044, P048, and P049 – Aerospace brake component manufacturing. As required by the reclassification to serious nonattainment for ozone under the 2015 ozone National Ambient Air Quality Standards (NAAQS) promulgated by U.S. EPA, this facility has submitted a VOC Reasonably Available Control Technology (RACT) study on May 7, 2026 (subsequently revised on July 21, 2026) to address the feasibility of controlling VOC emissions from their aerospace manufacturing operations. This facility does not have any prior source-specific VOC RACT established under OAC rule 3745-21-09. This permit modification includes the implementation of the proposed RACT limits in the July 21, 2026 revision of the RACT study. Section B of this permit cites the RACT limits under OAC rule 3745-21-11(B). The RACT limits are implemented under an OAC rule 3745-31-05(D) synthetic minor restriction for the affected emissions units in section C of this permit.

Pursuant to Part D of Title I of the Clean Air Act (CAA), Ohio EPA is required to establish a State Implementation Plan (SIP) for the attainment and maintenance of the NAAQS. This permit is part of Ohio's SIP for attainment and maintenance of the 2015 ozone NAAQS and will be submitted to United States Environmental Protection Agency (U.S. EPA) as a modification of the SIP.

3. Facility Emissions and Attainment Status:

This is a Title V facility. Summit County was designated as "serious" nonattainment for the 2015 ozone NAAQS but is now a maintenance county. The county is currently designated attainment for all NAAQS (criteria) pollutants which include ozone, PM<sub>2.5</sub>, PM<sub>10</sub>, CO, NO<sub>2</sub>, lead and SO<sub>2</sub>.

4. Source Emissions:

Emissions units P036, P037, P038, P039, P041, P044, P048, and P049 have VOC emissions that are subject to the VOC RACT requirements. The VOC RACT determination for these emissions unit is venting VOC emissions to a thermal oxidizer with an overall control efficiency of at least 98%, by weight, and includes associated monitoring, record keeping, reporting, and testing requirements.

5. Conclusion:

This permit modification establishes VOC RACT limits as proposed by Meggitt Aircraft Braking Systems Corporation in their VOC RACT study as part of the requirements for the 2015 ozone NAAQs nonattainment and maintenance areas under the reclassification to serious nonattainment for the Cleveland area. The VOC RACT limit established in this permit will be implemented upon final issuance of this permit.

6. Please provide additional notes or comments as necessary:

None



**Draft Permit-to-Install and Operate**

Meggitt Aircraft Braking Systems Corp.

**Permit Number:** P0141227

**Facility ID:** 1677010999

**Effective Date:** To be entered upon final issuance

7. Total Permit Allowable Emissions Summary (for informational purposes only):

| <u>Pollutant</u> | <u>Tons Per Year</u> |
|------------------|----------------------|
| VOC              | 11.67                |
| Combined HAPs    | 1.11                 |



**Environmental  
Protection  
Agency**

**DRAFT**

**Division of Air Pollution Control  
Permit-to-Install and Operate**

for

Meggitt Aircraft Braking Systems Corp.

|                |                                   |
|----------------|-----------------------------------|
| Facility ID:   | 1677010999                        |
| Permit Number: | P0141227                          |
| Permit Type:   | Administrative Modification       |
| Issued:        | 09/10/2026                        |
| Effective:     | To be entered upon final issuance |
| Expiration:    | To be entered upon final issuance |



**Division of Air Pollution Control**  
**Permit-to-Install and Operate**

for

Meggitt Aircraft Braking Systems Corp.

**Table of Contents**

|                                                                                                     |    |
|-----------------------------------------------------------------------------------------------------|----|
| Authorization.....                                                                                  | 7  |
| List of Commonly Used Abbreviations .....                                                           | 11 |
| A. Standard Terms and Conditions.....                                                               | 12 |
| B. Facility-Wide Terms and Conditions.....                                                          | 17 |
| C. Emissions Unit Terms and Conditions.....                                                         | 23 |
| 1. Emissions Unit Group - Carbon Furnaces: P036, P037, P038, P039, P041, P044, P048, and P049. .... | 24 |

## Authorization

Facility ID: 1677010999  
Application Number(s): M0008873M0008873  
Permit Number: P0141227  
Permit Description: Facility-initiated administrative modification to incorporate RACT standards. Pursuant to Part D of Title I of the Clean Air Act (CAA), Ohio EPA is required to establish a State Implementation Plan (SIP) for the attainment and maintenance of the NAAQS. The above-mentioned permit is a part of Ohio's SIP for attainment and maintenance of the 2015 ozone NAAQS and will be submitted to United States Environmental Protection Agency (U.S. EPA) as a modification of the SIP.  
Permit Type: Administrative Modification  
Permit Fee: \$0.00 *DO NOT send payment at this time, subject to change before final issuance*  
Issue Date: 09/10/2026  
Effective Date: To be entered upon final issuance  
Expiration Date: To be entered upon final issuance  
Permit Evaluation Report (PER) Annual Date: To be entered upon final issuance

This document constitutes issuance of a Permit-to-Install and Operate for the emissions unit(s) identified on the following page to:

Meggitt Aircraft Braking Systems Corp.  
1204 Massillon Rd.  
Akron, OH 44306

Ohio Environmental Protection Agency (EPA) District Office or local air agency responsible for processing and administering your permit:

Akron Regional Air Quality Management District  
1867 West Market St.  
Akron, OH 44313  
(330)375-2480

The above-named entity is hereby granted this Permit-to-Install and Operate for the air contaminant source(s) (emissions unit(s)) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the described emissions unit(s) will operate in compliance with applicable State and Federal laws and regulations.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

John Logue  
Director

## Authorization (continued)

Permit Number: P0141227

Permit Description: Facility-initiated administrative modification to incorporate RACT standards. Pursuant to Part D of Title I of the Clean Air Act (CAA), Ohio EPA is required to establish a State Implementation Plan (SIP) for the attainment and maintenance of the NAAQS. The above-mentioned permit is a part of Ohio's SIP for attainment and maintenance of the 2015 ozone NAAQS and will be submitted to United States Environmental Protection Agency (U.S. EPA) as a modification of the SIP.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

### Group Name: Carbon Furnaces

|                                   |                                  |
|-----------------------------------|----------------------------------|
| <b>Emissions Unit ID:</b>         | <b>P036</b>                      |
| Company Equipment ID:             | Carbon Processing Furnace P036-A |
| Superseded Permit Number:         | P0129464                         |
| General Permit Category and Type: | Not Applicable P0129464          |
| <b>Emissions Unit ID:</b>         | <b>P037</b>                      |
| Company Equipment ID:             | Carbon Processing Furnace P037-A |
| Superseded Permit Number:         | P0129464                         |
| General Permit Category and Type: | Not Applicable P0129464          |
| <b>Emissions Unit ID:</b>         | <b>P038</b>                      |
| Company Equipment ID:             | Carbon Processing Furnace        |
| Superseded Permit Number:         | P0129464                         |
| General Permit Category and Type: | Not Applicable P0129464          |
| <b>Emissions Unit ID:</b>         | <b>P039</b>                      |
| Company Equipment ID:             | Accutherm Carbonization Furnace  |
| Superseded Permit Number:         | P0129464                         |
| General Permit Category and Type: | Not Applicable P0129464          |
| <b>Emissions Unit ID:</b>         | <b>P041</b>                      |
| Company Equipment ID:             | Carbon Processing Furnace        |
| Superseded Permit Number:         | P0129464                         |
| General Permit Category and Type: | Not Applicable P0129464          |
| <b>Emissions Unit ID:</b>         | <b>P044</b>                      |
| Company Equipment ID:             | Carbon Processing Furnace        |
| Superseded Permit Number:         | P0129464                         |
| General Permit Category and Type: | Not Applicable P0129464          |
| <b>Emissions Unit ID:</b>         | <b>P048</b>                      |
| Company Equipment ID:             | Carbon Processing Furnace P036-B |
| Superseded Permit Number:         | P0129464                         |
| General Permit Category and Type: | Not Applicable P0129464          |



|                                   |                                  |
|-----------------------------------|----------------------------------|
| <b>Emissions Unit ID:</b>         | <b>P049</b>                      |
| Company Equipment ID:             | Carbon Processing Furnace P037-B |
| Superseded Permit Number:         | P0129464                         |
| General Permit Category and Type: | Not Applicable P0129464          |
|                                   |                                  |

# List of Commonly Used Abbreviations

|                                                                   |                                                                  |                                                                                                       |
|-------------------------------------------------------------------|------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------|
| AP-42 = U.S. EPA's Compilation of Air Pollution Emissions Factors | HVLP = high volume, low pressure                                 | PER = Permit Evaluation Report                                                                        |
| ASTM = American Society for Testing and Materials                 | LAER = lowest achievable emission rate                           | PM = particulate matter                                                                               |
| BACT = Best Available Control Technology                          | lb(s)/hr = pound(s) per hour                                     | PM <sub>10</sub> = particulate matter with an aerodynamic diameter less than or equal to 10 microns   |
| BAT = Best Available Technology                                   | LDAR = leak detection and repair                                 | PM <sub>2.5</sub> = particulate matter with an aerodynamic diameter less than or equal to 2.5 microns |
| CAA = Clean Air Act                                               | LPG = liquefied petroleum gas/propane                            | ppb = parts per billion                                                                               |
| CAM = compliance assurance monitoring                             | MACT = maximum achievable control technology                     | ppm = parts per million                                                                               |
| CEMS = continuous emissions monitoring system                     | MAGLC = maximum acceptable ground level concentration            | PSD = Prevention of Significant Deterioration                                                         |
| CFC = chlorofluorocarbon                                          | mg/m <sup>3</sup> = milligrams per cubic meter                   | psi = pounds per square inch                                                                          |
| CFR = Code of Federal Regulations                                 | MM = million                                                     | psia = pounds per square inch absolute                                                                |
| CH <sub>4</sub> = methane                                         | MMBtu = million British Thermal Units                            | PTE = potential-to-emit                                                                               |
| CI = compression ignition                                         | MSDS = material safety data sheet                                | PTI = Permit-to-Install                                                                               |
| CO = carbon monoxide                                              | MSW = municipal solid waste                                      | PTIO = Permit-to-Install and Operate                                                                  |
| CO <sub>2</sub> = carbon dioxide                                  | NAAQS = National Ambient Air Quality Standard                    | PTO = Permit-to-Operate                                                                               |
| COM = continuous opacity monitor                                  | NESHAP = National Emission Standard for Hazardous Air Pollutants | PWR = process weight rate                                                                             |
| DAPC = Division of Air Pollution Control                          | NG = natural gas                                                 | RACM = reasonably available control measures                                                          |
| DO/LAA = District Office/Local Air Agency                         | ng/m <sup>3</sup> = nanograms per cubic meter                    | RACT = reasonably available control technology                                                        |
| dscf = dry standard cubic foot                                    | NH <sub>3</sub> = ammonia                                        | RATA = relative accuracy test audit                                                                   |
| EAC = emissions activity category                                 | NMHC = non-methane hydrocarbons                                  | RTO = regenerative thermal oxidizer                                                                   |
| eDocs = electronic documents database                             | NMOC = non-methane organic compound                              | SB265 = Senate Bill 265                                                                               |
| ERAC = Environmental Review Appeals Commission                    | NO = nitrogen oxide                                              | scfm = standard cubic feet per minute                                                                 |
| ESP = electrostatic precipitator                                  | NO <sub>2</sub> = nitrogen dioxide                               | SI = spark ignition                                                                                   |
| EU = emissions unit                                               | NO <sub>x</sub> = nitrogen oxides                                | SIP = State Implementation Plan                                                                       |
| FEPTIO = Federally Enforceable Permit-to-Install and Operate      | NSPS = New Source Performance Standard                           | SO <sub>2</sub> = sulfur dioxide                                                                      |
| FER = Fee Emissions Report                                        | NSR = New Source Review                                          | SSMP = startup, shutdown, and malfunction plan                                                        |
| FR = Federal Register                                             | NTV = Non-Title V                                                | TDS = total dissolved solids                                                                          |
| GACT = generally achievable control technology                    | O&M = operation and maintenance                                  | TLV = threshold limit value                                                                           |
| GHG = greenhouse gases                                            | OAC = Ohio Administrative Code                                   | TO = thermal oxidizer                                                                                 |
| gr/dscf = grains per dry standard cubic foot                      | OC = organic compound                                            | TPH = ton(s) per hour                                                                                 |
| H <sub>2</sub> S = hydrogen sulfide                               | Ohio EPA = Ohio Environmental Protection Agency                  | TPY = ton(s) per year                                                                                 |
| H <sub>2</sub> SO <sub>4</sub> = sulfuric acid                    | ORC = Ohio Revised Code                                          | TSP = total suspended particulates                                                                    |
| HAP = hazardous air pollutant                                     | Pb = lead                                                        | VE = visible emissions                                                                                |
| HCl = hydrogen chloride                                           | PBR = Permit-By-Rule                                             | VMT = vehicle miles traveled                                                                          |
| HF = hydrogen fluoride                                            | PCB = polychlorinated biphenyl                                   | VOC = volatile organic compound                                                                       |
| Hg = mercury                                                      | PE = particulate emissions                                       | WPP = work practice plan                                                                              |
| hp = horsepower                                                   | PEMS = predictive emissions monitoring system                    | µg/m <sup>3</sup> = micrograms per cubic meter                                                        |

## **A. Standard Terms and Conditions**

**1. What does this permit-to-install and operate (PTIO) allow me to do?**

This permit allows you to install and operate the emissions unit(s) identified in this PTIO. You must install and operate the unit(s) in accordance with the application you submitted and all the terms and conditions contained in this PTIO, including emission limits and those terms that ensure compliance with the emission limits (for example, operating, recordkeeping and monitoring requirements).

**2. Who is responsible for complying with this permit?**

The person identified on the "Authorization" page, above, is responsible for complying with this permit until the permit is revoked, terminated, or transferred. "Person" means a person, firm, corporation, association, or partnership. The words "you," "your," or "permittee" refer to the "person" identified on the "Authorization" page above.

The permit applies only to the emissions unit(s) identified in the permit. If you install or modify any other equipment that requires an air permit, you must apply for an additional PTIO(s) for these sources.

**3. What records must I keep under this permit?**

You must keep all records required by this permit, including monitoring data, test results, strip-chart recordings, calibration data, maintenance records, and any other record required by this permit for five years from the date the record was created. You can keep these records electronically, provided they can be made available to Ohio EPA during an inspection at the facility. Failure to make requested records available to Ohio EPA upon request is a violation of this permit requirement.

**4. What are my permit fees and when do I pay them?**

There are two fees associated with permitted air contaminant sources in Ohio:

- a) PTIO fee. This one-time fee is based on a fee schedule in accordance with Ohio Revised Code (ORC) section 3745.11 or based on a time and materials charge for permit application review and permit processing if required by the Director.

You will be sent an invoice for this fee after you receive this PTIO and payment is due within 30 days of the invoice date. You are required to pay the fee for this PTIO even if you do not install or modify your operations as authorized by this permit.

- b) Annual emissions fee. Ohio EPA will assess a separate fee based on the total annual emissions from your facility. You self-report your emissions in accordance with Ohio Administrative Code (OAC) Chapter 3745-78. This fee assessed is based on a fee schedule in ORC section 3745.11 and funds Ohio EPA's permit compliance oversight activities. For facilities that are permitted as synthetic minor sources, the fee schedule is adjusted annually for inflation. Ohio EPA will notify you when it is time to report your emissions and to pay your annual emission fees.

**5. When does my PTIO expire, and when do I need to submit my renewal application?**

This permit expires on the date identified at the beginning of this permit document (see "Authorization" page above) and you must submit a renewal application to renew the permit. Ohio EPA will send a renewal notice to you approximately six months prior to the expiration date of this permit. However, it is very important that you submit a complete renewal permit application (either electronically through Ohio EPA's eBusiness Center: Air

Services web service or postmarked prior to expiration of this permit) even if you do not receive the renewal notice.

If a complete renewal application is submitted before the expiration date, Ohio EPA considers this a timely application for purposes of ORC section 119.06, and you are authorized to continue operating the emissions unit(s) covered by this permit beyond the expiration date of this permit until final action is taken by Ohio EPA on the renewal application.

**6. What happens to this permit if my project is delayed or I do not install or modify my source?**

This PTIO expires 18 months after the issue date identified on the "Authorization" page above unless otherwise specified if you have not (1) started constructing the new or modified emission sources identified in this permit, or (2) entered into a binding contract to undertake such construction. This deadline can be extended once by 12 months, provided you apply to Ohio EPA for this extension within a reasonable time before the 18-month period has ended and you can show good cause for any such extension.

**7. What reports must I submit under this permit?**

An annual permit evaluation report (PER) is required in addition to any malfunction reporting required by OAC rule 3745-15-06 or other specific rule-based reporting requirement identified in this permit. Your PER due date is identified in the Authorization section of this permit.

**8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and permit evaluation report (PER) obligations under this permit?**

If you are required to obtain a Title V permit under OAC Chapter 3745-77 in the future, the permit-to-operate portion of this permit will be superseded by the issued Title V permit. From the effective date of the Title V permit forward, this PTIO will effectively become a PTI (permit-to-install) in accordance with OAC rule 3745-31-02(B). The following terms and conditions of this permit will no longer be applicable after issuance of the Title V permit: Section B, Term 1.b) and Section C, for each emissions unit, Term a)(2).

The PER requirements in this permit remain effective until the date the Title V permit is issued and is effective and cease to apply after the effective date of the Title V permit. The final PER obligation will cover operations up to the effective date of the Title V permit and must be submitted on or before the submission deadline identified in this permit on the last day prior to the effective date of the Title V permit.

**9. What are my obligations when I perform scheduled maintenance on air pollution control equipment?**

You must perform scheduled maintenance of air pollution control equipment in accordance with OAC rule 3745-15-06(A). If scheduled maintenance requires shutting down or bypassing any air pollution control equipment, you must also shut down the emissions unit(s) served by the air pollution control equipment during maintenance, unless the conditions of OAC rule 3745-15-06(A)(3) are met. Any emissions that exceed permitted amount(s) under this permit (unless specifically exempted by rule) must be reported as deviations in the annual permit evaluation report (PER), including nonexempt excess emissions that occur during approved scheduled maintenance.

**10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report?**

If you have a reportable malfunction of any emissions unit(s) or any associated air pollution control system, you must report this to the Akron Regional Air Quality Management District in accordance with OAC rule 3745-15-06(B). Malfunctions that must be reported are those that result in emissions that exceed permitted emission levels. It is your responsibility to evaluate control equipment breakdowns and operational upsets to determine if a reportable malfunction has occurred.

If you have a malfunction but determine that it is not a reportable malfunction under OAC rule 3745-15-06(B), it is recommended that you maintain records associated with control equipment breakdown or process upsets. Although it is not a requirement of this permit, Ohio EPA recommends that you maintain records for non-reportable malfunctions.

**11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located?**

Yes. Under Ohio law, the Director or his/her authorized representative may inspect the facility, conduct tests, examine records or reports to determine compliance with air pollution laws and regulations and the terms and conditions of this permit. You must provide, within a reasonable time, any information Ohio EPA requests either verbally or in writing.

**12. What happens if one or more emissions units operated under this permit is/are shut down permanently?**

Ohio EPA can terminate the permit terms associated with any permanently shut down emissions unit. "Shut down" means the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31.

You should notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification that identifies the date on which the emissions unit was permanently shut down. The certification must be submitted by an authorized official from the facility. You cannot continue to operate an emission unit once the certification has been submitted to Ohio EPA by the authorized official.

You must comply with all recordkeeping and reporting for any permanently shut down emissions unit in accordance with the provisions of the permit, regulations or laws that were enforceable during the period of operation, such as the requirement to submit a PER, air fee emission report, or malfunction report. You must also keep all records relating to any permanently shut down emissions unit, generated while the emissions unit was in operation, for at least five years from the date the record was generated.

Again, you cannot resume operation of any emissions unit certified by the authorized official as being permanently shut down without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

**13. Can I transfer this permit to a new owner or operator?**

You can transfer this permit to a new owner or operator. If you transfer the permit, the new owner or operator must follow the procedures in OAC Chapter 3745-31-07, including notifying Ohio EPA or the local air agency of the change in ownership or operator within thirty days of the transfer date. Any transferee of this permit shall assume the responsibilities of the transferor permit holder.

**14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"?**

This permit and OAC rule 3745-15-07 prohibit operation of the air contaminant source(s) regulated under this permit in a manner that causes a nuisance. Ohio EPA can require additional controls or modification of the requirements of this permit through enforcement orders or judicial enforcement action if, upon investigation, Ohio EPA determines existing operations are causing a nuisance.

**15. What happens if a portion of this permit is determined to be invalid?**

If a portion of this permit is determined to be invalid, the remainder of the terms and conditions remain valid and enforceable. The exception is where the enforceability of terms and conditions are dependent on the term or condition that was declared invalid.

## **B. Facility-Wide Terms and Conditions**



1. This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

- a) For the purpose of a permit-to-install document, the facility-wide terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

- (1) None.

## 2. OAC rule 3745-21-11(B) VOC RACT Requirements

As required by the reclassification to serious nonattainment for ozone under the 2015 ozone National Ambient Air Quality Standards (NAAQS) promulgated by U.S. EPA, and pursuant to OAC rule 3745-21-11(B) and the VOC Reasonable Available Control Technology (RACT) Study submitted by MEGGITT AIRCRAFT BRAKING SYSTEMS CORP. on May 4, 2026 (subsequently revised on July 21, 2026):

“MEGGITT AIRCRAFT BRAKING SYSTEMS CORP.” (Facility ID: 1677010999) or any subsequent owner or operator of “MEGGITT AIRCRAFT BRAKING SYSTEMS CORP.” facility located at 1204 Massillon Road, Akron, Ohio 44306 shall comply with the following requirements\*:

- a) Emission Unit Group – Carbon Furnaces: P036, P037, P038, P039, P041, P044, P048, P049

- (1) The VOC emissions from emission units P036, P037, P038, P039, P041, P044, P048, and P049 shall be vented to a thermal oxidizer with an overall control efficiency of at least 99% by weight.

## 3. Monitoring and/or Recordkeeping Requirements

- a) In order to maintain compliance with the applicable emission limitation(s) contained in this permit, the acceptable average combustion temperature within the north thermal oxidizer, for any 3-hour block of time when one or more of the emissions units controlled by the north thermal oxidizer are in operation, shall not be more than 50°F below the average temperature measured during the most recent performance test that demonstrated the emissions units were in compliance.

- b) In order to maintain compliance with the applicable emission limitation(s) contained in this permit, the acceptable average combustion temperature within the south thermal oxidizer, for any 3-hour block of time when one or more of the emissions units controlled by the south thermal oxidizer are in operation, shall not be more than 50°F below the average temperature measured during the most recent performance test that demonstrated the emissions units were in compliance.

- c) The permittee shall properly install, operate, and maintain a continuous temperature monitor and recorder that measures and records the combustion temperature within the thermal oxidizers when any of the controlled emissions units are in operation, including periods of startup and shutdown. Units shall be in degrees Fahrenheit (°F). The accuracy for each thermocouple, monitor, and recorder shall be guaranteed by the manufacturer to be within  $\pm 1\%$  of the temperature being measured or  $\pm 5^\circ\text{F}$ , whichever is greater. The temperature monitor and recorder shall be installed, calibrated, operated, and maintained in accordance with the manufacturer's recommendations, instructions, and the operating manuals, with any modifications deemed necessary by the permittee. The permittee shall



collect and record the following information each day any of the controlled emissions units are in operation:

- (1) all 3-hour blocks of time, when any emissions unit was in operation and vented to the north thermal oxidizer, during which the average combustion temperature within the north thermal oxidizer was more than 50°F below the average temperature measured during the most recent performance test that demonstrated the emissions unit was in compliance;
- (2) all 3-hour blocks of time, when any emissions unit was in operation and vented to the south thermal oxidizer, during which the average combustion temperature within the south thermal oxidizer was more than 50°F below the average temperature measured during the most recent performance test that demonstrated the emissions unit was in compliance; and
- (3) a log (date and total time) of the downtime or bypass of the capture (collection) system and thermal oxidizer, and/or downtime of the monitoring equipment, when the associated emissions unit(s) was/were in operation.

These records shall be maintained at the facility for a period of five years.

- d) Whenever the monitored average combustion temperature within either of the thermal oxidizers deviates from the range or limit established in accordance with this permit, the permittee shall promptly investigate the cause of the deviation. The permittee shall maintain records of the following information for each investigation:

- (1) identification of the operating emissions unit(s) and oxidizer(s);
- (2) the date and time the deviation began;
- (3) the magnitude of the deviation at that time;
- (4) the date the investigation was conducted;
- (5) the name(s) of the personnel who conducted the investigation; and
- (6) the findings and recommendations.

In response to each required investigation to determine the cause of a deviation, the permittee shall take prompt corrective action to bring the operation of the control equipment within the acceptable range/limit specified in this permit, unless the permittee determines that corrective action is not necessary and documents the reasons for that determination and the date and time the deviation ended. The permittee shall maintain records of the following information for each corrective action taken:

- (7) a description of the corrective action;
- (8) the date corrective action was completed;
- (9) the date and time the deviation ended;



(10) the total period of time (in minutes) during which there was a deviation;

(11) the temperature readings immediately after the corrective action was implemented; and

(12) the name(s) of the personnel who performed the work.

Investigation and records required by this paragraph do not eliminate the need to comply with the requirements of OAC rule 3745-15-06 if it is determined that a malfunction has occurred.

#### 4. Reporting Requirements

a) The permittee shall submit quarterly deviation (excursion) reports that identify:

(1) all deviations (excursions) of the following emission limitations, operational restrictions and/or control device operating parameter limitations that restrict the potential to emit (PTE) of any regulated air pollutant and have been detected by the monitoring, record keeping and/or testing requirements in this permit:

a. all 3-hour blocks of time when any emissions unit was in operation and vented to the north thermal oxidizer during which the average combustion temperature within the north thermal oxidizer was more than 50°F below the average temperature maintained during the most recent performance test that demonstrated the emissions unit was in compliance;

b. all 3-hour blocks of time when any emissions unit was in operation and vented to the south thermal oxidizer during which the average combustion temperature within the south thermal oxidizer was more than 50°F below the average temperature maintained during the most recent performance test that demonstrated the emissions unit was in compliance;

c. any records of downtime (date and length of time) for the capture (collection) system, the thermal oxidizer, and/or the monitoring equipment when the emissions unit(s) was/were in operation;

d. any period of time (start time and date, and end time and date) when the emissions unit(s) was/were in operation and the process emissions were not vented to the thermal oxidizer;

(2) the probable cause of each deviation (excursion);

(3) any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and

(4) the magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.



The quarterly reports shall be submitted each year by January 31 (covering October to December), April 30 (covering January to March), July 31 (covering April to June), and October 31 (covering July to September), unless an alternative schedule has been established and approved by the Director (the appropriate district office or local air agency).

- b) All applications, notifications or reports required by terms and conditions in this permit to be submitted or “reported in writing” are to be submitted to Ohio EPA through the Ohio EPA’s eBusiness Center: Air Services web service (“Air Services”). Ohio EPA will accept hard copy submittals on an as-needed basis if the permittee cannot submit the required documents through the Ohio EPA eBusiness Center. In the event of an alternative hard copy submission in lieu of the eBusiness Center, the post-marked date or the date the document is delivered in person will be recognized as the date submitted. Electronic submission of applications, notifications, or reports required to be submitted to Ohio EPA fulfills the requirement to submit the required information to the Director, the district office or local air agency, and/or any other individual or organization specifically identified as an additional recipient identified in this permit unless otherwise specified. Consistent with OAC rule 3745-15-03, the required application, notification or report is considered to be “submitted” on the date the submission is successful using a valid electronic signature. Signature by the signatory authority may be represented as provided through procedures established in Air Services.

## 5. Testing Requirements

- a) The permittee shall conduct, or have conducted, emissions testing for emission units P036, P037, P038, P039, P041, P044, P048, and P049 per the following requirements:
- (1) The emissions testing shall be conducted within six months of the permit expiration.
  - (2) The emissions testing shall be conducted to demonstrate compliance with the overall control efficiency limitation for VOC. No capture testing is required because the emissions units listed above are a closed system (emissions are hard piped to the control equipment) with 100% capture efficiency.
  - (3) The control efficiency (that is, the percent reduction in mass emissions between the inlet and outlet of the control system) shall be determined per the test methods and procedures specified in OAC rule 3745-21-10 or an alternative test protocol approved by Ohio EPA. The test methods and procedures selected shall be based on a consideration of the diversity of the organic species present and the total concentration, and on a consideration of the potential presence of interfering gases.
  - (4) During the emissions testing, the EUs shall be operated under operational conditions approved in advance by the appropriate Ohio DO/LAA. Operational conditions that may need to be approved include, but are not limited to, the production rate, the type of material processed, material make-up (solvent content, etc.) or control equipment operational limitations (burner temperature, precipitator voltage, etc.). In general, testing shall be done under worst-case conditions expected during the life of the permit. As part of the information provided in the Intent-to-Test (ITT) notification form described below, the permittee shall provide a description



of the EU operational conditions they will meet during the emissions testing and describe why they believe worst-case operating conditions will be met. Prior to conducting the test(s), the permittee shall confirm with the appropriate Ohio EPA DO/LAA that the proposed operating conditions constitute worst-case. Failure to test under the approved conditions may result in Ohio EPA not accepting the test results as a demonstration of compliance.

- (5) Not later than 30 days prior to the proposed test date(s), the permittee shall submit an ITT notification to the appropriate Ohio EPA DO/LAA. The ITT notification shall describe in detail the proposed test methods and procedures, the EU operating parameters, the time(s) and date(s) of the test(s) and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA DO/LAA's refusal to accept the results of the emission test(s).
- (6) Personnel from the appropriate Ohio EPA DO/LAA shall be permitted to witness the test(s), examine the testing equipment and acquire data and information necessary to ensure that the operation of the EUs and the testing procedures provide a valid characterization of the emissions from the EUs and/or the performance of the control equipment.
- (7) A comprehensive written report on the results of the emissions test(s) shall be signed by the person(s) responsible for the tests and submitted to the appropriate Ohio EPA DO/LAA within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the appropriate Ohio EPA DO/LAA.

## **C. Emissions Unit Terms and Conditions**

**1. Emissions Unit Group - Carbon Furnaces: P036, P037, P038, P039, P041, P044, P048, and P049.**

| <b>EU ID</b> | <b>Operations, Property and/or Equipment Description</b>                                                                                           |
|--------------|----------------------------------------------------------------------------------------------------------------------------------------------------|
| P036         | 11' carbon processing furnace - Carbon Processing Furnace P036-A                                                                                   |
| P037         | 11' carbon processing furnace - Carbon Processing Furnace P037-A                                                                                   |
| P038         | 11' carbon processing furnace                                                                                                                      |
| P039         | Carbonization furnace (Plant F-Dept. 665) - Accutherm Carbonization Furnace                                                                        |
| P041         | One 11' Carbon Processing Furnace - Carbon Processing Furnace                                                                                      |
| P044         | Carbon Processing Furnace (Plant F-Dept. 665) - Carbon Processing Furnace                                                                          |
| P048         | One 11' carbon processing furnace - Carbon Processing Furnace P036-B (Previously part of emissions unit P036 covered by Permit to Install 16-1531) |
| P049         | One 11' carbon processing furnace - Carbon Processing Furnace P037-B (Previously part of emissions unit P037 covered by Permit to Install 16-1531) |

a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

(1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

a. None.

(2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.

a. b)(1)b.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.



|    | Applicable Rules/Requirements                                                                                                   | Applicable Emissions Limitations/Control Measures                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
|----|---------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| a. | OAC rule 3745-31-05(A)                                                                                                          | <p>The emissions of organic material (OM) from emissions units P036 and P048, combined, shall not exceed 2.5 pounds per hour and 10.95 tons per year.</p> <p>The emissions of OM from emissions units P037 and P049, combined, shall not exceed 2.5 pounds per hour and 10.95 tons per year.</p> <p>The emissions of OM from emissions unit P038 shall not exceed 2.5 pounds per hour and 10.95 tons per year.</p> <p>The emissions of OM from emissions unit P039 shall not exceed 2.5 pounds per hour and 10.95 tons per year.</p> <p>The emissions of OM from emissions unit P041 shall not exceed 2.5 pounds per hour and 10.95 tons per year.</p> <p>The volatile organic compound (VOC) emissions from emissions unit P044 shall not exceed 2.47 pounds per hour and 10.82 tons per year.</p> <p>See b)(2)a. and b)(2)b. below.</p> |
| b. | OAC rule 3745-31-05(D)<br>(Synthetic Minor to avoid Title V permitting and MACT applicability under 40 CFR Part 63, Subpart GG) | The use of a thermal oxidizer that restricts the annual emissions from emissions units P036, P037, P038, P039, P041, P044, P048 and P049, combined, to 11.67 tons of VOC per rolling, 12-month period and 1.11 tons of combined hazardous air pollutants (HAP) per rolling, 12-month period.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| c. | OAC rule 3745-31-05(D)<br>[Federally enforceable requirements to comply with OAC rule 3745-21-11(B)]                            | See Facility-Wide Terms and Conditions B.2. through B.5. above.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| d. | OAC Rule 3745-21-07(N)(3)                                                                                                       | The control measure specified by this rule is less stringent than the control measure established pursuant to OAC rule 3745-31-                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |



|  |  |                                                 |
|--|--|-------------------------------------------------|
|  |  | 05(D) as specified under d)(1) and d)(2) below. |
|--|--|-------------------------------------------------|

(2) Additional Terms and Conditions

a. See Facility-Wide Terms and Conditions B.2.a) above.

b. All of the VOC and organic HAPs emissions from the emissions units listed above and all of the OM emissions from emissions units P036, P037, P038, P039, P041, P048 and P049 shall be vented to a thermal oxidizer that shall meet the operational, monitoring, and record keeping requirements of this permit, when one or more of the emissions units are in operation.

c. The annual emission limitations are based on the “worst-case” scenario. However, if any proposed change(s), such as with production capacity, the types and/or quantities of materials used or processed, or anything else that increases the potential emissions of any air pollutant, then the permittee shall apply for and obtain either a final Chapter 31 or a final administrative modification to the federally enforceable permit-to-install and operate (FEPTIO) prior to the change(s).

c) Operational Restrictions

(1) None.

d) Monitoring and/or Recordkeeping Requirements

(1) See Facility-Wide Terms and Conditions B.3. above.

(2) In order to maintain compliance with the applicable emission limitation(s) contained in this permit, the acceptable average combustion temperature within the north thermal oxidizer, for any 3-hour block of time when one or more of the emissions units controlled by the north thermal oxidizer are in operation, shall not be more than 50°F below the average temperature measured during the most recent performance test that demonstrated the emissions units were in compliance.

(3) In order to maintain compliance with the applicable emission limitation(s) contained in this permit, the acceptable average combustion temperature within the south thermal oxidizer, for any 3-hour block of time when one or more of the emissions units controlled by the south thermal oxidizer are in operation, shall not be more than 50°F below the average temperature measured during the most recent performance test that demonstrated the emissions units were in compliance.

(4) The permittee shall properly install, operate, and maintain a continuous temperature monitor and recorder that measures and records the combustion temperature within the thermal oxidizers when any of the controlled emissions units are in operation, including periods of startup and shutdown. Units shall be in degrees Fahrenheit (°F). The accuracy for each thermocouple, monitor, and recorder shall be guaranteed by the manufacturer to be within ±



1% of the temperature being measured or  $\pm 5^{\circ}\text{F}$ , whichever is greater. The temperature monitor and recorder shall be installed, calibrated, operated, and maintained in accordance with the manufacturer's recommendations, instructions, and the operating manuals, with any modifications deemed necessary by the permittee. The permittee shall collect and record the following information each day any of the controlled emissions units are in operation:

- a. all 3-hour blocks of time, when any emissions unit was in operation and vented to the north thermal oxidizer, during which the average combustion temperature within the north thermal oxidizer was more than  $50^{\circ}\text{F}$  below the average temperature measured during the most recent performance test that demonstrated the emissions unit was in compliance;
- b. all 3-hour blocks of time, when any emissions unit was in operation and vented to the south thermal oxidizer, during which the average combustion temperature within the south thermal oxidizer was more than  $50^{\circ}\text{F}$  below the average temperature measured during the most recent performance test that demonstrated the emissions unit was in compliance; and
- c. a log (date and total time) of the downtime or bypass of the capture (collection) system and thermal oxidizer, and/or downtime of the monitoring equipment, when the associated emissions unit(s) was/were in operation.

These records shall be maintained at the facility for a period of five years.

- (5) Whenever the monitored average combustion temperature within either of the thermal oxidizers deviates from the range or limit established in accordance with this permit, the permittee shall promptly investigate the cause of the deviation. The permittee shall maintain records of the following information for each investigation:
  - a. identification of the operating emissions unit(s) and oxidizer(s);
  - b. the date and time the deviation began;
  - c. the magnitude of the deviation at that time;
  - d. the date the investigation was conducted;
  - e. the name(s) of the personnel who conducted the investigation; and
  - f. the findings and recommendations.

In response to each required investigation to determine the cause of a deviation, the permittee shall take prompt corrective action to bring the operation of the control equipment within the acceptable range/limit specified in this permit, unless the permittee determines that corrective action is not necessary and documents the reasons for that determination and the date and



time the deviation ended. The permittee shall maintain records of the following information for each corrective action taken:

- g. a description of the corrective action;
- h. the date corrective action was completed;
- i. the date and time the deviation ended;
- j. the total period of time (in minutes) during which there was a deviation;
- k. the temperature readings immediately after the corrective action was implemented;  
and
- l. the name(s) of the personnel who performed the work.

Investigation and records required by this paragraph do not eliminate the need to comply with the requirements of OAC rule 3745-15-06 if it is determined that a malfunction has occurred.

- (6) The temperature ranges/limits are effective for the duration of this permit, unless revisions are requested by the permittee and approved in writing by the appropriate Ohio EPA district office or local air agency. The permittee may request revisions to the permitted temperature ranges/limits based upon information obtained during future performance tests that demonstrate compliance with the allowable emission rate(s) for the controlled pollutant(s). In addition, approved revisions to the temperature ranges/limits will not constitute a relaxation of the monitoring requirements of this permit and may be incorporated into this permit by means of an administrative modification.
- (7) The permittee shall maintain monthly records of the following information:
  - a. the rolling, 12-month summation of VOC emissions from emissions units P036, P037, P038, P039, P041, P044, P048 and P049, combined; and
  - b. the rolling, 12-month summation of total combined HAP emissions from emissions units P036, P037, P038, P039, P041, P044, P048 and P049, combined.

e) Reporting Requirements

(1) See Facility-Wide Terms and Conditions B.4. above.

- (2) The permittee shall submit quarterly deviation (excursion) reports that identify:
  - a. all deviations (excursions) of the following emission limitations, operational restrictions and/or control device operating parameter limitations that restrict the potential to emit (PTE) of any regulated air pollutant and have been detected by the monitoring, record keeping and/or testing requirements in this permit:



- i. all 3-hour blocks of time when any emissions unit was in operation and vented to the north thermal oxidizer during which the average combustion temperature within the north thermal oxidizer was more than 50°F below the average temperature maintained during the most recent performance test that demonstrated the emissions unit was in compliance;
  - ii. all 3-hour blocks of time when any emissions unit was in operation and vented to the south thermal oxidizer during which the average combustion temperature within the south thermal oxidizer was more than 50°F below the average temperature maintained during the most recent performance test that demonstrated the emissions unit was in compliance;
  - iii. any records of downtime (date and length of time) for the capture (collection) system, the thermal oxidizer, and/or the monitoring equipment when the emissions unit(s) was/were in operation;
  - iv. any period of time (start time and date, and end time and date) when the emissions unit(s) was/were in operation and the process emissions were not vented to the thermal oxidizer;
- b. the probable cause of each deviation (excursion);
  - c. any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and
  - d. the magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted each year by January 31 (covering October to December), April 30 (covering January to March), July 31 (covering April to June), and October 31 (covering July to September), unless an alternative schedule has been established and approved by the Director (the appropriate district office or local air agency).

- (3) The permittee shall submit an annual Permit Evaluation Report (PER) to the Ohio EPA. The PER must be submitted by the due date identified in the Authorization section of this permit. The PER shall cover a reporting period of no more than 12 months for each air contaminant source identified in this permit.
- (4) All applications, notifications or reports required by terms and conditions in this permit to be submitted or "reported in writing" are to be submitted to Ohio EPA through the Ohio EPA's eBusiness Center: Air Services web service ("Air Services"). Ohio EPA will accept hard copy submittals on an as-needed basis if the permittee cannot submit the required documents through the Ohio EPA eBusiness Center. In the event of an alternative hard copy submission in lieu of the eBusiness Center, the post-marked date or the date the document is delivered in



person will be recognized as the date submitted. Electronic submission of applications, notifications, or reports required to be submitted to Ohio EPA fulfills the requirement to submit the required information to the Director, the district office or local air agency, and/or any other individual or organization specifically identified as an additional recipient identified in this permit unless otherwise specified. Consistent with OAC rule 3745-15-03, the required application, notification or report is considered to be “submitted” on the date the submission is successful using a valid electronic signature. Signature by the signatory authority may be represented as provided through procedures established in Air Services.

f) Testing Requirements

(1) See Facility-Wide Terms and Conditions B.5. above.

(2) Compliance with the Emissions Limitations and/or Control Requirements specified in section b) of these terms and conditions shall be determined in accordance with the following methods:

a. Emission Limitations:

The emissions of OM from emissions units P036 and P048, combined, shall not exceed 2.5 pounds per hour and 10.95 tons per year.

The emissions of OM from emissions units P037 and P049, combined, shall not exceed 2.5 pounds per hour and 10.95 tons per year.

The emissions of OM from emissions unit P038 shall not exceed 2.5 pounds per hour and 10.95 tons per year.

The emissions of OM from emissions unit P039 shall not exceed 2.5 pounds per hour and 10.95 tons per year.

The emissions of OM from emissions unit P041 shall not exceed 2.5 pounds per hour and 10.95 tons per year.

The VOC emissions from emissions unit P044 shall not exceed 2.47 pounds per hour and 10.82 tons per year.

Applicable Compliance Method:

Compliance with the hourly allowable OM and VOC emission limitations identified above shall be determined based upon the emission testing requirements in section f)(2).

The annual allowable OM and VOC emission limitations above were determined by multiplying the hourly allowable OM/VOC emission limitation by 8,760 hours per year, and dividing by 2,000 pounds per ton. Therefore, as long as compliance with the hourly allowable emission limitations is maintained, compliance with the annual allowable emission limitations will be demonstrated



b. Emission Limitation:

The use of a thermal oxidizer that restricts the annual emissions from emissions units P036, P037, P038, P039, P041, P044, P048 and P049, combined, to 11.67 tons of VOC per rolling, 12-month period and 1.11 tons of combined HAPs per rolling, 12-month period.

Applicable Compliance Method:

Compliance with the allowable annual VOC and combined HAPs emission limitations above shall be determined based upon the emission testing requirements in section f)(2).

(3) The permittee shall conduct, or have conducted, emission testing for the emissions units listed above in accordance with the following requirements:

- a. The emission testing shall be conducted within 6 months prior to the permit expiration.
- b. The emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for VOC, organic HAPs and OM.
- c. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s):

- i. Methods 1 through 4 and 18 of 40 CFR Part 60, Appendix A.

Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA.

- d. During the emission testing, the emissions unit shall be operated under operational conditions approved in advance by the appropriate Ohio EPA district office or local air agency. Operational conditions that may need to be approved include, but are not limited to, the production rate, the type of material processed, material make-up (solvent content, etc.), or control equipment operational limitations (burner temperature, precipitator voltage, etc.). In general, testing shall be done under "worst case" conditions expected during the life of the permit. As part of the information provided in the "Intent to Test" notification form described below, the permittee shall provide a description of the emissions unit operational conditions they will meet during the emissions testing and describe why they believe "worst case" operating conditions will be met. Prior to conducting the test(s), the permittee shall confirm with the appropriate Ohio EPA district office or local air agency that the proposed operating conditions constitute "worst case". Failure to test under the approved conditions may result in Ohio EPA not accepting the test results as a demonstration of compliance.
  - e. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA district office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and



date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA district office's or local air agency's refusal to accept the results of the emission test(s).

- f. Personnel from the appropriate Ohio EPA district office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- g. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA district office or local air agency within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the appropriate Ohio EPA district office or local air agency.

g) Miscellaneous Requirements

- (1) None.

# **VOC RACT STUDY**

## **CARBON PROCESSING FURNACES**

The Meggitt logo consists of the word "MEGGITT" in a white, sans-serif, all-caps font, centered within a dark navy blue square.

**Meggitt Aircraft Braking Systems Corporation**

**Prepared By:**

**TRINITY CONSULTANTS**

400 Polaris Parkway  
Suite 275  
Westerville, Ohio 43082

|                     |            |
|---------------------|------------|
| Initial Submission: | March 2026 |
| Revision 1:         | May 2026   |
| Revision 2:         | July 2026  |

Project 253601.0166

**Trinity**  
Consultants 

The Trinity Consultants logo features the word "Trinity" in a large, blue, sans-serif font, with "Consultants" in a smaller, blue, sans-serif font below it. To the right of the text is a stylized graphic consisting of several overlapping, curved lines in shades of blue and green, forming a triangular shape.

## TABLE OF CONTENTS

---

|                                                                                            |            |
|--------------------------------------------------------------------------------------------|------------|
| <b>1. BACKGROUND</b>                                                                       | <b>1-1</b> |
| <b>2. FACILITY OVERVIEW</b>                                                                | <b>2-1</b> |
| 2.1 General Facility Information .....                                                     | 2-1        |
| 2.2 Permitted VOC Sources .....                                                            | 2-2        |
| <b>3. RACT DETERMINATION</b>                                                               | <b>A-1</b> |
| 3.1 Source Overview .....                                                                  | A-1        |
| 3.2 Control Overview .....                                                                 | A-1        |
| 3.3 Source Modification/Replacement .....                                                  | A-2        |
| 3.4 RACT Determination .....                                                               | A-3        |
| <b>APPENDIX A. POTENTIAL-TO-EMIT DOCUMENTATION</b>                                         | <b>A-4</b> |
| <b>APPENDIX B. SOURCE INFORMATION</b>                                                      | <b>B-1</b> |
| <b>APPENDIX C. THERMAL OXIDIZER STACK TEST RESULTS</b>                                     | <b>C-1</b> |
| <br><b>LIST OF FIGURES</b>                                                                 |            |
| Figure 2-1. Area Map for Meggitt                                                           | 2-1        |
| <br><b>LIST OF TABLES</b>                                                                  |            |
| Table 2-1. PTIO Permitted VOC Sources at the Akron Facility <sup>a</sup>                   | 2-3        |
| <br><b>APPENDIX: LIST OF FIGURES</b>                                                       |            |
| Appendix Figure B-1. Facility Plot Plan                                                    | B-4        |
| <br><b>APPENDIX: LIST OF TABLES</b>                                                        |            |
| Appendix Table B-1. General Source Information                                             | B-1        |
| Appendix Table B-2. Annual Production Rates for 2022-2024                                  | B-2        |
| Appendix Table B-3. Average and Maximum Daily and Annual Actual VOC Emissions <sup>a</sup> | B-3        |

## 1. BACKGROUND

---

On March 17, 2022, Ohio EPA promulgated revisions to the existing volatile organic compound (VOC) regulations under Chapter 3745-21 of the Ohio Administrative Code (OAC) due to the downgrade to moderate nonattainment status for the Cleveland area with respect to the 2015 8-hr Ozone National Ambient Air Quality Standard (NAAQS) as well as the change to marginal nonattainment status for the Cincinnati area.

Changes in the revised standards include but are not limited to:

- Extension of existing VOC Reasonably Available Control Technology (RACT) rules in OAC 3745-21 to the Cincinnati area; and
- Requirement for major VOC emitters (from non-control technique guidelines (CTG) sources) in the Cincinnati and Cleveland areas to conduct a detailed engineering study pursuant to OAC 3745-21-11.

Chapter 3745-21-11 requires facilities located in Butler, Clermont, Cuyahoga, Geauga, Hamilton, Lake, Lorain, Medina, Portage, Summit, or Warren County that have potential VOC emissions greater than 100 tons per year (tpy) from non-CTG sources to conduct a detailed engineering study to determine the technical and economic feasibility of reducing VOC emissions and define RACT for the affected sources. Additionally, it requires that any facility that has an existing site-specific definition of RACT in Chapter 3745-12-09 of the OAC submit an updated RACT study. In both cases the engineering study must be submitted to Ohio EPA within one (1) year of the effective date of the rule (i.e., by March 27, 2023).

On April 1, 2025, Ohio EPA promulgated revisions to the existing volatile organic compound (VOC) regulations under Chapter 3745-21 of the Ohio Administrative Code (OAC) following the classification of the Cleveland area to serious nonattainment status for the 2015 8-hr Ozone NAAQS in the Cleveland area.

Changes included in the revised standards include but are not limited to:

- ▶ Requirement for major VOC emitters (from non-CTG sources) in the Cleveland area to conduct a detailed engineering study pursuant to OAC 3745-21-11.

Chapter 3745-21-11 requires facilities located in Cuyahoga, Geauga, Lake, Lorain, Medina, Portage, or Summit County that have potential VOC emissions greater than 50 tpy from non-CTG sources to conduct a detailed engineering study to determine the technical and economic feasibility of reducing VOC emissions and define RACT for the affected sources. Additionally, it requires that any facility that has an existing site-specific definition of RACT in Chapter 3745-12-09 of the OAC submit an updated RACT study. In both cases the engineering study must be submitted to Ohio EPA within one (1) year of the effective date of the rule (i.e., by April 1, 2026).

Meggitt Aircraft and Braking Systems Corporation's manufacturing facility located in Akron, Ohio, is subject to a non-CTG RACT determination pursuant to OAC 3745-21-11. Accordingly, the facility is required to submit a VOC RACT study by April 1, 2026. The following sections comprise the required VOC RACT study for the Meggitt Aircraft Braking Systems Corporation Akron, Ohio Facility.

## 2. FACILITY OVERVIEW

### 2.1 General Facility Information

Meggitt Aircraft Braking Systems Corporation (Meggitt) owns and operates an aircraft parts and auxiliary equipment manufacturing facility Summit County. The facility is located at 1204 Massillon Road, Akron, Ohio 44306. The Akron Facility manufactures advanced aircraft braking systems. These include:

- ▶ Wheels
- ▶ Carbon brakes
- ▶ Brake control systems
- ▶ Landing gear components.

Figure 2-1 is an area map that shows the site location relative to predominant geographical features such as highways and railroads.

**Figure 2-1. Area Map for Meggitt**



Facility information required by sections (1) through (4) of OAC 3745-21-11(B) is provided as follows:

- a) The complete facility name, Ohio EPA air program facility identification number, and address:

*Meggitt Aircraft Braking System Corporation  
Facility ID 1677010999  
1204 Massillon Road  
Akron, OH 44306*

- b) The name, title, address and telephone number of the owner or operator's representative within the company who is the contact person for this facility regarding the engineering study and affected sources, and

*Gary Scotton*  
*EHS Manager*  
*1204 Massillon Road*  
*Akron, OH 44306*  
*(330) 796-5933*  
[Gary.Scotton@parker.com](mailto:Gary.Scotton@parker.com)

- c) The name, title, address, and telephone number of the official who is responsible for approval of the engineering study:

*Patrick Sines*  
*Senior Manager, Site Operations*  
*1204 Massillon Road*  
*Akron, OH 44306*  
*(330) 208-3634*  
[Patrick.Sines@parker.com](mailto:Patrick.Sines@parker.com)

- d) The standard industrial classification code and source classification code numbers which are applicable to the facility's operation:

*SIC Code: 3728*  
*SCC: 3-09-900-03*

## **2.2 Permitted VOC Sources**

Table 2-1 summarizes the PTIO permitted VOC sources at the Akron Facility. A detailed documentation of the approach for calculating potential to emit (PTE) is provided in Appendix A.

As shown in Table 2-1, Meggitt operates a touch up booth (i.e., K008), three portable parts washers (i.e., L007), a Grieve oven (i.e., P023), a foam packaging system (i.e., Z706), and a research and development furnace (TMP187138) that are de minimis sources of VOC emissions which are excluded from the RACT study.

The Akron Facility operates eight carbon processing electric induction coil furnaces (i.e., P036-P039, P041, P044, and P048-P049) that are subject to a non-CTG RACT determination at OAC 3745-21-11. The remainder of this study provides proposed VOC RACT determinations for these sources.

**Table 2-1. PTIO Permitted VOC Sources at the Akron Facility<sup>a</sup>**

| <b>Emission Unit ID</b>                                   | <b>Emission Unit Description</b> | <b>Current VOC Control</b> | <b>VOC PTE (tpy)</b> | <b>Current VOC Emission Limit(s)</b> | <b>VOC RACT Applicability</b> |
|-----------------------------------------------------------|----------------------------------|----------------------------|----------------------|--------------------------------------|-------------------------------|
| P036, P037, P038, P041, P044, P048, and P049 <sup>b</sup> | Carbon Processing Furnaces       | Thermal Oxidizer           | 11.3                 | 11.67                                | RACT Study                    |
| P039 <sup>b</sup>                                         | Accutherm Carbonization Furnace  |                            | 0.4                  |                                      |                               |

a. Excludes de-minimis and insignificant sources.

b. P036-P039, P041, P044, and P048-P049 are subject to a combined VOC emission limit of 11.67 tons per rolling, 12-month period.

## 3. RACT DETERMINATION

---

As discussed in Section 1 above, Meggitt is required to perform a RACT study for carbon processing furnaces (i.e, Ohio EPA Emission Unit IDs P036, P037, P038, P039, P041, P044, P048, and P049) pursuant to OAC 3745-21-11. Appendix B provides source specific information required by OAC 3745-21-11(B)(1) through (7). The following sections include a detailed description of the source followed by the top-down RACT analysis.

### 3.1 Source Overview

Meggitt operates carbon processing electric induction coil furnaces (i.e, Ohio EPA Emission Unit IDs P036, P037, P038, P039, P041, P044, P048, and P049), which are industrial thermal treatment units used to heat carbon-containing materials to high temperatures under controlled conditions. The furnaces perform processes such as carbonization, heat treatment, or stabilization to modify the physical and mechanical properties of the material, including strength, hardness, and thermal resistance.

Carbonization is a controlled thermal treatment process in which carbon-containing materials are heated in a high-temperature furnace operated under oxygen-limited or inert conditions. The purpose of the process is to thermally decompose organic constituents and remove volatile material while converting the processed material into a carbon-rich solid with improved structural and thermal properties.

The furnace is operated using controlled heating rates dependent on product requirements. The process environment prevents oxidation and open combustion; no direct flame contact occurs between the heating source and the material being processed.

VOC emissions associated with carbonization are generated as process emissions resulting from thermal decomposition of organic binders, resins, or other carbon-containing constituents within the material. As temperature increases, volatile organic compounds, moisture, and light hydrocarbons are driven off as off-gas.

The carbonization process itself is not a combustion process. Any fuel firing associated with the unit is limited to indirect heating of the furnace chamber and does not constitute a primary source of VOC emissions.

Off-gases from the carbonization furnace may contain, VOCs, Carbon Monoxide (CO), Methane and other hydrocarbons, and Carbon Dioxide (CO<sub>2</sub>). Emission composition and quantity depend on material type, throughput, and operating temperature.

The carbonization process at Meggitt's Akron facility does not include coating operations, or cleanup solvents. Therefore, the requirements of OAC 3745-21(B)(7)(e) and (f), which are for coating operations and solvent cleaning activities, do not apply to Meggitt.

### 3.2 Control Overview

The carbon furnaces are equipped with thermal oxidizers, which are an air pollution control device used to control VOC emissions generated as process off-gases from the carbonization process. There are two thermal oxidizers associated with P036-P038, P041, P044, and P048-P049, and an additional thermal

oxidizer associated with P039. Process exhaust gases from the carbonization furnaces are ducted directly to the thermal oxidizers, where VOCs and other combustibles are destroyed through high-temperature oxidation prior to atmospheric release.

The thermal oxidizers are regulated through Permit-to-Install and Operate (PTIO) P0129464, which contains enforceable operating parameters, including continuous monitoring and recordkeeping, to maintain minimum combustion temperatures. Additionally, the PTIO requires stack testing to demonstrate compliance with the allowable mass emission rates for VOC, organic hazardous air pollutants (HAPs), and organic material (OM). Appendix C provides a copy of the most recent stack test as required by OAC 3745-21-11(B)(7)(h).

A top-down RACT analysis was not performed for the carbon furnaces because the units are already equipped with thermal oxidizers that represent the highest level of reasonably available VOC control technology for this source category. Exhaust gases from the carbon furnaces are routed to thermal oxidizers designed and operated to achieve a VOC destruction efficiency of 99%.

Capture efficiency is estimated to exceed 99% because furnace exhaust is conveyed through a dedicated closed-duct system directly to a thermal oxidizer, and the furnaces are maintained under vacuum throughout the carbonization process. The integrity of the exhaust ductwork is critical because the introduction of oxygen into a furnace during carbonization could create a significant safety hazard, including the potential for fire or other upset conditions.

Thermal oxidation is widely recognized as the most effective and commonly implemented control technology for high-temperature, continuous industrial furnace exhaust streams containing VOCs. The installed thermal oxidizers provide near-complete oxidation of organic compounds and represents the upper bound of feasible VOC control performance for this type of process. Alternative control technology evaluated under a traditional top-down analysis (i.e., carbon adsorption, catalytic incinerator, condenser, scrubber, or alternative combustion-based controls) would not provide a materially higher level of control than the existing 99% destruction efficiency, nor would they be technically practicable for the furnace exhaust conditions.

Because the unit already achieves VOC emission reductions consistent with the most stringent level of control that is reasonably available, there are no technically feasible or economically reasonable control options that would result in a meaningful incremental reduction in VOC emissions beyond the existing configuration. Therefore, a top-down RACT analysis would not identify any additional RACT-level controls and would not materially inform the determination of RACT for this emission unit.

Accordingly, the existing carbon furnaces equipped with thermal oxidizers with a destruction efficiency of 99% are considered to meet RACT, and no further controls are evaluated.

### **3.3 Source Modification/Replacement**

In accordance with OAC 3745-21-11(B)(11), this RACT evaluation includes consideration of process modifications or operational changes that could reduce or eliminate VOC emissions at the source.

The carbonization furnaces are integral to Meggitt's operations. These emission units are used to thermally process materials under controlled conditions to achieve required product characteristics and performance specifications. Continuous and reliable operation of the carbonization furnaces is necessary to meet production demands and maintain product quality and consistency.

Potential pollution prevention measures, including reductions in furnace operating frequency or limitations on operating hours, or elimination of carbonization activities, were evaluated. However, implementation of such measures would directly interfere with the Meggitt facility's ability to meet its manufacturing, quality assurance, and customer requirements and would not be consistent with the intended function of the source. The furnaces are operated in accordance with established production and operating practices designed to optimize thermal efficiency and minimize unnecessary material throughput, thereby limiting VOC generation to the extent practicable.

Based on this evaluation, elimination or substantial modification of the carbonization furnace operations is not technically feasible.

### **3.4 RACT Determination**

The proposed RACT determination for VOC emissions from the carbon furnace is the continued operation of the existing thermal oxidizers in accordance with the operating requirements specified in PTIO P0129464. The thermal oxidizers are designed and operated to achieve a VOC capture and destruction efficiency of 99% and represent the most effective and commonly applied control technology for this type of emission source.

Continued operation of the thermal oxidizers ensures that VOC emissions from the carbon furnaces are controlled to a level consistent with the maximum degree of emission reduction that is reasonably available. No additional add-on controls or process modifications have been identified that would result in a meaningful incremental reduction in VOC emissions beyond the performance achieved by the existing control device. Therefore, continued operation and proper maintenance of the thermal oxidizer is proposed as RACT for the carbon furnace.

## **APPENDIX A. POTENTIAL-TO-EMIT DOCUMENTATION**

---

**REDACTED**

**REDACTED**

MEGGITT AIRCRAFT BRAKING SYSTEMS CORPORATION  
AKRON, OHIO

EMISSION CALCULATIONS

**REDACTED**

**REDACTED**

**REDACTED**

## APPENDIX B. SOURCE INFORMATION

**Appendix Table B-1. General Source Information**

| <b>Emission Unit ID</b> | <b>Emission Unit Description</b> | <b>Installation Date (Month and Year)</b> | <b>Operating Schedule (hrs/day / days/week / weeks/yr)</b> | <b>Control Equipment</b> | <b>Control Device Installation Date</b> |
|-------------------------|----------------------------------|-------------------------------------------|------------------------------------------------------------|--------------------------|-----------------------------------------|
| P036                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P037                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P038                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P039                    | Accutherm Carbonization Furnace  | 6/1996                                    | 24/7/52                                                    | Thermal Oxidizer         | 3/1/1996                                |
| P041                    | Carbon Processing Furnace        | 12/1998                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P044                    | Carbon Processing Furnace        | 7/1999                                    | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P048                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P049                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |

**Appendix Table B-2. Annual Production Rates for 2022-2024**

| <b>Emission Unit ID</b>                | <b>Production Units</b> | <b>Average Daily Production Rates</b> |      |      | <b>Maximum Daily Production Rates</b> |      |      | <b>Annual Production Rates</b> |      |      |
|----------------------------------------|-------------------------|---------------------------------------|------|------|---------------------------------------|------|------|--------------------------------|------|------|
|                                        |                         | 2023                                  | 2024 | 2025 | 2023                                  | 2024 | 2025 | 2023                           | 2024 | 2025 |
| P036                                   | ■                       | ■                                     | ■    | ■    | ■                                     | ■    | ■    | ■                              | ■    | ■    |
| P037, P038, P041, P044, P048, and P049 | ■                       | ■                                     | ■    | ■    | ■                                     | ■    | ■    | ■                              | ■    | ■    |
| P039                                   | ■                       | ■                                     | ■    | ■    | ■                                     | ■    | ■    | ■                              | ■    | ■    |


**Appendix Table B-3. Average and Maximum Daily and Annual Actual VOC Emissions<sup>a</sup>**

| <b>OEPA Emission Unit ID</b>              | <b>Emission Unit Description</b> | <b>Average<br/>Daily VOC<br/>Emissions<br/>(lb/day)</b> | <b>Maximum<br/>Daily VOC<br/>Emissions<br/>(lb/day)</b> | <b>Maximum<br/>Annual VOC<br/>Emissions<br/>(tpy)</b> |
|-------------------------------------------|----------------------------------|---------------------------------------------------------|---------------------------------------------------------|-------------------------------------------------------|
| P036                                      | Carbon Processing Furnaces       |                                                         | Did not operate                                         |                                                       |
| P037, P038, P041, P044,<br>P048, and P049 | Carbon Processing Furnaces       | 0.61                                                    | 0.78                                                    | 0.11                                                  |
| P039                                      | Accutherm Carbonization Furnace  | 0.68                                                    | 0.35                                                    | 0.05                                                  |

<sup>a</sup> As specified by OAC 3745-21-11(B)(7) the average daily, maximum daily, and maximum annual VOC emissions are based upon the highest production rates for each of the three full calendar years preceding submission of the RACT study (i.e., 2023-2025).

## **Appendix Figure B-1. Facility Plot Plan**





## **APPENDIX C. THERMAL OXIDIZER STACK TEST RESULTS**

---



Meggitt Aircraft Braking Systems Corporation  
1204 Massillon Road  
Akron, Ohio 44306

### Report

Performed Velocity, Moisture, Temperature, Volumetric Flow Rate  
and Volatile Organic Compounds Emissions Testing

Sampling performed on the North & South Afterburner Outlets

Akron, OH

Test Date: 12/7/20 & 12/8/20

**Meggitt Aircraft Braking Systems Corporation  
1204 Massillon Road  
Akron, Ohio 44306**

**Report**

**Performed Velocity, Moisture, Temperature, Volumetric Flow Rate  
and Volatile Organic Compounds Emissions Testing**

**Sampling performed on the North & South Afterburner Outlets**

**Akron, OH**

**Test Date: 12/7/20 & 12/8/20**

A handwritten signature in black ink, reading "Brian E. Lemasters". The signature is written in a cursive, flowing style. The first name "Brian" is written with a large, stylized 'B'. The middle initial "E" is smaller and positioned between the first and last names. The last name "Lemasters" is written in a similar cursive style, with a large 'L' and a trailing flourish.

**Brian E. Lemasters  
Custom Stack Analysis, LLC.**

## REPORT CERTIFICATION

Custom Stack Analysis, LLC. has used its professional experience and best professional efforts in performing this compliance test. I have reviewed the results of these tests and to the best of my knowledge and belief they are true and correct.

A handwritten signature in black ink that reads "Brian E. Lemasters". The signature is written in a cursive style with a large, stylized 'B' and 'L'.

Brian E.Lemasters

## **TABLE OF CONTENTS**

|                                 |       |
|---------------------------------|-------|
| Executive Summary .....         | 1-2   |
| Test Results .....              | 3-4   |
| Methods Description .....       | 5-6   |
| Sampling Train Diagrams .....   | 7-8   |
| Sampling Point Description..... | 9-10  |
| Calculations .....              | 11-18 |

### **APPENDIX**

|                        |   |
|------------------------|---|
| Test Data .....        | 1 |
| Laboratory Data .....  | 2 |
| Calibration Data ..... | 3 |
| Monitoring Data .....  | 4 |

## **EXECUTIVE SUMMARY**

Custom Stack Analysis, LLC. conducted emissions sampling using USEPA Methods 1-4 and 25A at Facility ID# - 1677010999. Testing was conducted on the North & South Afterburner Outlets on December 7<sup>th</sup> & 8<sup>th</sup>, 2020 for compliance purposes - Permit # - P0121253 (see Table 1.2).

The Custom Stack Analysis, LLC. test crew consisted of Mr. James Gray, Mr. Brian Lemasters and Mr. Ethan Minor. The testing procedures were coordinated by Mr. Jim Davies and Mr. Jon Carver of Meggitt Aircraft Braking Systems Corporation (see Table 1.1).

**Table 1.1: Emissions Testing Program Contact Personnel**

| Name, Title                                                                                                         | Company Address                                                                | Phone, Fax, email                              |
|---------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|------------------------------------------------|
| Mr. Jim Davies<br>Mr. Jon Carver                                                                                    | Meggitt Aircraft Braking Corporation<br>1204 Massillon Road<br>Akron, OH 44306 | (330) 796-1743 (Phone)                         |
| Mr. James Gray<br>Owner<br><br>Mr. Brian Lemasters<br>Project Manager<br><br>Mr. Ethan Minor<br>Project Technicians | Custom Stack Analysis, LLC.<br>14614 Cenfield St. N.E.<br>Alliance, OH 44601   | (330) 525-5119 (Phone)<br>(330) 525-7908 (Fax) |

Test results are located on pages 3-4. A description of the testing protocol is included on pages 5-6. All testing calculations are located on pages 11-18. Appendix 1 includes field test data. Appendix 2 contains laboratory data from Custom Stack Analysis, LLC. Appendix 3 contains calibration data for the equipment used on test day. Appendix 4 contains monitoring data.

Table 1.2 demonstrates how Meggitt Aircraft Baking Systems Corporation in Akron, OH is operating in compliance with the applicable emission standards.

**Table 1.2: Emission Limits and Test Results Summary**

| Pollutant                  | Emission Limitations | Test Result Average                                                  | Compliance Demonstrated |
|----------------------------|----------------------|----------------------------------------------------------------------|-------------------------|
| Volatile Organic Compounds | See below            | <b><u>North Afterburner</u></b><br>0.00415 lbs/hr<br>0.0182 tons/yr  | Yes<br>Yes              |
|                            |                      | <b><u>South Afterburner</u></b><br>0.00166 lbs/hr<br>0.00726 tons/yr | Yes<br>Yes              |

Individual unit VOC limitations:

- from emissions units P036 and P048, combined, 2.5 lb/hr and 10.95 ton/yr
- from emissions units P037 and P049, combined, 2.5 lb/hr and 10.95 ton/yr
- from emissions unit P038, 2.5 lb/hr and 10.95 ton/yr
- from emissions unit P041, 2.5 lb/hr and 10.95 ton/yr
- from emissions unit P044, 2.47 lb/hr and 10.82 ton/yr

The overall combined VOC emissions from emissions units P036, P037, P038, P041, P044, P048 and P049 are limited to 11.31 ton/yr.

# Test Results

Meggitt Aircraft Braking Systems Corporation - North Afterburner Outlet  
12/7/2020

Methods 1-4 & 25A

|                              | <b><u>Run #1</u></b> | <b><u>Run #2</u></b> | <b><u>Run #3</u></b> | <b><u>Avg.</u></b> |
|------------------------------|----------------------|----------------------|----------------------|--------------------|
| Stack Gas Velocity (ft/sec)  | 37.31                | 38.22                | 38.31                | 37.95              |
| Standard Cubic Feet an Hour  | 227,390              | 230,154              | 232,946              | 230,163            |
| Actual Cubic Feet per Minute | 15,822               | 16,212               | 16,246               | 16,093             |
| Moisture %                   | 8.18%                | 8.70%                | 8.48%                | 8.45%              |
| Carbon Dioxide %             | 4.33%                | 4.17%                | 4.17%                | 4.22%              |
| Oxygen %                     | 12.17%               | 12.33%               | 12.17%               | 12.22%             |
| Nitrogen %                   | 83.50%               | 83.50%               | 83.66%               | 83.55%             |

## Method 25A

|                 |          |          |          |          |
|-----------------|----------|----------|----------|----------|
| VOC (ppm)       | 0.20     | 0.19     | 0.20     | 0.19     |
| (lbs/hr Carbon) | 4.17E-03 | 4.01E-03 | 4.29E-03 | 4.15E-03 |
| (tons/yr)       | 1.83E-02 | 1.76E-02 | 1.88E-02 | 1.82E-02 |

# Test Results

Meggitt Aircraft Braking Systems Corporation - South Afterburner Outet

12/8/2020

Methods 1-4 & 25A

|                              | <b><u>Run #1</u></b> | <b><u>Run #2</u></b> | <b><u>Run #3</u></b> | <b><u>Avg.</u></b> |
|------------------------------|----------------------|----------------------|----------------------|--------------------|
| Stack Gas Velocity (ft/sec)  | 30.58                | 30.95                | 30.53                | 30.69              |
| Standard Cubic Feet an Hour  | 197,116              | 195,080              | 190,059              | 194,085            |
| Actual Cubic Feet per Minute | 12,968               | 13,128               | 12,950               | 13,015             |
| Moisture %                   | 8.46%                | 8.80%                | 8.39%                | 8.55%              |
| Carbon Dioxide %             | 4.83%                | 4.83%                | 4.83%                | 4.83%              |
| Oxygen %                     | 11.67%               | 11.67%               | 11.50%               | 11.61%             |
| Nitrogen %                   | 83.50%               | 83.50%               | 83.67%               | 83.56%             |

## Method 25A

|                 |          |          |          |          |
|-----------------|----------|----------|----------|----------|
| VOC (ppm)       | 0.11     | 0.09     | 0.08     | 0.09     |
| (lbs/hr Carbon) | 2.01E-03 | 1.60E-03 | 1.36E-03 | 1.66E-03 |
| (tons/yr)       | 8.82E-03 | 7.01E-03 | 5.95E-03 | 7.26E-03 |

## **METHOD 1**

Sample and velocity traverses for stationary sources.

To aid in the representative measurement of pollutant emissions and/ or total volumetric flow rate from a stationary source, a measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas. A traverse point is then located within each of these equal areas.

## **METHOD 2**

Determination of stack gas velocity and volumetric flow rate.

The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Staustscheibe or reverse type) pitot tube.

## **METHOD 3**

Gas analysis for the determination of dry molecular weight.

This method is applicable for determining carbon dioxide and oxygen concentrations and dry molecular weight of a sample from a gas stream of a fossil-fuel combustion process.

## **METHOD 4**

Determination of moisture content in stack gases.

A gas sample is extracted at a constant rate from the source. It is determined either volumetrically or gravimetrically.

## METHOD 25A TESTING DESCRIPTION

This method will be used to measure the total VOC concentration expressed in terms of ppm propane. A gas sample is extracted from the source through a stainless steel probe, through a heated sample line (teflon), to a flame ionization analyzer. The main components of Method 25A are the same as Method 204B with the exception of a non heated sample probe.

The sampling system is heated up to the proper operating temperature. Within two hours of the start of the test the FIA is calibrated. The calibration range or span is selected to be from 1.5 to 2.5 times the expected concentration. Three calibration ranges are then selected as follows: Low level 25-35% of the span, Mid level 45-55% of the span, and a High level 80-90% of the span. A zero and a high level calibration gas is then injected at the valve assembly and the FIA is adjusted to these levels. Then all four gases are introduced into the analyzer and recorded. If the responses are within 5% of the expected values then the analyzer is responding correctly. The sample probe is located in the center of the stack and sealed in place and the test is started. The test lasts for 60 minutes. At the end of the test run a drift check is run. The zero gas and the mid level calibration gas is injected at the valve assembly. The analyzer responses are then recorded. The drift check is acceptable if the results are within 3% of the span value. These checks are performed before and after each test run.






FIGURE 3

# 25A Sampling System




## Location of Sampling Points



|                |                          |        |        |
|----------------|--------------------------|--------|--------|
| Location:      | North Afterburner Outlet |        |        |
| Upstream       | 3'                       |        |        |
| Downstream     | 15'                      |        |        |
| Stack Diameter | 36                       | Inches |        |
| Sample Point # |                          |        |        |
|                | 1                        | 1.6    | Inches |
|                | 2                        | 5.3    |        |
|                | 3                        | 10.7   |        |
|                | 4                        | 25.3   |        |
|                | 5                        | 30.7   |        |
|                | 6                        | 34.4   |        |

## Location of Sampling Points



|                |                          |        |        |
|----------------|--------------------------|--------|--------|
| Location:      | South Afterburner Outlet |        |        |
| Upstream       | 3'                       |        |        |
| Downstream     | 15'                      |        |        |
| Stack Diameter | 36                       | Inches |        |
| Sample Point # |                          |        |        |
|                | 1                        | 1.6    | Inches |
|                | 2                        | 5.3    |        |
|                | 3                        | 10.7   |        |
|                | 4                        | 25.3   |        |
|                | 5                        | 30.7   |        |
|                | 6                        | 34.4   |        |

# CALCULATIONS

## North Afterburner Outlet

|    |                 | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|----|-----------------|---------------|---------------|---------------|---|
| 1. | <b>Vm (std)</b> | 42.74         | 42.04         | 42.21         | = |

$$VM * 17.64 * \frac{PBAR + 13.6}{Tm} * Y$$

|          |                                                                    |   |                        |                        |                        |
|----------|--------------------------------------------------------------------|---|------------------------|------------------------|------------------------|
| Vm (std) | = Volume of gas collected, corrected to standard conditions, cuft. | = | <u>RUN #1</u><br>42.74 | <u>RUN #2</u><br>42.04 | <u>RUN #3</u><br>42.21 |
| Vm       | = Volume of gas sampled at meter box, cuft.                        | = | 45.13                  | 44.39                  | 44.53                  |
| 17.64    | = Standard temperature, 528 Rankine / std pressure, 29.92.         | = | 17.64                  | 17.64                  | 17.64                  |
| Tm       | = Average dry gas meter temperature, + 460 Rankine.                | = | 538.58333              | 538.58333              | 538.16667              |
| Pbar     | = Barometric pressure, inches of mercury (Hg)                      | = | 28.76                  | 28.76                  | 28.76                  |
| ^H       | = Average pressure differential across orifice.                    | = | 2                      | 2                      | 2                      |
| 13.6     | = Specific gravity of mercury.                                     | = | 13.6                   | 13.6                   | 13.6                   |
| Y        | = Calibration factor of meter box.                                 | = | 1.0004                 | 1.0004                 | 1.0004                 |

|    |                 | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|----|-----------------|---------------|---------------|---------------|---|
| 2. | <b>Vw (std)</b> | 3.81          | 4.01          | 3.91          | = |

$$Vlc * \frac{P H20}{Mh20} * \frac{R Tstd}{Pstd} = K2 * Vlc$$

|       |                                                     |   |                       |                     |                     |
|-------|-----------------------------------------------------|---|-----------------------|---------------------|---------------------|
| Vlc   | = Volume of water and silica collected.             | = | <u>RUN #1</u><br>80.8 | <u>RUN #2</u><br>85 | <u>RUN #3</u><br>83 |
| P H20 | = Density of water, 0.002201 lb/ml.                 | = | 0.002201              | 0.002201            | 0.002201            |
| M H20 | = Molecular weight of water, 18.01 lb/lb-mole.      | = | 18.01                 | 18.01               | 18.01               |
| R     | = Ideal gas constant, 21.85 in. hg - ft3/R-lb-mole. | = | 21.85                 | 21.85               | 21.85               |
| Tstd  | = Standard absolute temperature, 528 R.             | = | 528                   | 528                 | 528                 |
| Pstd  | = Standard absolute pressure, 29.92 in. Hg.         | = | 29.92                 | 29.92               | 29.92               |
| K2    | = 0.0471 ft3 / ml.                                  | = | 0.0471                | 0.0471              | 0.0471              |

|    |            | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|----|------------|---------------|---------------|---------------|---|
| 3. | <b>Bws</b> | 0.08180       | 0.08698       | 0.08481       | = |

$$\frac{Vw(std)}{Vm(std) + Vw(std)}$$

|         |                                                 |   |                          |                          |                          |
|---------|-------------------------------------------------|---|--------------------------|--------------------------|--------------------------|
| Bws     | = Water vapor in the gas stream, proportion.    | = | <u>RUN #1</u><br>0.08180 | <u>RUN #2</u><br>0.08698 | <u>RUN #3</u><br>0.08481 |
| Vw(std) | = Volume of water vapor in the gas sample, scf. | = | 3.81                     | 4.01                     | 3.91                     |
| Vm(std) | = Volume of gas sampled at meter box, scf.      | = | 42.74                    | 42.04                    | 42.21                    |

|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                  |               |               |  |
|----|----------------------------------------------------------|-----------------------------------------------------|---------------|---------------|---|----------------------------------------------------------------------------------|---------------|---------------|--|
| 4. | <b>Md</b>                                                | 29.1796                                             | 29.1604       | 29.154        | = | <div>0.44 (%CO2) + 0.32 (%O2) + 0.28 (%N2) + %CO</div>                           |               |               |  |
|    | Md                                                       | = Dry molecular weight, lb / lb-mole.               |               |               | = | <u>RUN #1</u>                                                                    | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 29.18                                                                            | 29.16         | 29.15         |  |
|    | 0.44                                                     | = Molecular weight of CO2 divided by 100.           |               |               | = | 0.44                                                                             | 0.44          | 0.44          |  |
|    | 0.32                                                     | = Molecular weight of O2 divided by 100.            |               |               | = | 0.32                                                                             | 0.32          | 0.32          |  |
|    | 0.28                                                     | = Molecular weight of N2 or CO divided by 100.      |               |               | = | 0.28                                                                             | 0.28          | 0.28          |  |
|    | Co2, O2, N2, and CO are in percent by volume, dry basis. |                                                     |               |               |   |                                                                                  |               |               |  |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                  |               |               |  |
| 5. | <b>Ms</b>                                                | 28.27                                               | 28.19         | 28.21         | = | <div>Md * (1-Bws) + M H2O * (Bws)</div>                                          |               |               |  |
|    | Ms                                                       | = Molecular weight of gas , wet basis, lb /lb-mole. |               |               | = | <u>RUN #1</u>                                                                    | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 28.27                                                                            | 28.19         | 28.21         |  |
|    | M H2O                                                    | = Molecular weight of water, 18 lb / lb-mole.       |               |               | = | 18                                                                               | 18            | 18            |  |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                  |               |               |  |
| 6. | <b>Vs</b>                                                | 37.31                                               | 38.22         | 38.31         | = | <div><div>85.49 * Cp √ ∆p √ <math>\frac{T_s + 460}{P_s * M_s}</math></div></div> |               |               |  |
|    | Vs                                                       | = Average stack gas velocity, ft / sec.             |               |               | = | <u>RUN #1</u>                                                                    | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 37.31                                                                            | 38.22         | 38.31         |  |
|    | 85.49                                                    | = Pitot tube constant, ft / sec.                    |               |               | = | 85.49                                                                            | 85.49         | 85.49         |  |
|    | Cp                                                       | = Pitot tube coefficient, dimensionless.            |               |               | = | 0.84                                                                             | 0.84          | 0.84          |  |
|    | ∆P                                                       | = Velocity head of stack gas, avg. sq rt.           |               |               | = | 0.33580                                                                          | 0.34248       | 0.34462       |  |
|    | Ts                                                       | = Temperature of stack gas, + 460 (Rankine).        |               |               | = | 1948.2083                                                                        | 1961          | 1946          |  |
|    | Ps                                                       | = Absolute stack gas pressure, barometric + static. |               |               | = | 28.80                                                                            | 28.80         | 28.80         |  |
|    | Ms                                                       | = Molecular weight of stack gas, wet basis.         |               |               | = | 28.27                                                                            | 28.19         | 28.21         |  |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                  |               |               |  |
| 7. | <b>ACFM</b>                                              | 15821.95                                            | 16211.57      | 16246.01      | = | <div>Stack Area * 60 * Vs</div>                                                  |               |               |  |
|    | Vs                                                       | = Average stack gas velocity, ft / sec.             |               |               | = | <u>RUN #1</u>                                                                    | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 37.31                                                                            | 38.22         | 38.31         |  |

|   |      | <u>RUN #1</u> | <u>RUN #2</u>                                     | <u>RUN #3</u> |   |                                                                                                                                                         |
|---|------|---------------|---------------------------------------------------|---------------|---|---------------------------------------------------------------------------------------------------------------------------------------------------------|
| 8 | SCFH | 227390        | 230154                                            | 232946        | = | <div><div><div>Tstd</div><div>Ps</div></div><div><div>3600 * ( 1 - Bws ) * Vs * A</div><div><div>Ts</div><div>Pstd</div></div></div></div>              |
|   |      |               |                                                   |               |   | <div><div><div><u>RUN #1</u></div><div>3600</div></div><div><u>RUN #2</u></div><div>3600</div></div> <div><div><u>RUN #3</u></div><div>3600</div></div> |
|   | 3600 | =             | Seconds per hour.                                 |               | = |                                                                                                                                                         |
|   | Bws  | =             | Water vapor in the gas stream, proportion.        |               | = | 0.0817974 0.0869803 0.084805                                                                                                                            |
|   | A    | =             | Area of stack in sq ft.                           |               | = | 7.07 7.07 7.07                                                                                                                                          |
|   | Tstd | =             | Standard absolute temperature, 528 R.             |               | = | 528 528 528                                                                                                                                             |
|   | Pstd | =             | Standard absolute pressure, 29.92 in. Hg.         |               | = | 29.92 29.92 29.92                                                                                                                                       |
|   | Ts   | =             | Temperature of stack gas, + 460 (Rankine).        |               |   | 1948.2083 1961 1946                                                                                                                                     |
|   | Ps   | =             | Absolute stack gas pressure, barometric + static. |               |   | 28.76 28.76 28.76                                                                                                                                       |
|   | Vs   | =             | Average stack gas velocity, ft / sec.             |               |   | 37.31 38.22 38.31                                                                                                                                       |

## CALCULATIONS

| <u>VOC</u> |                       | <u>RUN #1</u> | <u>RUN #2</u>                                    | <u>RUN #3</u> |   |                                                                         |
|------------|-----------------------|---------------|--------------------------------------------------|---------------|---|-------------------------------------------------------------------------|
| 1.         | <b>Lbs/Hr Propane</b> | 0.00510       | 0.00490                                          | 0.00524       | = | 0.11443 * SCFH * PPM * 10 <sup>-6</sup>                                 |
|            | scfh                  | =             | Standard stack volumetric flow rate.             |               | = | <u>RUN #1</u><br>227390 <u>RUN #2</u><br>230154 <u>RUN #3</u><br>232946 |
|            | PPM                   | =             | PPM                                              |               | = | 0.1960352    0.1861953    0.1966794                                     |
| 2.         | <b>Lbs/Hr Carbon</b>  | 0.00417       | 0.00401                                          | 0.00429       | = | 0.031182 * SCFH * PPM * 3 * 10 <sup>-6</sup>                            |
|            | scfh                  | =             | Standard stack volumetric flow rate.             |               | = | <u>RUN #1</u><br>227390 <u>RUN #2</u><br>230154 <u>RUN #3</u><br>232946 |
|            | PPM                   | =             | PPM                                              |               | = | 0.1960352    0.1861953    0.1966794                                     |
|            | 3                     | =             | Carbon equivalent correction factor for propane. |               | = | 3                    3                    3                             |

# CALCULATIONS

## South Afterburner Outlet

|    |                 | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|----|-----------------|---------------|---------------|---------------|---|
| 1. | <b>Vm (std)</b> | 43.20         | 42.42         | 42.83         | = |

$$VM * 17.64 * \frac{PBAR + 13.6}{Tm} * Y$$

|          |                                                                    | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|----------|--------------------------------------------------------------------|---------------|---------------|---------------|
| Vm (std) | = Volume of gas collected, corrected to standard conditions, cuft. | 43.20         | 42.42         | 42.83         |
| Vm       | = Volume of gas sampled at meter box, cuft.                        | 45.21         | 44.38         | 44.80         |
| 17.64    | = Standard temperature, 528 Rankine / std pressure, 29.92.         | 17.64         | 17.64         | 17.64         |
| Tm       | = Average dry gas meter temperature, + 460 Rankine.                | 535.58333     | 535.33333     | 535.20833     |
| Pbar     | = Barometric pressure, inches of mercury (Hg)                      | 28.85         | 28.85         | 28.85         |
| ^H       | = Average pressure differential across orifice.                    | 2             | 2             | 2             |
| 13.6     | = Specific gravity of mercury.                                     | 13.6          | 13.6          | 13.6          |
| Y        | = Calibration factor of meter box.                                 | 1.0004        | 1.0004        | 1.0004        |

|    |                 | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|----|-----------------|---------------|---------------|---------------|---|
| 2. | <b>Vw (std)</b> | 3.99          | 4.09          | 3.92          | = |

$$Vlc * \frac{P H20}{Mh20} * \frac{R Tstd}{Pstd} = K2 * Vlc$$

|       |                                                     | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-------|-----------------------------------------------------|---------------|---------------|---------------|
| Vlc   | = Volume of water and silica collected.             | 84.7          | 86.9          | 83.2          |
| P H20 | = Density of water, 0.002201 lb/ml.                 | 0.002201      | 0.002201      | 0.002201      |
| M H20 | = Molecular weight of water, 18.01 lb/lb-mole.      | 18.01         | 18.01         | 18.01         |
| R     | = Ideal gas constant, 21.85 in. hg - ft3/R-lb-mole. | 21.85         | 21.85         | 21.85         |
| Tstd  | = Standard absolute temperature, 528 R.             | 528           | 528           | 528           |
| Pstd  | = Standard absolute pressure, 29.92 in. Hg.         | 29.92         | 29.92         | 29.92         |
| K2    | = 0.0471 ft3 / ml.                                  | 0.0471        | 0.0471        | 0.0471        |

|    |            | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|----|------------|---------------|---------------|---------------|---|
| 3. | <b>Bws</b> | 0.08458       | 0.08803       | 0.08385       | = |

$$\frac{Vw(std)}{Vm(std) + Vw(std)}$$

|         |                                                 | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|---------|-------------------------------------------------|---------------|---------------|---------------|
| Bws     | = Water vapor in the gas stream, proportion.    | 0.08458       | 0.08803       | 0.08385       |
| Vw(std) | = Volume of water vapor in the gas sample, scf. | 3.99          | 4.09          | 3.92          |
| Vm(std) | = Volume of gas sampled at meter box, scf.      | 43.20         | 42.42         | 42.83         |

|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                    |               |               |  |
|----|----------------------------------------------------------|-----------------------------------------------------|---------------|---------------|---|------------------------------------------------------------------------------------|---------------|---------------|--|
| 4. | <b>Md</b>                                                | 29.2396                                             | 29.2396       | 29.2328       | = | <u>0.44 (%CO2) + 0.32 (%O2) + 0.28 (%N2) + %CO)</u>                                |               |               |  |
|    | Md                                                       | = Dry molecular weight, lb / lb-mole.               |               |               | = | <u>RUN #1</u>                                                                      | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 29.24                                                                              | 29.24         | 29.23         |  |
|    | 0.44                                                     | = Molecular weight of CO2 divided by 100.           |               |               | = | 0.44                                                                               | 0.44          | 0.44          |  |
|    | 0.32                                                     | = Molecular weight of O2 divided by 100.            |               |               | = | 0.32                                                                               | 0.32          | 0.32          |  |
|    | 0.28                                                     | = Molecular weight of N2 or CO divided by 100.      |               |               | = | 0.28                                                                               | 0.28          | 0.28          |  |
|    | Co2, O2, N2, and CO are in percent by volume, dry basis. |                                                     |               |               |   |                                                                                    |               |               |  |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                    |               |               |  |
| 5. | <b>Ms</b>                                                | 28.29                                               | 28.25         | 28.29         | = | <u>Md * (1-Bws) + M H2O * (Bws)</u>                                                |               |               |  |
|    | Ms                                                       | = Molecular weight of gas , wet basis, lb /lb-mole. |               |               | = | <u>RUN #1</u>                                                                      | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 28.29                                                                              | 28.25         | 28.29         |  |
|    | M H2O                                                    | = Molecular weight of water, 18 lb / lb-mole.       |               |               | = | 18                                                                                 | 18            | 18            |  |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                    |               |               |  |
| 6. | <b>Vs</b>                                                | 30.58                                               | 30.95         | 30.53         | = | <u><math>85.49 * C_p \sqrt{\Delta p} \sqrt{\frac{T_s + 460}{P_s * M_s}}</math></u> |               |               |  |
|    | Vs                                                       | = Average stack gas velocity, ft / sec.             |               |               | = | <u>RUN #1</u>                                                                      | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 30.58                                                                              | 30.95         | 30.53         |  |
|    | 85.49                                                    | = Pitot tube constant, ft / sec.                    |               |               | = | 85.49                                                                              | 85.49         | 85.49         |  |
|    | Cp                                                       | = Pitot tube coefficient, dimensionless.            |               |               | = | 0.84                                                                               | 0.84          | 0.84          |  |
|    | ΔP                                                       | = Velocity head of stack gas, avg. sq rt.           |               |               | = | 0.28360                                                                            | 0.28421       | 0.27818       |  |
|    | Ts                                                       | = Temperature of stack gas, + 460 (Rankine).        |               |               | = | 1842.2083                                                                          | 1877          | 1909          |  |
|    | Ps                                                       | = Absolute stack gas pressure, barometric + static. |               |               | = | 28.89                                                                              | 28.89         | 28.89         |  |
|    | Ms                                                       | = Molecular weight of stack gas, wet basis.         |               |               | = | 28.29                                                                              | 28.25         | 28.29         |  |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                    |               |               |  |
| 7. | <b>ACFM</b>                                              | 12967.65                                            | 13127.84      | 12949.88      | = | <u>Stack Area * 60 * Vs</u>                                                        |               |               |  |
|    | Vs                                                       | = Average stack gas velocity, ft / sec.             |               |               | = | <u>RUN #1</u>                                                                      | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 30.58                                                                              | 30.95         | 30.53         |  |

|               |               | <u>RUN #1</u>                                     | <u>RUN #2</u> | <u>RUN #3</u> |           |                                                                                                                                            |               |               |               |      |      |      |
|---------------|---------------|---------------------------------------------------|---------------|---------------|-----------|--------------------------------------------------------------------------------------------------------------------------------------------|---------------|---------------|---------------|------|------|------|
| 8             | SCFH          | 197116                                            | 195080        | 190059        | =         | $3600 * ( 1 - Bws ) * Vs * A * \frac{Tstd}{Ts} * \frac{Ps}{Pstd}$                                                                          |               |               |               |      |      |      |
|               |               |                                                   |               |               |           |                                                                                                                                            |               |               |               |      |      |      |
|               |               |                                                   |               |               |           | <table><tr><th><u>RUN #1</u></th><th><u>RUN #2</u></th><th><u>RUN #3</u></th></tr><tr><td>3600</td><td>3600</td><td>3600</td></tr></table> | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> | 3600 | 3600 | 3600 |
| <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u>                                     |               |               |           |                                                                                                                                            |               |               |               |      |      |      |
| 3600          | 3600          | 3600                                              |               |               |           |                                                                                                                                            |               |               |               |      |      |      |
| 3600          | =             | Seconds per hour.                                 |               | =             |           |                                                                                                                                            |               |               |               |      |      |      |
| Bws           | =             | Water vapor in the gas stream, proportion.        |               | =             | 0.0845824 | 0.0880319 0.0838546                                                                                                                        |               |               |               |      |      |      |
| A             | =             | Area of stack in sq ft.                           |               | =             | 7.07      | 7.07 7.07                                                                                                                                  |               |               |               |      |      |      |
| Tstd          | =             | Standard absolute temperature, 528 R.             |               | =             | 528       | 528 528                                                                                                                                    |               |               |               |      |      |      |
| Pstd          | =             | Standard absolute pressure, 29.92 in. Hg.         |               | =             | 29.92     | 29.92 29.92                                                                                                                                |               |               |               |      |      |      |
| Ts            | =             | Temperature of stack gas, + 460 (Rankine).        |               |               | 1842.2083 | 1877 1909                                                                                                                                  |               |               |               |      |      |      |
| Ps            | =             | Absolute stack gas pressure, barometric + static. |               |               | 28.85     | 28.85 28.85                                                                                                                                |               |               |               |      |      |      |
| Vs            | =             | Average stack gas velocity, ft / sec.             |               |               | 30.58     | 30.95 30.53                                                                                                                                |               |               |               |      |      |      |

## CALCULATIONS

| <u>VOC</u> |                       | <u>RUN #1</u> | <u>RUN #2</u>                                    | <u>RUN #3</u> |   |                                                                         |
|------------|-----------------------|---------------|--------------------------------------------------|---------------|---|-------------------------------------------------------------------------|
| 1.         | <b>Lbs/Hr Propane</b> | 0.00246       | 0.00196                                          | 0.00166       | = | 0.11443 * SCFH * PPM * 10 <sup>-6</sup>                                 |
|            | scfh                  | =             | Standard stack volumetric flow rate.             |               | = | <u>RUN #1</u><br>197116 <u>RUN #2</u><br>195080 <u>RUN #3</u><br>190059 |
|            | PPM                   | =             | PPM                                              |               | = | 0.1092398    0.0877224    0.0764071                                     |
| 2.         | <b>Lbs/Hr Carbon</b>  | 0.00201       | 0.00160                                          | 0.00136       | = | 0.031182 * SCFH * PPM * 3 * 10 <sup>-6</sup>                            |
|            | scfh                  | =             | Standard stack volumetric flow rate.             |               | = | <u>RUN #1</u><br>197116 <u>RUN #2</u><br>195080 <u>RUN #3</u><br>190059 |
|            | PPM                   | =             | PPM                                              |               | = | 0.1092398    0.0877224    0.0764071                                     |
|            | 3                     | =             | Carbon equivalent correction factor for propane. |               | = | 3                      3                      3                         |

# **Appendix #1**

## **Test Data**

# Custom Stack Analysis, LLC.

## Pitot Traverse Data Sheet

Plant: ggitt Aircraft Braking Systems Corporat

Date 12/7/2020

Location North Afterburner

By Ethan M

| Run No. | Pre 1     |      | Post 1    |      | Post 2    |      | Post 3    |      |
|---------|-----------|------|-----------|------|-----------|------|-----------|------|
| Point # | Pitot Δ P | °F   | Pitot Δ P | °F   | Pitot Δ P | °F   | Pitot Δ P | °F   |
| A-1     | 0.16      | 1658 | 0.06      | 1547 | 0.08      | 1651 | 0.07      | 1733 |
| 2       | 0.18      | 1689 | 0.05      | 1599 | 0.10      | 1692 | 0.08      | 1762 |
| 3       | 0.26      | 1602 | 0.15      | 1671 | 0.11      | 1669 | 0.11      | 1593 |
| 4       | 0.22      | 1548 | 0.10      | 1292 | 0.09      | 1545 | 0.11      | 1448 |
| 5       | 0.18      | 1355 | 0.07      | 1074 | 0.07      | 1295 | 0.09      | 1233 |
| 6       | 0.10      | 1157 | 0.06      | 1048 | 0.06      | 1198 | 0.08      | 1054 |
| B-1     | 0.04      | 1680 | 0.15      | 1578 | 0.14      | 1660 | 0.11      | 1634 |
| 2       | 0.05      | 1720 | 0.17      | 1673 | 0.17      | 1697 | 0.22      | 1726 |
| 3       | 0.04      | 1612 | 0.22      | 1702 | 0.20      | 1633 | 0.22      | 1630 |
| 4       | 0.07      | 1413 | 0.19      | 1645 | 0.18      | 1524 | 0.16      | 1349 |
| 5       | 0.07      | 1235 | 0.16      | 1478 | 0.15      | 1475 | 0.14      | 1150 |
| 6       | 0.06      | 1118 | 0.11      | 1392 | 0.10      | 1289 | 0.11      | 1032 |

| Run #1  |       |         |       | Run #2 |         | Run #3 |       |         |
|---------|-------|---------|-------|--------|---------|--------|-------|---------|
|         | 0.34  | 1488.21 |       | 0.34   | 1501.13 |        | 0.34  | 1486.33 |
|         | 0.328 | 1502    | 0.343 | 1475   | 0.342   | 1527   | 0.347 | 1445    |
| Static: | 0.53  |         | 0.54  |        | 0.55    |        | 0.53  |         |

# TEST DATA

|              |                                                |
|--------------|------------------------------------------------|
| COMPANY NAME | Meggitt Aircraft Braking Systems Corporation - |
| ADDRESS      | 1204 Massillon Road                            |
| CITY         | Akron                                          |
| STATE        | OH                                             |
| ZIP          | 44306                                          |
| TEST METHODS | Methods 1-4 & 25A                              |
| CREW MEMBERS | Brian L. Ethan M                               |
| LOCATION     | Outlet                                         |
| SOURCE       | North Afterburner                              |
| CONTROL      |                                                |

|                     | RUN #1    | RUN #2    | RUN #3    |
|---------------------|-----------|-----------|-----------|
| DATE                | 12/7/2020 | 12/7/2020 | 12/7/2020 |
| RUN LENGTH (min)    | 60        | 60        | 60        |
| VOLUME (cubic feet) | 45.125    | 44.390    | 44.529    |
| Y FACTOR            | 1.0004    | 1.0004    | 1.0004    |
| BAROMETRIC          | 28.76     | 28.76     | 28.76     |
| METER TEMP. (R)     | 538.58    | 538.58    | 538.17    |
| STACK TEMP. (R)     | 1948.21   | 1961.13   | 1946.33   |
| AVERAGE ^P          | 0.34      | 0.34      | 0.34      |
| AVERAGE ^H          | 2.00      | 2.00      | 2.00      |
| IMPINGER VOLUME     | 80.80     | 85.00     | 83.00     |
|                     |           |           |           |
| PITOT COEF.         | 0.84      | 0.84      | 0.84      |
| STATIC PRESSURE     | 0.54      | 0.55      | 0.54      |
| STACK AREA          | 7.07      | 7.07      | 7.07      |
|                     |           |           |           |
| CARBON DIOXIDE      | 4.33      | 4.17      | 4.17      |
| OXYGEN              | 12.17     | 12.33     | 12.17     |
| NITROGEN            | 83.50     | 83.50     | 83.66     |

# TEST RESULTS

North Afterburner Outlet  
12/7/2020

|             | RUN #1    | RUN #2    | RUN #3    |
|-------------|-----------|-----------|-----------|
| VM (std)    | 42.741    | 42.044    | 42.209    |
| VW (std)    | 3.808     | 4.005     | 3.911     |
| BWS         | 0.082     | 0.087     | 0.085     |
| MD          | 29.180    | 29.160    | 29.154    |
| MS          | 28.265    | 28.190    | 28.208    |
| VS (ft/sec) | 37.306    | 38.224    | 38.306    |
|             |           |           |           |
| SCFH        | 227389.53 | 230153.95 | 232946.44 |
| ACFM        | 15821.95  | 16211.57  | 16246.01  |
| DCFM        | 3789.83   | 3835.90   | 3882.44   |

Vm (std) = Volume of gas sampled at standard conditions.

Vw (std) = Volume of water vapor collected at standard conditions.

Bws = Stack moisture content.

Md = Determination of dry molecular weight of stack gas.

Ms = Determination of stack gas molecular weight.

Vs = Average gas stack velocity. (ft/sec.)

ACFM = Actual cubic feet per minute of gas velocity.

DCFM = Dry standard cubic feet per minute of gas velocity.

# TEST RESULTS

North Afterburner Outlet

12/7/2020

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <u>CEM MONITORING</u> |        |        |        |
|                       |        |        |        |
| VOC (lbs/hr propane)  | 0.005  | 0.005  | 0.005  |
| VOC (lbs/hr carbon)   | 0.004  | 0.004  | 0.004  |

# TEST DATA

North Afterburner Outlet

12/7/2020

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <u>CEM MONITORING</u> |        |        |        |
|                       |        |        |        |
| VOC (ppm)             | 0.20   | 0.19   | 0.20   |

# Custom Stack Analysis, L.L.C.

## Method 4

Plant: eggitt Aircraft Braking Systems Corporati Date : 12/7/2020

North Afterburner Outlet

|                |       |                        |        |
|----------------|-------|------------------------|--------|
|                |       | Meter Box              |        |
| Barometer (Pg) | 28.76 | ID:                    | 1      |
| Ambient Temp   |       | Y                      | 1.0004 |
|                |       | $\Delta H$             | 1.986  |
|                |       | $\Delta H$ Set Point : | 2.0    |
|                | Time  | Run Time               |        |
| Start:         | 12:14 | 60                     |        |
| Stop:          | 13:14 |                        |        |

### Run #1

| Cold Box #  |              |        |            |    |           |         |
|-------------|--------------|--------|------------|----|-----------|---------|
| 9           | Meter Volume |        | Meter Temp |    | Cond Temp | VAC "Hg |
| Time        |              |        |            |    |           |         |
| 0           | 478.000      |        | 77         | 75 | 41        | 3       |
| 5           | 481.764      |        | 78         | 76 | 41        | 3       |
| 10          | 485.534      |        | 79         | 76 | 40        | 3       |
| 15          | 489.282      |        | 80         | 76 | 40        | 3       |
| 20          | 493.042      |        | 82         | 77 | 41        | 3       |
| 25          | 496.631      |        | 81         | 77 | 42        | 3       |
| 30          | 500.430      |        | 81         | 77 | 43        | 3       |
| 35          | 504.175      |        | 81         | 78 | 43        | 3       |
| 40          | 508.275      |        | 81         | 79 | 45        | 3       |
| 45          | 511.755      |        | 81         | 77 | 44        | 3       |
| 50          | 515.450      |        | 81         | 77 | 44        | 3       |
| 55          | 519.230      |        | 81         | 78 | 45        | 3       |
| 60          | 523.125      |        |            |    |           |         |
| Vm          | 45.125       |        |            |    |           |         |
| Leak Rate @ | AVG:         |        | 79         |    | 42.4      | 3.0     |
|             | 5.5          | " Hg = | 0.000      |    |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 13:45 | 60       |
| Stop:  | 14:45 |          |

## Run #2

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>6</b>           | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 526.364      | 79         | 77    | 42        | 4       |
| <b>5</b>           | 530.111      | 79         | 77    | 40        | 4       |
| <b>10</b>          | 533.812      | 79         | 77    | 39        | 4       |
| <b>15</b>          | 537.549      | 79         | 77    | 40        | 4       |
| <b>20</b>          | 541.278      | 80         | 77    | 41        | 4       |
| <b>25</b>          | 544.972      | 80         | 77    | 42        | 4       |
| <b>30</b>          | 548.684      | 80         | 77    | 43        | 4       |
| <b>35</b>          | 552.372      | 80         | 77    | 43        | 4       |
| <b>40</b>          | 556.058      | 80         | 78    | 45        | 4       |
| <b>45</b>          | 559.751      | 80         | 78    | 44        | 4       |
| <b>50</b>          | 563.435      | 80         | 78    | 44        | 4       |
| <b>55</b>          | 566.535      | 81         | 79    | 46        | 4       |
| <b>60</b>          | 570.754      |            |       |           |         |
| <b>Vm</b>          | 44.390       |            |       |           |         |
|                    | AVG:         | 79         |       | 42.4      | 4.0     |
| <b>Leak Rate @</b> | 8.0          | " Hg =     | 0.000 |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 15:13 | 60       |
| Stop:  | 16:13 |          |

### Run #3

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>11</b>          | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 571.148      | 78         | 77    | 39        | 4       |
| <b>5</b>           | 574.893      | 78         | 77    | 1         | 4       |
| <b>10</b>          | 578.625      | 79         | 77    | 41        | 4       |
| <b>15</b>          | 582.387      | 79         | 77    | 43        | 4       |
| <b>20</b>          | 586.065      | 79         | 78    | 44        | 4       |
| <b>25</b>          | 589.731      | 80         | 77    | 44        | 4       |
| <b>30</b>          | 593.435      | 80         | 78    | 45        | 4       |
| <b>35</b>          | 597.210      | 80         | 78    | 45        | 5       |
| <b>40</b>          | 600.935      | 79         | 77    | 47        | 5       |
| <b>45</b>          | 604.645      | 79         | 77    | 45        | 5       |
| <b>50</b>          | 608.345      | 80         | 77    | 46        | 5       |
| <b>55</b>          | 612.153      | 79         | 76    | 46        | 5       |
| <b>60</b>          | 615.677      |            |       |           |         |
| <b>Vm</b>          | 44.529       |            |       |           |         |
|                    | AVG:         | 78         |       | 40.5      | 5.0     |
| <b>Leak Rate @</b> | 8.5          | " Hg =     | 0.000 |           |         |

# Custom Stack Analysis, LLC.

## Pitot Traverse Data Sheet

Plant ggitt Aircraft Braking Systems Corpor

Date 12/8/2020

Location South Afterburner

By Ethan M

| Run No. | Pre 1     |      | Post 1    |      | Post 2    |      | Post 3    |      |
|---------|-----------|------|-----------|------|-----------|------|-----------|------|
| Point # | Pitot Δ P | °F   | Pitot Δ P | °F   | Pitot Δ P | °F   | Pitot Δ P | °F   |
| A-1     | 0.06      | 1743 | 0.08      | 1231 | 0.07      | 1356 | 0.07      | 1595 |
| 2       | 0.10      | 1703 | 0.11      | 1449 | 0.09      | 1523 | 0.10      | 1633 |
| 3       | 0.08      | 1538 | 0.11      | 1435 | 0.07      | 1701 | 0.08      | 1523 |
| 4       | 0.07      | 1144 | 0.10      | 1395 | 0.11      | 1658 | 0.07      | 1176 |
| 5       | 0.10      | 1236 | 0.09      | 1121 | 0.08      | 1432 | 0.06      | 1062 |
| 6       | 0.08      | 1087 | 0.07      | 1046 | 0.06      | 1134 | 0.07      | 1087 |
| B-1     | 0.06      | 1153 | 0.06      | 1467 | 0.05      | 1473 | 0.06      | 1543 |
| 2       | 0.07      | 1326 | 0.08      | 1692 | 0.08      | 1657 | 0.11      | 1687 |
| 3       | 0.06      | 1648 | 0.10      | 1581 | 0.07      | 1682 | 0.11      | 1654 |
| 4       | 0.08      | 1305 | 0.07      | 1411 | 0.10      | 1519 | 0.09      | 1521 |
| 5       | 0.10      | 1212 | 0.09      | 1275 | 0.09      | 1389 | 0.06      | 1362 |
| 6       | 0.06      | 1189 | 0.07      | 1168 | 0.06      | 1222 | 0.07      | 1198 |

|         |        |         |        |         |        |         |
|---------|--------|---------|--------|---------|--------|---------|
|         | Run #1 |         | Run #2 |         | Run #3 |         |
|         | 0.28   | 1382.21 | 0.28   | 1417.38 | 0.28   | 1449.46 |
|         | 0.276  | 1409    | 0.292  | 1356    | 0.277  | 1479    |
| Static: | 0.53   |         | 0.57   |         | 0.55   | 0.53    |

# TEST DATA

|              |                                                |
|--------------|------------------------------------------------|
| COMPANY NAME | Meggitt Aircraft Braking Systems Corporation - |
| ADDRESS      | 1204 Massillon Road                            |
| CITY         | Akron                                          |
| STATE        | OH                                             |
| ZIP          | 44306                                          |
| TEST METHODS | Methods 1-4 & 25A                              |
| CREW MEMBERS | Brian L. Ethan M                               |
| LOCATION     | Outlet                                         |
| SOURCE       | South Afterburner                              |
| CONTROL      |                                                |

|                     | RUN #1    | RUN #2    | RUN #3    |
|---------------------|-----------|-----------|-----------|
| DATE                | 12/8/2020 | 12/8/2020 | 12/8/2020 |
| RUN LENGTH (min)    | 60        | 60        | 60        |
| VOLUME (cubic feet) | 45.212    | 44.380    | 44.801    |
| Y FACTOR            | 1.0004    | 1.0004    | 1.0004    |
| BAROMETRIC          | 28.85     | 28.85     | 28.85     |
| METER TEMP. (R)     | 535.58    | 535.33    | 535.21    |
| STACK TEMP. (R)     | 1842.21   | 1877.38   | 1909.46   |
| AVERAGE ^P          | 0.28      | 0.28      | 0.28      |
| AVERAGE ^H          | 2.00      | 2.00      | 2.00      |
| IMPINGER VOLUME     | 84.70     | 86.90     | 83.20     |
|                     |           |           |           |
| PITOT COEF.         | 0.84      | 0.84      | 0.84      |
| STATIC PRESSURE     | 0.55      | 0.56      | 0.54      |
| STACK AREA          | 7.07      | 7.07      | 7.07      |
|                     |           |           |           |
| CARBON DIOXIDE      | 4.83      | 4.83      | 4.83      |
| OXYGEN              | 11.67     | 11.67     | 11.50     |
| NITROGEN            | 83.50     | 83.50     | 83.67     |

# TEST RESULTS

South Afterburner Outlet  
12/8/2020

|             | RUN #1    | RUN #2    | RUN #3    |
|-------------|-----------|-----------|-----------|
| VM (std)    | 43.197    | 42.422    | 42.834    |
| VW (std)    | 3.991     | 4.095     | 3.921     |
| BWS         | 0.085     | 0.088     | 0.084     |
| MD          | 29.240    | 29.240    | 29.233    |
| MS          | 28.289    | 28.250    | 28.291    |
| VS (ft/sec) | 30.576    | 30.954    | 30.534    |
|             |           |           |           |
| SCFH        | 197115.57 | 195079.74 | 190058.77 |
| ACFM        | 12967.65  | 13127.84  | 12949.88  |
| DCFM        | 3285.26   | 3251.33   | 3167.65   |

Vm (std) = Volume of gas sampled at standard conditions.

Vw (std) = Volume of water vapor collected at standard conditions.

Bws = Stack moisture content.

Md = Determination of dry molecular weight of stack gas.

Ms = Determination of stack gas molecular weight.

Vs = Average gas stack velocity. (ft/sec.)

ACFM = Actual cubic feet per minute of gas velocity.

DCFM = Dry standard cubic feet per minute of gas velocity.

# TEST RESULTS

South Afterburner Outet

12/8/2020

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <u>CEM MONITORING</u> |        |        |        |
|                       |        |        |        |
| VOC (lbs/hr propane)  | 0.002  | 0.002  | 0.002  |
| VOC (lbs/hr carbon)   | 0.002  | 0.002  | 0.001  |

# TEST DATA

South Afterburner Outet

12/8/2020

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <u>CEM MONITORING</u> |        |        |        |
|                       |        |        |        |
| VOC (ppm)             | 0.11   | 0.09   | 0.08   |

# Custom Stack Analysis, L.L.C.

## Method 4

Plant: eggitt Aircraft Braking Systems Corporati

Date : 12/8/2020

### South Afterburner Outet

|                |       | Meter Box              |          |
|----------------|-------|------------------------|----------|
| Barometer (Pg) | 28.85 | ID:                    | 1        |
| Ambient Temp   | 30    | Y                      | 1.0004   |
|                |       | $\Delta H$             | 1.986    |
|                |       | $\Delta H$ Set Point : | 2.0      |
|                |       | Time                   | Run Time |
| Start:         | 8:40  | 60                     |          |
| Stop:          | 9:40  |                        |          |

### Run #1

| Cold Box #  |              |            |       |           |         |
|-------------|--------------|------------|-------|-----------|---------|
| 12          | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| Time        |              |            |       |           |         |
| 0           | 669.947      | 77         | 75    | 37        | 4       |
| 5           | 673.645      | 75         | 75    | 38        | 4       |
| 10          | 677.430      | 77         | 77    | 36        | 4       |
| 15          | 681.450      | 77         | 77    | 39        | 4       |
| 20          | 685.020      | 75         | 75    | 39        | 4       |
| 25          | 688.905      | 75         | 76    | 40        | 4       |
| 30          | 692.605      | 76         | 74    | 40        | 4       |
| 35          | 696.250      | 77         | 75    | 43        | 4       |
| 40          | 700.100      | 76         | 74    | 41        | 4       |
| 45          | 703.955      | 77         | 74    | 43        | 4       |
| 50          | 707.740      | 76         | 74    | 42        | 4       |
| 55          | 711.462      | 76         | 74    | 43        | 4       |
| 60          | 715.159      |            |       |           |         |
| Vm          | 45.212       |            |       |           |         |
|             | AVG:         | 76         |       | 40.1      | 4.0     |
| Leak Rate @ | 7.5          | " Hg =     | 0.000 |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 10:40 | 60       |
| Stop:  | 11:40 |          |

## Run #2

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>11</b>          | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 716.015      | 76         | 74    | 39        | 5       |
| <b>5</b>           | 719.788      | 76         | 74    | 41        | 5       |
| <b>10</b>          | 723.551      | 76         | 74    | 43        | 5       |
| <b>15</b>          | 727.279      | 77         | 75    | 42        | 5       |
| <b>20</b>          | 731.004      | 76         | 74    | 42        | 5       |
| <b>25</b>          | 734.717      | 76         | 75    | 44        | 5       |
| <b>30</b>          | 738.405      | 76         | 75    | 45        | 5       |
| <b>35</b>          | 742.091      | 77         | 74    | 46        | 5       |
| <b>40</b>          | 745.754      | 77         | 74    | 46        | 5       |
| <b>45</b>          | 749.512      | 76         | 75    | 47        | 5       |
| <b>50</b>          | 753.100      | 77         | 74    | 47        | 5       |
| <b>55</b>          | 756.862      | 76         | 74    | 48        | 5       |
| <b>60</b>          | 760.395      |            |       |           |         |
| <b>Vm</b>          | 44.380       |            |       |           |         |
|                    | AVG:         | 75         |       | 44.2      | 5.0     |
| <b>Leak Rate @</b> | 10.0         | " Hg =     | 0.000 |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 12:15 | 60       |
| Stop:  | 13:15 |          |

### Run #3

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>9</b>           | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 761.450      | 75         | 74    | 42        | 5       |
| <b>5</b>           | 765.015      | 76         | 74    | 43        | 5       |
| <b>10</b>          | 768.815      | 77         | 74    | 43        | 5       |
| <b>15</b>          | 772.445      | 76         | 74    | 44        | 5       |
| <b>20</b>          | 776.295      | 77         | 74    | 46        | 5       |
| <b>25</b>          | 780.225      | 76         | 75    | 46        | 5       |
| <b>30</b>          | 783.825      | 77         | 74    | 47        | 5       |
| <b>35</b>          | 787.550      | 76         | 74    | 47        | 5       |
| <b>40</b>          | 791.281      | 77         | 74    | 46        | 5       |
| <b>45</b>          | 795.039      | 76         | 75    | 46        | 5       |
| <b>50</b>          | 798.793      | 76         | 74    | 48        | 5       |
| <b>55</b>          | 802.514      | 76         | 74    | 46        | 5       |
| <b>60</b>          | 806.251      |            |       |           |         |
| <b>Vm</b>          | 44.801       |            |       |           |         |
|                    | AVG:         | 75         |       | 45.3      | 5.0     |
| <b>Leak Rate @</b> | 9.5          | " Hg =     | 0.000 |           |         |

# Fyrite

Date: 12-7-20

Technician: Ethan

| Run #1 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | <u>Avg</u>      |       |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|-------|
|        | Time            | 12:15 | Time            | 12:45 | Time            | 13:07 |                 |       |
|        | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.33  |
|        | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.5  | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.17 |

| Run #2 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | <u>Avg</u>      |       |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|-------|
|        | Time            | 13:50 | Time            | 14:17 | Time            | 14:42 |                 |       |
|        | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.17  |
|        | O <sup>2</sup>  | 12.5  | O <sup>2</sup>  | 12.5  | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.33 |

| Run #3 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | <u>Avg</u>      |       |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|-------|
|        | Time            | 15:16 | Time            | 15:38 | Time            | 16:00 |                 |       |
|        | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.17  |
|        | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.5  | O <sup>2</sup>  | 12.17 |

# Fyrite

Date:

12-8-20

Technician:

F. Thompson

| Run #1 | <u>1</u>        |      | <u>2</u>        |      | <u>3</u>        |      | Avg             |       |
|--------|-----------------|------|-----------------|------|-----------------|------|-----------------|-------|
|        | Time            | 8:41 | Time            | 9:16 | Time            | 9:40 |                 |       |
|        | CO <sup>2</sup> | 4.5  | CO <sup>2</sup> | 5.0  | CO <sup>2</sup> | 4.5  | CO <sup>2</sup> | 4.83  |
|        | O <sup>2</sup>  | 12.0 | O <sup>2</sup>  | 11.5 | O <sup>2</sup>  | 11.5 | O <sup>2</sup>  | 11.67 |

| Run #2 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | Avg             |       |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|-------|
|        | Time            | 10:44 | Time            | 11:09 | Time            | 11:35 |                 |       |
|        | CO <sup>2</sup> | 5.0   | CO <sup>2</sup> | 5.0   | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.83  |
|        | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 11.67 |

| Run #3 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | Avg             |      |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|------|
|        | Time            | 12:17 | Time            | 12:46 | Time            | 13:13 |                 |      |
|        | CO <sup>2</sup> | 5.0   | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 5.0   | CO <sup>2</sup> | 4.83 |
|        | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 11.5 |

# **Appendix #2**

## **Laboratory Data**

Lab Data Sheet For: Meggitt Aircraft Braking Systems Corporation - North Afterburner Outlet

By: Ethan M

Moisture Weights

Moisture

| RUN # 1 |         | Box ID | grams    | grams | grams | grams | grams | grams |
|---------|---------|--------|----------|-------|-------|-------|-------|-------|
|         |         |        | 1        | 2     | 3     | 4     | 5     | 6     |
|         |         |        | Drierite |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         | Gross   | 9      | 821.3    | 652.2 | 537.2 |       |       | 981.5 |
|         | Tare    |        | 749.7    | 651.1 | 536.5 |       |       | 974.1 |
|         | Net     |        | 71.6     | 1.1   | 0.7   | 0.0   | 0.0   | 7.4   |
|         | Reagent |        | H2O      | H2O   |       |       |       |       |
|         | mLs     |        | 100.0    | 100.0 |       |       |       |       |

|                  |       |                  |               |                       |
|------------------|-------|------------------|---------------|-----------------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>73.4 | grams<br>Total = 80.8 |
|------------------|-------|------------------|---------------|-----------------------|

| RUN # 2 |         | Box ID | grams    | grams | grams | grams | grams | grams |
|---------|---------|--------|----------|-------|-------|-------|-------|-------|
|         |         |        | 1        | 2     | 3     | 4     | 5     | 6     |
|         |         |        | Drierite |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         | Gross   | 6      | 688.3    | 755.3 | 508.4 |       |       | 956.0 |
|         | Tare    |        | 612.6    | 754.1 | 507.8 |       |       | 948.5 |
|         | Net     |        | 75.7     | 1.2   | 0.6   | 0.0   | 0.0   | 7.5   |
|         | Reagent |        | H2O      | H2O   |       |       |       |       |
|         | mLs     |        | 100.0    | 100.0 |       |       |       |       |

|                  |       |                  |               |                     |
|------------------|-------|------------------|---------------|---------------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>77.5 | grams<br>Total = 85 |
|------------------|-------|------------------|---------------|---------------------|

| RUN # 3 |         | Box ID | grams    | grams | grams | grams | grams | grams |
|---------|---------|--------|----------|-------|-------|-------|-------|-------|
|         |         |        | 1        | 2     | 3     | 4     | 5     | 6     |
|         |         |        | Drierite |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         | Gross   | 11     | 802.2    | 723.5 | 535.8 |       |       | 997.8 |
|         | Tare    |        | 729.0    | 722.6 | 535.0 |       |       | 989.7 |
|         | Net     |        | 73.2     | 0.9   | 0.8   | 0.0   | 0.0   | 8.1   |
|         | Reagent |        | H2O      | H2O   |       |       |       |       |
|         | mLs     |        | 100.0    | 100.0 |       |       |       |       |

|                  |       |                  |               |                     |
|------------------|-------|------------------|---------------|---------------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>74.9 | grams<br>Total = 83 |
|------------------|-------|------------------|---------------|---------------------|

Lab Data Sheet For: Meggitt Aircraft Braking Systems Corporation - South Afterburner Outet

By: Ethan M

Moisture Weights

Moisture

| RUN # 1 |         | Box ID | grams    | grams | grams | grams | grams | grams |
|---------|---------|--------|----------|-------|-------|-------|-------|-------|
|         |         |        | 1        | 2     | 3     | 4     | 5     | 6     |
|         |         |        | Drierite |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         | Gross   | 12     | 697.9    | 546.8 | 625.2 |       |       | 993.1 |
|         | Tare    |        | 622.0    | 546.1 | 624.8 |       |       | 985.4 |
|         | Net     |        | 75.9     | 0.7   | 0.4   | 0.0   | 0.0   | 7.7   |
|         | Reagent |        | H2O      | H2O   |       |       |       |       |
|         | mLs     |        | 100.0    | 100.0 |       |       |       |       |

|                 |       |                  |         |
|-----------------|-------|------------------|---------|
| Intial Imp mL = | 200.0 | grams            | grams   |
|                 |       | Impinger Total = | Total = |
|                 |       | 77               | 84.7    |

| RUN # 2 |         | Box ID | grams    | grams | grams | grams | grams | grams |
|---------|---------|--------|----------|-------|-------|-------|-------|-------|
|         |         |        | 1        | 2     | 3     | 4     | 5     | 6     |
|         |         |        | Drierite |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         | Gross   | 11     | 806.6    | 723.2 | 535.6 |       |       | 970.4 |
|         | Tare    |        | 729.2    | 722.3 | 535.1 |       |       | 962.3 |
|         | Net     |        | 77.4     | 0.9   | 0.5   | 0.0   | 0.0   | 8.1   |
|         | Reagent |        | H2O      | H2O   |       |       |       |       |
|         | mLs     |        | 100.0    | 100.0 |       |       |       |       |

|                 |       |                  |         |
|-----------------|-------|------------------|---------|
| Intial Imp mL = | 200.0 | grams            | grams   |
|                 |       | Impinger Total = | Total = |
|                 |       | 78.8             | 86.9    |

| RUN # 3 |         | Box ID | grams    | grams | grams | grams | grams | grams |
|---------|---------|--------|----------|-------|-------|-------|-------|-------|
|         |         |        | 1        | 2     | 3     | 4     | 5     | 6     |
|         |         |        | Drierite |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         | Gross   | 9      | 824.8    | 652.0 | 536.9 |       |       | 979.0 |
|         | Tare    |        | 750.0    | 651.4 | 536.6 |       |       | 971.5 |
|         | Net     |        | 74.8     | 0.6   | 0.3   | 0.0   | 0.0   | 7.5   |
|         | Reagent |        | H2O      | H2O   |       |       |       |       |
|         | mLs     |        | 100.0    | 100.0 |       |       |       |       |

|                 |       |                  |         |
|-----------------|-------|------------------|---------|
| Intial Imp mL = | 200.0 | grams            | grams   |
|                 |       | Impinger Total = | Total = |
|                 |       | 75.7             | 83.2    |

# **Appendix #3**

## **Calibration Data**



B21856!

Scott-Gross Co., Inc.  
664 Magnolia Ave.  
Lexington, KY 40505  
(859)231-0225 (888)431-5882

## Certificate of Analysis


Certification Date: 12 January 2017  
Certificate Number: 0097B-02T5-C01  
Mixture Grade: EPA Protocol Standard Gas Mixture  
Lot Number: 0097B-02T5  
Expiration Date: 12 January 2025  
Cylinder Number: EB0049442  
Part Number: T5L EPA2RATAP-14

| Mixture Components | Requested Composition | Certified Composition | U (Expanded Uncertainty, k=2) |
|--------------------|-----------------------|-----------------------|-------------------------------|
| Propane            | 43 ppm                | 47.05 PPM             | +/- 0.12 PPM (absolute)       |
| Air                | Balance               | Balance               |                               |

Cylinder Pressure: 1900 psi – Do not use below 100 psi (0.7 megapascals)  
Production Lab: Tier 5 Labs, LLC, Indianapolis, IN, PGVP Vendor ID R12017  
Procedure Used: EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012  
Analytical Method: C3H8: FTIR  
Multipoint Calibration Date: Propane: 12/29/2016

| Reference Standards |         |            |      |           |         |               |                 |                |
|---------------------|---------|------------|------|-----------|---------|---------------|-----------------|----------------|
| Serial Number       | Lot     | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
| CAL017809           | 83-J-12 | 8/17/2017  | SRM  | C3H8      | Air     | 48.83 PPM     | 0.225           | 1667b          |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025-2005.

  
Jeff Lynn



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 3415-11278230

Traceable® Certificate of Calibration for Digital Calipers

Customer: Custom Slack Analysis, LLC, 14614 Cenfield Street NE, Alliance, OH-44601, U.S.A.

Instrument Identification:

Model: 3415,

S/N: 101856179

Manufacturer: Control Company

Standards/Equipment:

| Description | Serial Number | Due Date    | NIST Traceable Reference |
|-------------|---------------|-------------|--------------------------|
| Gage Set    | 99146223      | 17 Dec 2020 | 1000449283               |

Certificate Information:

Technician: 57

Procedure: CAL-05

Cal Date: 12 May 2020

Cal Due Date: 12 May 2021

Test Conditions: 55.18%RH 22.45°C 1018mBar

Calibration Data:

| Unit(s)   | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U      | TUR    |
|-----------|---------|----------|--------|---------|---------|--------|-------|-------|---------|--------|
| in        | N.A.    | N.A.     |        | 0.1000  | 0.1005  | Y      | 0.099 | 0.101 | 0.0003  | 3.33:1 |
| in        | N.A.    | N.A.     |        | 2.0000  | 2.0005  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in        | N.A.    | N.A.     |        | 4.0000  | 4.0005  | Y      | 3.996 | 4.004 | 0.0004  | >4:1   |
| in        | N.A.    | N.A.     |        | 6.0000  | 6.0005  | Y      | 5.994 | 6.006 | 0.0005  | >4:1   |
| In depth  | N.A.    | N.A.     |        | 2.0000  | 2.000   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| In inside | N.A.    | N.A.     |        | 1.0000  | 1.0005  | Y      | 0.999 | 1.001 | 0.00031 | 3.23:1 |
| In step   | N.A.    | N.A.     |        | 2.0000  | 1.9985  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy= $\pm(\text{Max}-\text{Min})/2$ ; Min=As Left Nominal(Rounded) - Tolerance; Max=As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*

Nicol Rodriguez, Quality Manager

*Marisa Elms*

Marisa Elms, Technical Manager

Note:

Maintaining Accuracy:

In our opinion once calibrated your Digital Calipers should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Calipers change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

Issue Date: 12 May 2020

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.traceable.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2015 Quality Certified by DNV GL, Certificate No. CERT-01805-2006-AQ-HOU-ANAB.  
International Laboratory Accreditation Cooperation - Multilateral Recognition Arrangement (ILAC-MRA).

B21925B



Scott-Gross Co., Inc.  
664 Blagden Ave.  
Lexington, KY 40505  
(859)231-0225 (888)431-5882

|                     |                                   |                       |                  |
|---------------------|-----------------------------------|-----------------------|------------------|
| Cylinder Number:    | CC444989                          | Certification Date:   | 28 April 2017    |
| Mixture Grade:      | EPA Protocol Standard Gas Mixture | Expiration Date:      | 29 April 2025    |
| Certificate Number: | 1147B-02T5-C01                    | Lot Number:           | 1147B-02T5       |
| Cylinder Pressure:  | 2015 PSIG                         | Customer Part Number: | T5L EPA2RATAP-19 |

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

### Certified Concentrations

| Component | Concentration | Uncertainty            | Assay Dates |
|-----------|---------------|------------------------|-------------|
| Propane   | 24.7 PPM      | +/- 0.2 PPM (absolute) | 4/28/2017   |
| Air       | Balance       |                        |             |

### Analytical Instrumentation

| Component | Analytical Principle | Make   | Model       | Serial     | MPC Date  |
|-----------|----------------------|--------|-------------|------------|-----------|
| Propane   | FTIR                 | Thermo | Antaris IGS | AWZ1200117 | 4/17/2017 |


### Reference Standards

| Serial Number | Lot        | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|------------|------------|------|-----------|---------|---------------|-----------------|----------------|
| CC459851      | 2186A-01T5 | 11/10/2024 | GMIS | C3H8      | N2      | 247.7 PPM     | 0.411           | 2644a          |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of  $k=2$  to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid.

This calibration meets the requirements of ISO/IEC 17025-2005

  
Analyst: Allison Hanover

  
Reviewer: Jeff Lynn

Production Laboratory:

Tier 5 Labs, LLC

5353 W. Southern Ave.

Indianapolis, IN 46241

PGVP Vendor ID R12017

B21925B



Scott-Gross Co., Inc.  
664 Magnolia Ave.  
Lexington, KY 40505  
(859)231-6225 (888)431-5882

|                     |                                   |                       |                  |
|---------------------|-----------------------------------|-----------------------|------------------|
| Cylinder Number:    | CC444989                          | Certification Date:   | 28 April 2017    |
| Mixture Grade:      | EPA Protocol Standard Gas Mixture | Expiration Date:      | 29 April 2025    |
| Certificate Number: | 1147B-02T5-C01                    | Lot Number:           | 1147B-02T5       |
| Cylinder Pressure:  | 2015 PSIG                         | Customer Part Number: | T5L EPA2RATAP-19 |

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

### Certified Concentrations

| Component | Concentration | Uncertainty            | Assay Dates |
|-----------|---------------|------------------------|-------------|
| Propane   | 24.7 PPM      | +/- 0.2 PPM (absolute) | 4/28/2017   |
| Air       | Balance       |                        |             |

### Analytical Instrumentation


| Component | Analytical Principle | Make   | Model       | Serial     | MPC Date  |
|-----------|----------------------|--------|-------------|------------|-----------|
| Propane   | FTIR                 | Thermo | Antaris IGS | AWZ1200117 | 4/17/2017 |


### Reference Standards

| Serial Number | Lot        | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|------------|------------|------|-----------|---------|---------------|-----------------|----------------|
| CC459851      | 2186A-01T5 | 11/10/2024 | GMIS | C3H8      | N2      | 247.7 PPM     | 0.411           | 2644a          |


The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of  $k=2$  to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid.

This calibration meets the requirements of ISO/IEC 17025-2005

  
Analyst: Allison Hanover

  
Reviewer: Jeff Lynn

Production Laboratory:  
Tier 5 Labs, LLC  
5353 W. Southern Ave.  
Indianapolis, IN 46241  
PGVP Vendor ID R12017



**LIQUID TECHNOLOGY CORPORATION**  
"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis  
**- EPA PROTOCOL GAS -**

Customer IE Monitoring Instruments (Worthington, OH)  
Date October 06, 2014  
Delivery Receipt DR-53322  
Gas Standard 13.8 ppm Propane/Air - EPA PROTOCOL  
Final Analysis Date October 06, 2014  
Expiration Date October 07, 2022

B21477B

Component Propane  
Balance Gas Air

Analytical Data:  
EPA Protocol, Section No. 2.2, Procedure G-1.

**DO NOT USE BELOW 100 psig**

Reported Concentrations  
**Propane: 13.7 ppm +/- 0.1 ppm**  
**Air: Balance**

Reference Standards:

SRM/GMIS: GMIS  
Cylinder Number: CC-165367  
Concentration: 20.21 ppm Propane (+/- 0.09 ppm)  
Expiration Date: 12/02/18  
NIST Sample Number: NA

GMIS Traceability

SRM-1667b  
XF-003853 B  
49.54 ppm Propane (+/- 0.26 ppm)  
07/12/15  
83-I-14

Certification Instrumentation

Component: Propane  
Make/Model: Agilent 7890A  
Serial Number: CN10736166  
Principal of Measurement: GC-FID  
Last Calibration: September 28, 2014

Cylinder Data

Cylinder Serial Number: EB-0051537  
Cylinder Volume: 138 Cubic Feet

Cylinder Outlet: CGA 590  
Cylinder Pressure: 1950 psig, 70°F

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-12/531.

Certified by:

*Cole Dylewski*

Cole Dylewski

PGVP Vendor ID: E12014

**"UNMATCHED EXCELLENCE"**



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 1870-11290275

**Traceable® Certificate of Calibration for Digital Barometer Module**

Customer: Custom Stack Analysis, LLC, 14614 Cenfield Street NE, Alliance, OH-44601, U.S.A.

**Instrument Identification:**

Model: 1870,

S/N: 90724105

Manufacturer: Control Company

**Standards/Equipment:**

| Description               | Serial Number  | Due Date    | NIST Traceable Reference |
|---------------------------|----------------|-------------|--------------------------|
| Digital Thermometer       | 221197993      | 10 Oct 2020 | 4000-10785768            |
| Chilled Mirror Hygrometer | 31874/1H2048MR | 22 Jan 2021 | 18004                    |
| Digital Barometer         | D4540001       | 01 Nov 2020 | 1000447551               |

**Certificate Information:**

Technician: 57

Procedure: CAL-31

Cal Date: 17 May 2020

Cal Due Date: 17 May 2021

Test Conditions: 57.18%RH 22.6°C 1012mBar

**Calibration Data:**

| Unit(s) | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U   | TUR  |
|---------|---------|----------|--------|---------|---------|--------|-------|-------|------|------|
| %RH     | N.A.    | N.A.     |        | 48.33   | 32      | N      | 43    | 53    | 0.74 | >4:1 |
| °C      | N.A.    | N.A.     |        | 24.29   | 24      | Y      | 23.29 | 25.29 | 0.05 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 806.00  | 812     | Y      | 795   | 817   | 0.62 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 909.98  | 914     | Y      | 899   | 921   | 0.62 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 1018.72 | 1022    | Y      | 1008  | 1030  | 0.62 | >4:1 |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement": (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*  
Nicol Rodriguez, Quality Manager

*Marisa Elms*  
Marisa Elms, Technical Manager

Note:

**Maintaining Accuracy:**

In our opinion once calibrated your Digital Barometer Module should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Barometer Module change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

**Recalibration:**

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

Issue Date: 17 May 2020

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.traceable.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2015 Quality Certified by DNV GL, Certificate No. CERT-D1805-2006-AQ-HOU-ANAB.  
International Laboratory Accreditation Cooperation - Multilateral Recognition Arrangement (ILAC-MRA).



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 3415-10347847

**Traceable® Certificate of Calibration for Digital Calipers**

Manufactured for and distributed by: Control Company 12554 Galveston Rd B230, Webster, TX 77598

**Instrument Identification:**

Model: 3415,

S/N: 192125551

Manufacturer: Control Company

**Standards/Equipment:**

| Description    | Serial Number | Due Date    | NIST Traceable Reference |
|----------------|---------------|-------------|--------------------------|
| Gage Block Set | 99146223      | 06 Dec 2019 | 1000434942               |

**Certificate Information:**

Technician: 57

Procedure: CAL-05

Cal Date: 23 Apr 2019

Cal Due Date: 23 Apr 2021

Test Conditions: 57.01%RH 23.96°C 1018mBar

**Calibration Data: (New Instrument)**

| Unit(s)   | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U      | TUR    |
|-----------|---------|----------|--------|---------|---------|--------|-------|-------|---------|--------|
| in        | N.A.    | N.A.     |        | 0.1000  | 0.0995  | Y      | 0.099 | 0.101 | 0.0003  | 3.33:1 |
| in        | N.A.    | N.A.     |        | 2.0000  | 1.9985  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in        | N.A.    | N.A.     |        | 4.0000  | 3.998   | Y      | 3.996 | 4.004 | 0.0004  | >4:1   |
| in        | N.A.    | N.A.     |        | 6.0000  | 5.997   | Y      | 5.994 | 6.006 | 0.0005  | >4:1   |
| in depth  | N.A.    | N.A.     |        | 2.0000  | 1.998   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in inside | N.A.    | N.A.     |        | 1.0000  | 0.9995  | Y      | 0.999 | 1.001 | 0.00031 | 3.23:1 |
| in step   | N.A.    | N.A.     |        | 2.0000  | 2.000   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement": (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*

Nicol Rodriguez, Quality Manager

*Asur Justice*

Asur Justice, Technical Manager

Note:

**Maintaining Accuracy:**

In our opinion once calibrated your Digital Calipers should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Calipers change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

**Recalibration:**

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.control3.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2008 Quality Certified by DNV GL, Certificate No. CERT-01805-2008-AQ-HOU-RvA.  
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).

**MATHESON**

ask...The Gas Professionals™

**Certificate of Batch Analysis**

| <b>Manufacturing Location</b><br>Matheson<br>1055 Garden Street<br>Greensburg, PA 15601<br><br><b>CYLINDER NUMBER(S)</b><br><br>748203Y<br>30-872<br>W-450273<br>TWC-563435<br>279432Y<br>3041791Y<br><br>24698<br>BA-1423<br>NK00455<br><br>7899<br>Q8572<br><br>784192<br>3597456Y<br>SG904256<br><br>935283<br>46-1392<br><br><b>Lot No:</b> 118K41520<br><br><b>Fill Date:</b> 4/28/2015                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | <b>To:</b> Matheson                                  |                         | <b>Sales Order No:</b><br><b>Purchase Order:</b>  |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------|-------------------------|---------------------------------------------------|-------------------------|-------|-------------------|--------|---------|------|---|---|-----|------|------|-----|---|-------|----|-----|-----|---|----------------|----|----|-----|---|-----------------|----|----|-----|---|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | <b>Product:</b> Air                                  |                         | <b>Cylinder Size:</b> 1L<br><b>Valve:</b> CGA 590 |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | <b>Grade:</b> Ultra Zero<br><b>Part No:</b> G2001312 |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         | <b>Pressure:</b> 2400 PSIG                        |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| <table border="1"><thead><tr><th>Component</th><th>Specification</th><th>Certified Concentration</th><th>Units</th><th>Analytical Method</th></tr></thead><tbody><tr><td>Oxygen</td><td>20 - 22</td><td>20.8</td><td>%</td><td>J</td></tr><tr><td>THC</td><td>&lt;0.1</td><td>0.01</td><td>ppm</td><td>E</td></tr><tr><td>Water</td><td>&lt;2</td><td>1.6</td><td>ppm</td><td>F</td></tr><tr><td>Carbon Dioxide</td><td>&lt;1</td><td>ND</td><td>ppm</td><td>H</td></tr><tr><td>Carbon Monoxide</td><td>&lt;1</td><td>ND</td><td>ppm</td><td>H</td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr></tbody></table> |                                                      | Component               | Specification                                     | Certified Concentration | Units | Analytical Method | Oxygen | 20 - 22 | 20.8 | % | J | THC | <0.1 | 0.01 | ppm | E | Water | <2 | 1.6 | ppm | F | Carbon Dioxide | <1 | ND | ppm | H | Carbon Monoxide | <1 | ND | ppm | H |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Component                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | Specification                                        | Certified Concentration | Units                                             | Analytical Method       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Oxygen                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      | 20 - 22                                              | 20.8                    | %                                                 | J                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| THC                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | <0.1                                                 | 0.01                    | ppm                                               | E                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Water                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | <2                                                   | 1.6                     | ppm                                               | F                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Carbon Dioxide                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | <1                                                   | ND                      | ppm                                               | H                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Carbon Monoxide                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | <1                                                   | ND                      | ppm                                               | H                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| <b>COMMENTS</b><br>Product Composition verified by instrumentation calibrated with at least one of the following: NIST traceable weights, gas mixtures traceable to NIST weights, NIST gas standards such as NTRM's or SRM's, manufacturer NIST calibrations                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| <b>Analytical Method Key</b><br>A Trace oxygen analyzer<br>B Gas chromatograph with thermal conductivity detector<br>C Gas chromatograph with flame ionization detector<br>D Trace nitric oxide analyzer<br>E Total hydrocarbon analyzer<br>F Specific moisture analyzer<br>G Gas chromatograph with thermal conductivity detector<br>H Gas chromatograph with discharge ionization detector<br>I Specific carbon monoxide analyzer<br>J Percent oxygen analyzer<br>K Specific carbon dioxide analyzer<br>L Binary gas mixture analyzer                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |

**IMPORTANT**

The information contained herein has been prepared at your request by qualified experts within Matheson. While we believe that the information is accurate within the limits of the analytical methods employed and is complex to the extent of the specified analysis performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Matheson arising out of the use of the information contained herein exceed the fee established for providing such information.

The undersigned certifies that the product(s) listed above reflect gas phase by volume (unless otherwise indicated) and meet or exceed the minimum purity specification(s).

Analyst

12/20/16  
Date



## Page 1 of 1

APEX INSTRUMENTS

EPA Method 5

560 Series Meter Box Calibration

Pre-Test Orifice Method

Metric Meter Box Volume Units, English K Factor

Filename: C:\Customer Project Files\APPENDIX\Cal Sheets\Meter Boxes\Meter Box 1 5-7-20.xlsja  
Revised: 7/25/95 Version: 2.2

Model #: 1  
Serial #: 28 44 (in Hg)  
Theoretical Critical Vacuum: 13.42 (in Hg)

Date: 5/7/2020  
Barometric Pressure: 28.44 (in Hg)  
Theoretical Critical Vacuum: 13.42 (in Hg)

\*\*\*\*\*  
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
IMPORTANT The Critical Orifice Coefficient, K, must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in Hg)<sup>0.5</sup>(min))  
\*\*\*\*\*

CONVERSION FACTORS

1 mm Hg = 0.1330 kPa  
1 inch = 0.39370 cm  
1 inch = 0.03937 mm  
1 cu ft = 28.32 liters

----- DRY GAS METER READINGS -----

| dH<br>in H <sub>2</sub> O | Time<br>(min) | Volume                        |                             | Volume            |  | Initial Temps.   |                   | Final Temps.     |                   | Orifice K<br>Serial# Coefficient<br>(number) (see above) | Actual - Ambient Temperature -- |                  | Average Temperatures --  |                           |                            |        |       |
|---------------------------|---------------|-------------------------------|-----------------------------|-------------------|--|------------------|-------------------|------------------|-------------------|----------------------------------------------------------|---------------------------------|------------------|--------------------------|---------------------------|----------------------------|--------|-------|
|                           |               | Initial<br>(ft <sup>3</sup> ) | Final<br>(ft <sup>3</sup> ) | Total<br>(liters) |  | Inlet<br>(deg F) | Outlet<br>(deg F) | Inlet<br>(deg F) | Outlet<br>(deg F) |                                                          | Vacuum Initial<br>(in Hg)       | Final<br>(deg F) | DGM<br>Outlet<br>(deg R) | DGM<br>Overall<br>(deg R) | Ambient<br>Temp<br>(deg R) |        |       |
| 0.5                       | 10            | 311.555                       | 315.488                     | 111.38256         |  | 62               | 61                | 65               | 62                | 12                                                       | 0.30390681                      | 15               | 64                       | 64                        | 521.5                      | 522.5  | 524   |
| 0.93                      | 10            | 315.488                       | 320.81                      | 150.71904         |  | 67               | 63                | 68               | 63                | 16                                                       | 0.41080925                      | 15               | 64                       | 65                        | 523                        | 524.75 | 524.5 |
| 1.4                       | 10            | 320.81                        | 327.085                     | 177.708           |  | 66               | 64                | 68               | 65                | 19                                                       | 0.48449779                      | 15               | 65                       | 65                        | 524.5                      | 525.75 | 525   |
| 2.1                       | 5             | 327.085                       | 331.027                     | 111.63744         |  | 68               | 65                | 69               | 66                | 23                                                       | 0.60910402                      | 15               | 66                       | 66                        | 525.5                      | 527    | 526   |
| 3.8                       | 5             | 331.027                       | 336.224                     | 147.17904         |  | 68               | 66                | 70               | 67                | 31                                                       | 0.80595932                      | 15               | 66                       | 66                        | 526.5                      | 527.75 | 526   |

----- DRY GAS METER READINGS -----

| ----- CRITICAL ORIFICE READINGS ----- |  |  |  |  |  |  |  |  |  |  |  |  |
|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|
| ----- CRITICAL ORIFICE READINGS ----- |  |  |  |  |  |  |  |  |  |  |  |  |

\*\*\*\*\* RESULTS \*\*\*\*\*

--- DRY GAS METER --- ORIFICE --- ORIFICE ---

| VOLUME CORRECTED |         | VOLUME CORRECTED |           | VOLUME CORRECTED |           | VOLUME CORRECTED |           | VOLUME CORRECTED |           | VOLUME CORRECTED |           | VOLUME CORRECTED |           |
|------------------|---------|------------------|-----------|------------------|-----------|------------------|-----------|------------------|-----------|------------------|-----------|------------------|-----------|
| Vm(std)          | Vm(std) | Vm(std)          | Vm(std)   | Vm(std)          | Vm(std)   | Vm(std)          | Vm(std)   | Vm(std)          | Vm(std)   | Vm(std)          | Vm(std)   | Vm(std)          | Vm(std)   |
| 3.7811759        | 107.08  | 3.77576          | 106.92952 | 3.94373          | 111.36256 | 4.1014902        | 114.4742  | 4.2691998        | 117.708   | 4.436998         | 120.93798 | 4.603756         | 124.17904 |
| 5.1002748        | 144.44  | 5.014902         | 144.4742  | 5.33353          | 150.71904 | 5.6521998        | 157.00000 | 5.9708798        | 163.28112 | 6.2895598        | 169.56216 | 6.6082398        | 175.84320 |
| 6.0094088        | 170.19  | 6.0136998        | 170.30798 | 6.29322          | 177.008   | 6.596998         | 183.01608 | 6.899698         | 189.03216 | 7.202398         | 195.04824 | 7.505098         | 201.06432 |
| 3.7729909        | 106.85  | 3.7765756        | 106.95262 | 3.95984          | 111.63744 | 4.1431998        | 113.27488 | 4.3265598        | 114.91232 | 4.5099198        | 116.54976 | 4.6932798        | 118.18720 |
| 4.988287         | 141.28  | 4.9971208        | 141.51846 | 5.23935          | 147.17904 | 5.4816998        | 152.73968 | 5.7240998        | 158.30032 | 5.9664998        | 163.86096 | 6.2088998        | 169.42160 |
| Average Y -----> |         | 1.00043          |           | 1.00043          |           | 1.00043          |           | 1.00043          |           | 1.00043          |           | 1.00043          |           |

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dh@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

SIGNED: Brian Lemasters

Date: 5/7/2020

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

595572

FOR Custom Scale 593P

14614 CenFeld St Alliance Ohio

☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5525 Galileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 1001 Findlay Rd.  
 LIMA, OH 45801  
 419-226-5021  
☐ 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7180  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jaclyn Court  
 SOUTH BEND, IN 46614  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45089  
 513-777-5800  
☐ 100 McClunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

2019-01-01

TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO.

STATE OF Ohio

WEIGHT  
SIN'S

Calan kut #3

SCALE  
TECHNICIAN: MR.

SIGNATURE

ACCEPTED BY: John Day  
SIGNATURE

PARTS USED

| TAG NO. | MFG          | MOD NO.          | S/N               | LOC.       | CAP.          | GRAD. SIZE  | NORM RING                      | CAL FRO         | CLEAN TEST | CAL STICK | NEXT CAL       |
|---------|--------------|------------------|-------------------|------------|---------------|-------------|--------------------------------|-----------------|------------|-----------|----------------|
|         | <u>Chaus</u> | <u>Navigator</u> | <u>1119252904</u> | <u>Lab</u> | <u>2,100g</u> | <u>0.1g</u> | <u>HI 2000</u><br><u>LO 10</u> | <u>6 months</u> | <u>YES</u> | <u>✓</u>  | <u>11/2020</u> |
|         |              |                  |                   |            | AS LEFT       |             |                                |                 | COMMENTS   |           |                |
| 1       | 200          | 200.0            | 0                 | NO         | 200.0         |             |                                |                 |            |           |                |
| 2       | 500          | 500.0            | 0                 | NO         | 500.0         |             |                                |                 |            |           |                |
| 3       | 1000         | 1000.0           | 0                 | NO         | 1000.0        |             |                                |                 |            |           |                |
| 4       |              |                  |                   |            |               |             |                                |                 |            |           |                |
| 5       |              |                  |                   |            |               |             |                                |                 |            |           |                |
| 6       |              |                  |                   |            |               |             |                                |                 |            |           |                |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584495

FOR CUSTOM STACK 393P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/10/20

- ☐ 14941 Liberty Hi Rd.  
BOWLING GREEN, OH 43402  
419-354-2030  
☐ 4005 South Ave.  
YOUNGSTOWN, OH 44512  
330-259-0414  
☐ 1424 Scale St. S.W.  
CANTON, OH 44706-3086  
330-453-2424  
☐ 490 S. Mapleton St.  
COLUMBUS, IN 47201  
812-372-8374  
☐ 7550 Jacks Lane  
CLAYTON, OH 45315  
937-832-2040  
☐ 3305 Cavalier Dr.  
FORT WAYNE, IN 46808  
260-495-8489  
☐ 520 Brookpark Rd.  
CLEVELAND, OH 44109-5898  
216-661-2680  
☐ 5200 Grand Avenue  
PITTSBURGH, PA 15225  
412-298-7980  
☐ 4070 Perimeter Dr.  
COLUMBUS, OH 43228  
614-274-9008  
☐ 1001 Findlay Rd.  
LIMA, OH 45801  
419-228-5021  
☐ 477 North Pike Rd.  
SARVER, PA 16055  
724-224-7180  
☐ 2351 Jacyln Court  
SOUTH BEND, IN 46614  
☐ 8930 Crescent Park Drive  
WEST CHESTER, OH 43088  
513-777-5800  
☐ 1080 National Parkway  
MANSFIELD, OH 44906  
419-529-3006  
☐ 526 31st St.  
PARKERSBURG, WV 26101  
304-428-1792  
☐ 100 McLunkin Road  
NITRO, WV 25143  
304-755-0886

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

2019. 0/87

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO.

Gram 1113

WEIGHT  
S/N'S

SCALE  
TECHNICIAN: M.P.

SIGNATURE

ACCEPTED BY: J. J. J.

SIGNATURE

PARTS USED

| TAG NO.  | MFG     | MOD NO.    | S/N        | LOC.     | CAP.    | GRAD. SIZE | NORM RING        | CAL FRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|----------|---------|------------|------------|----------|---------|------------|------------------|----------|------------|-----------|----------|
|          | OH-ALIS | ADVENTURER | 1203240794 | LAB      | 4100 g  | .1 g       | HW - g<br>LO - g | 6 Months | YES        | NO        | 11/2020  |
| COMMENTS |         |            |            |          |         |            |                  |          |            |           |          |
| 1        | 10g     | 10.0       | 10.0       | YES / NO | AS LEFT | 10.0       |                  |          |            |           |          |
| 2        | 20g     | 20.0       | 20.0       | YES / NO | 20.0    |            |                  |          |            |           |          |
| 3        | 50g     | 50.0       | 50.0       | YES / NO | 50.0    |            |                  |          |            |           |          |
| 4        | 100g    | 100.0      | 100.0      | YES / NO | 100.0   |            |                  |          |            |           |          |
| 5        | 1kg     | 999.7      | 999.7      | YES / NO | 1000.0  |            |                  |          |            |           |          |
| 6        | 2kg     | 1999.4     | 1999.4     | YES / NO | 2000.0  |            |                  |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584497

FOR CUSTOM STACK 593P - COD(1111)

14614 CENFIELD ST ALLIANCE, OH 44601

☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Caveller Dr.  
 FORT WAYNE, IN 46808  
 260-486-8469  
☐ 5205 Galileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7980  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-525-3006  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46614  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5800  
☐ 100 McLunkin Road  
 NITRO, WV 25143  
 304-755-0886

P.O. \_\_\_\_\_ DATE 5/12/20

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT S/N'S Colan kit #3

SCALE TECHNICIAN: M.P.

ACCEPTED BY: [Signature] SIGNATURE

PARTS USED

| TAG NO.  | MFG    | MOD NO.   | S/N        | LOC.     | CAP.    | GRAD. SIZE | NORM RNG               | CAL FRQ  | CLEAR TEST | CAL STICK | NEXT CAL |
|----------|--------|-----------|------------|----------|---------|------------|------------------------|----------|------------|-----------|----------|
| WGT USED | OHAUS  | SCOUT PRO | 7124111434 | LAB      | 2000 -  | .1 --      | H 2000 --<br>LO 500 -- | 6 Months | YES        | YES       | 11/2020  |
| 1 500    | 500.0  | 0         | +/- 2%     | YES / NO | AS LEFT | 500.0      |                        |          |            |           |          |
| 2 1000   | 1000.0 | 0         | +/- 2%     | YES / NO | 1000.0  |            |                        |          |            |           |          |
| 3 1500   | 1500.0 | 0         | +/- 2%     | YES / NO | 1500.0  |            |                        |          |            |           |          |
| 4 2000   | 2000.0 | 0         | +/- 2%     | YES / NO | 2000.0  |            |                        |          |            |           |          |
| 5        |        |           |            | YES / NO |         |            |                        |          |            |           |          |
| 6        |        |           |            | YES / NO |         |            |                        |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechtbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/INCISL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584496

CUSTOM STACK 593P - COD(III)

FOR

14614 CENFIELD ST ALLIANCE, OH 44601

COD(III)

PO

DATE 5/12/20

J 14941 Liberty H. Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
 J 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
 J 41424 Scale St. S.W.  
 CANTON, OH 44708-3096  
 330-453-2424  
 J 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
 J 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
 J 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-486-8468  
 J 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
 J 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-239-7960  
 J 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7160  
 J 1001 Findlay Rd.  
 LIMA, OH 45801  
 419-226-5021  
 J 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
 J 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
 J 2351 Jaclyn Court  
 SOUTH BEND, IN 46614  
 J 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5800  
 J 100 McJunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

2019-0182

TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO.

STATE OF OHIO

WEIGHT  
SN'S

Calibration #3

SCALE  
TECHNICIAN: M.P.

ACCEPTED BY: *[Signature]*  
SIGNATURE

PARTS USED

| TAG NO. | MFG       | MOD NO.  | S/N      | LOC.     | CAP.     | GRAD. SIZE | NORM RNG         | CAL FRQ  | CLEAN TEST | CAL STICK | NEXT CAL  |
|---------|-----------|----------|----------|----------|----------|------------|------------------|----------|------------|-----------|-----------|
|         | SARTORIUS | A2005    | 38080133 | LAB      | 100 GM g | 0.1 g      | HI - g<br>LO - g | 6 Months | YES        | NO        | 11/2/2020 |
| 1       | 10g       | 10000.9  | +0.9     | YES / NO | AS LEFT  | 10000.0    | CALIBRATED       |          |            |           |           |
| 2       | 20g       | 20001.3  | +1.3     | YES / NO | 20000.0  |            |                  |          |            |           |           |
| 3       | 50g       | 50004.5  | +4.5     | YES / NO | 50000.0  |            |                  |          |            |           |           |
| 4       | 100g      | 100010.8 | +10.8    | YES / NO | 100000.0 |            |                  |          |            |           |           |
| 5       | g         |          |          | YES / NO |          |            |                  |          |            |           |           |
| 6       | g         |          |          | YES / NO |          |            |                  |          |            |           |           |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER Scales, Inc.

## SCALE INSPECTION REPORT

584489

FOR CUSTOM STACK 593P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/12/20

- ☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 1001 Findlay Rd.  
 LIMA, OH 45801  
 419-228-5021  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46614  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5800  
☐ 100 McJunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0186

WEIGHT

S/N'S 2019-0186

SCALE

TECHNICIAN: M.R.

SIGNATURE

ACCEPTED BY: [Signature]

SIGNATURE

PARTS USED

| TAG NO. | MFG  | MOD NO   | SN       | LOC.     | CAP.     | GRAD. SIZE | NORM RNG            | CAL FRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|---------|------|----------|----------|----------|----------|------------|---------------------|----------|------------|-----------|----------|
|         | A&D  | HR-200   | 12323498 | LAB      | 210 g    | 0.0001 g   | HI 200 g<br>LO 10 g | 6 Months | YES        | NO        | 11/2020  |
| 1       | 10g  | 9.9995   | -0.0005  | ADJUSTED | AS LEFT  | 10.0000    | C.A.C. BALANCED     |          |            |           |          |
| 2       | 20g  | 19.9996  | -0.0004  | YES / NO | 20.0000  | 50.0000    |                     |          |            |           |          |
| 3       | 50g  | 49.9997  | -0.0003  | YES / NO | 50.0000  | 100.0000   |                     |          |            |           |          |
| 4       | 100g | 99.9980  | -0.0020  | YES / NO | 100.0000 | 200.0000   |                     |          |            |           |          |
| 5       | 200g | 199.9970 | -0.0030  | YES / NO | 200.0000 |            |                     |          |            |           |          |
| 6       | g    |          |          | YES / NO |          |            |                     |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.



# SCALE INSPECTION REPORT

584490

FOR CUSTOM STACK 593P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/12/20

- |                                                                                          |                                                                                       |                                                                                    |                                                                                        |                                                                                    |                                                                                 |                                                                                       |
|------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------|------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------|------------------------------------------------------------------------------------|---------------------------------------------------------------------------------|---------------------------------------------------------------------------------------|
| <input type="checkbox"/> 14941 Liberty Hi Rd.<br>BOWLING GREEN, OH 43402<br>419-354-2030 | <input type="checkbox"/> 1424 Scale St. S.W.<br>CANTON, OH 44706-3096<br>330-453-2424 | <input type="checkbox"/> 7550 Jacks Lane<br>CLAYTON, OH 45315<br>937-832-2040      | <input type="checkbox"/> 520 Brookpark Rd.<br>CLEVELAND, OH 44109-5898<br>216-661-2680 | <input type="checkbox"/> 4070 Perimeter Dr.<br>COLUMBUS, OH 43228<br>614-274-9009  | <input type="checkbox"/> 1001 Findlay Rd.<br>LIMA, OH 45801<br>419-228-5021     | <input type="checkbox"/> 2351 Jaclyn Court<br>SOUTH BEND, IN 46614                    |
| <input type="checkbox"/> 4005 South Ave.<br>YOUNGSTOWN, OH 44512<br>330-259-0414         | <input type="checkbox"/> 490 S. Mapleton St.<br>COLUMBUS, IN 47201<br>812-372-8374    | <input type="checkbox"/> 3306 Cavalier Dr.<br>FORT WAYNE, IN 46808<br>260-496-8469 | <input type="checkbox"/> 5525 Galasso Court<br>INDIANAPOLIS, IN 46241<br>317-548-7821  | <input type="checkbox"/> 5200 Grand Avenue<br>PITTSBURGH, PA 15225<br>412-299-7980 | <input type="checkbox"/> 477 North Pike Rd.<br>SARVER, PA 16055<br>724-224-7180 | <input type="checkbox"/> 1080 National Parkway<br>MANSFIELD, OH 44906<br>419-529-3006 |
|                                                                                          |                                                                                       |                                                                                    |                                                                                        |                                                                                    |                                                                                 | <input type="checkbox"/> 100 McJunkin Road<br>NITRO, WV 25143<br>304-765-0886         |

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT GRAM 1013

SCALE TECHNICIAN: MT.  
ACCEPTED BY: [Signature] SIGNATURE

PARTS USED

| TAG NO.  | MFG      | MOD NO. | S/N  | LOC.      | CAP.    | GRAD. SIZE | NORM FNG            | CAL FRQ  | CLEAN TEST | CAL STICK | NEXT CAL |  |
|----------|----------|---------|------|-----------|---------|------------|---------------------|----------|------------|-----------|----------|--|
| -        | US SOLID | NONE    | NONE | TRAVELLER | 500 g   | 0.001 g    | HI 200 g<br>LO 10 g | 6 Months | YES        | YES       | 11/2020  |  |
|          |          |         |      |           |         |            |                     |          |            |           |          |  |
| WGT USED |          |         |      |           | AS LEFT |            | COMMENTS            |          |            |           |          |  |
| 1        | 10g      | 10.000  |      | YES / NO  | 10.000  |            |                     |          |            |           |          |  |
| 2        | 20g      | 20.000  |      | YES / NO  | 20.000  |            |                     |          |            |           |          |  |
| 3        | 50g      | 50.000  |      | YES / NO  | 50.000  |            |                     |          |            |           |          |  |
| 4        | 100g     | 100.000 |      | YES / NO  | 100.000 |            |                     |          |            |           |          |  |
| 5        | 200g     | 200.000 |      | YES / NO  | 200.000 |            |                     |          |            |           |          |  |
| 6        | g        |         |      | YES / NO  |         |            |                     |          |            |           |          |  |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechtbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

# BRECHBUHLER Scales, Inc.

## SCALE INSPECTION REPORT

584488

FOR CUSTOM STACK 533P - COD!!!!  
14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!! DATE 5/12/20  
☐ 14941 Liberty Hi Rd. ☐ 1424 Scale St. S.W. ☐ 7550 Jacks Lane  
 BOWLING GREEN, OH 43402 CANTON, OH 44706-3096 CLAYTON, OH 45315  
 419-354-2030 330-453-2424 937-832-2040  
☐ 4005 South Ave. ☐ 490 S. Mapleton St. ☐ 3305 Cavalier Dr.  
 YOUNGSTOWN, OH 44512 COLUMBUS, IN 47201 FORT WAYNE, IN 46808  
 330-259-0414 812-372-8374 260-496-8469  
☐ 520 Brookpark Rd. ☐ 4070 Peirce Rd. ☐ 1080 National Parkway  
 CLEVELAND, OH 44109-5898 COLUMBUS, OH 43228 LIMA, OH 45801  
 216-661-2680 614-274-9009 419-528-5021  
☐ 5525 Galena Court ☐ 5300 Grand Avenue ☐ 477 North Pike Rd. ☐ 526 31st St.  
 INDIANAPOLIS, IN 46241 PITTSBURGH, PA 15225 SARVER, PA 16055 PARKERSBURG, WV 26101  
 317-548-7821 412-299-7960 724-224-7180 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187  
 WEIGHT GRAM #3  
 S/N'S

SCALE TECHNICIAN: MT

ACCEPTED BY: [Signature]  
 SIGNATURE

PARTS USED

| TAG NO.  | MFG      | MOD NO. | S/N      | LOC.     | CAP.    | GRAD. SIZE | NORM RING | CAL FRQ | CLEAN TEST | CAL STICK | NEXT CAL |
|----------|----------|---------|----------|----------|---------|------------|-----------|---------|------------|-----------|----------|
| WGT USED | AS FOUND | DEV.    | TOL. +/- | ADJUSTED | AS LEFT | COMMENTS   |           |         |            |           |          |
| 1 200g   | 200.00   | 0       |          | YES / NO | 200.00  |            |           |         |            |           |          |
| 2 500g   | 500.00   | 0       |          | YES / NO | 500.00  |            |           |         |            |           |          |
| 3 1000g  | 1000.00  | 0       |          | YES / NO | 1000.00 |            |           |         |            |           |          |
| 4 g      |          |         |          | YES / NO |         |            |           |         |            |           |          |
| 5 g      |          |         |          | YES / NO |         |            |           |         |            |           |          |
| 6 g      |          |         |          | YES / NO |         |            |           |         |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechtbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.



7410 Worthington-Galena Road  
Worthington, Ohio 43085  
Phone: (614) 436-4933  
Fax: (614) 436-9144

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.iereents.com](http://www.iereents.com)

### Temperature Calibration Certificate

Instrument: H-B Thermometer  
Serial #: 4A6108

Date: 4/6/2020  
Technician: Sam Shults

| <u>Lab Standard</u> | <u>Thermometer Mark</u> |
|---------------------|-------------------------|
| 169.9               | 170.0                   |
| 190.0               | 190.0                   |
| 204.8               | 205.0                   |
| 214.6               | 215.0                   |

Accuracy = 1 F

#### Reference Standards

PIE 525B sn. 116765 Cal Due: 9/6/2020  
Hart 9103 Temp Dry Well

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**



7410 Worthington-Galena Road  
Worthington, Ohio 43085  
Phone: (614) 436-4933  
Fax: (614) 436-9144

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.iemts.com](http://www.iemts.com)

### Temperature Calibration Certificate

Instrument: H-B Thermometer  
Serial #: 4B5200

Date: 4/6/2020  
Technician: Sam Shults

| <u>Lab Standard</u> | <u>Thermometer Mark</u> |
|---------------------|-------------------------|
| 30.1                | 30.0                    |
| 50.1                | 50.0                    |
| 70.0                | 70.0                    |
| 88.0                | 88.0                    |

Accuracy = 1 F

#### Reference Standards

PIE 525B sn. 116765 Cal Due: 9/6/2020  
Hart 9103 Temp Dry Well

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**

# THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/23/19 BY ANDREW CANNON Pb 28.76

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| ICE WATER           |           | BOILING WATER |           |     |
|---------------------|-----------|---------------|-----------|-----|
| TC                  | PRECISION | TC            | PRECISION | TC  |
| OVEN THERMOCOUPLES  |           |               |           |     |
| O-1                 | 32        | 32            | 212       | 212 |
| O-2                 | 32        | 32            | 212       | 212 |
| O-3                 | 32        | 31            | 212       | 211 |
| O-4                 | 32        | 31            | 212       | 211 |
| O-5                 | 32        | 32            | 212       | 212 |
| O-6                 | 32        | 31            | 212       | 211 |
| O-7                 | 32        | 31            | 212       | 211 |
| O-8                 | 32        | 32            | 212       | 212 |
| O-9                 | 32        | 32            | 212       | 212 |
| O-10                | 32        | 32            | 212       | 212 |
| O-11                | 32        | 31            | 212       | 211 |
| O-12                | 32        | 31            | 212       | 211 |
| STACK THERMOCOUPLES |           |               |           |     |
| 2S-1                | 32        | 31            | 212       | 211 |
| 2S-2                | 32        | 31            | 212       | 211 |
| 2S-3                | 32        | 32            | 212       | 212 |
| 3S-1                | 32        | 32            | 212       | 212 |
| 3S-2                | 32        | 31            | 212       | 211 |
| 3S-3                | 32        | 31            | 212       | 211 |
| 3S-4                | 32        | 31            | 212       | 211 |
| 3S-5                | 32        | 31            | 212       | 211 |
| 4S-1                | 32        | 32            | 212       | 212 |
| 4S-2                | 32        | 31            | 212       | 211 |
| 4S-3                | 32        | 31            | 212       | 211 |
| 4S-4                | 32        | 33            | 212       | 213 |
| 4S-5                | 32        | 31            | 212       | 211 |
| 4S-6                | 32        | 32            | 212       | 212 |
| 5S-1                | 32        | 32            | 212       | 212 |
| 5S-2                | 32        | 32            | 212       | 212 |
| 5S-3                | 32        | 33            | 212       | 213 |
| 6S-1                | 32        | 31            | 212       | 211 |
| 6S-2                | 32        | 31            | 212       | 211 |
| 6S-3                | 32        | 31            | 212       | 211 |
| 6S-4                | 32        | 32            | 212       | 212 |
| 8S-1                | 32        | 32            | 212       | 212 |
| 8S-2                | 32        | 32            | 212       | 212 |
| 10S-1               | 32        | 32            | 212       | 212 |
| 10S-2               | 32        | 31            | 212       | 211 |
| 12S-1               | 32        | 31            | 212       | 211 |

# THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/23/19 BY ANDREW CANNAN Pb 28.76

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| ICE WATER               |           | BOILING WATER |           |     |
|-------------------------|-----------|---------------|-----------|-----|
| TC                      | PRECISION | TC            | PRECISION | TC  |
| CONDENSOR THERMOCOUPLES |           |               |           |     |
| C-1                     | 32        | 31            | 212       | 211 |
| C-2                     | 32        | 31            | 212       | 211 |
| C-3                     | 32        | 31            | 212       | 211 |
| C-4                     | 32        | 31            | 212       | 211 |
| C-5                     | 32        | 31            | 212       | 211 |
| C-6                     | 32        | 32            | 212       | 212 |
| C-7                     | 32        | 31            | 212       | 211 |
| C-8                     | 32        | 31            | 212       | 211 |
| C-9                     | 32        | 31            | 212       | 211 |
| PROBE THERMOCOUPLES     |           |               |           |     |
| 2P-1                    | 32        | 31            | 212       | 211 |
| 2P-2                    | 32        | 31            | 212       | 211 |
| 2P-3                    | 32        | 31            | 212       | 211 |
| 3P-1                    | 32        | 32            | 212       | 212 |
| 3P-2                    | 32        | 31            | 212       | 211 |
| 3P-3                    | 32        | 31            | 212       | 211 |
| 3P-4                    | 32        | 32            | 212       | 212 |
| 3P-5                    | 32        | 33            | 212       | 213 |
| 4P-1                    | 32        | 32            | 212       | 212 |
| 4P-2                    | 32        | 32            | 212       | 212 |
| 4P-3                    | 32        | 32            | 212       | 212 |
| 4P-4                    | 32        | 32            | 212       | 212 |
| 4P-5                    | 32        | 32            | 212       | 212 |
| 4P-6                    | 32        | 32            | 212       | 212 |
| 5P-1                    | 32        | 32            | 212       | 212 |
| 5P-2                    | 32        | 31            | 212       | 211 |
| 5P-3                    | 32        | 31            | 212       | 211 |
| 6P-1                    | 32        | 31            | 212       | 211 |
| 6P-2                    | 32        | 31            | 212       | 211 |
| 6P-3                    | 32        | 31            | 212       | 211 |
| 6P-4                    | 32        | 31            | 212       | 211 |
| 8P-1                    | 32        | 32            | 212       | 212 |
| 8P-2                    | 32        | 32            | 212       | 212 |
| 10P-1                   | 32        | 33            | 212       | 213 |
| 10P-2                   | 32        | 32            | 212       | 212 |
| 12P-1                   | 32        | 32            | 212       | 212 |

Client: heggitt

## Pitot Tube Inspection


Date: 12-6-20

|                         |      |                            |      |
|-------------------------|------|----------------------------|------|
| Probe/Pitot Number      | 3p-2 | A (Pa + Pb)                | .957 |
| Level and Perpendicular | yes  | Zs = A tan Y (< 0.125")    | 0    |
| Obstruction?            | no   | Ws = A tan 0 (< 0.03125")  | 0    |
| Damaged?                | no   | Dt (0.1875" < Dt < 0.375") | .375 |
| a1 (-10° < a1 < +10°)   | 0    | Pa (1.05 Dt < Pa < 1.5 Dt) | .471 |
| a2 (-10° < a2 < +10°)   | 0    | Pb (1.05 Dt < Pb < 1.5 Dt) | .486 |
| b1 (-5° < b1 < +5°)     | 0    | Pa = Pb ± 0.063"           | .015 |
| b2 (-5° < b2 < +5°)     | 0    |                            |      |

## Probe Minimum Interferences

|              |  |                |  |
|--------------|--|----------------|--|
| Y (>= 3.0")  |  | Dn             |  |
| X (> .75")   |  | X/Dn (>= 1.5") |  |
| Zp (>= .75") |  |                |  |

- Pa Distance between where pitots adjoin to tip of pitot (Must be between 1.05 & 1.50 times O.D. of tubing)  
 Pb Distance between where pitots adjoin to tip of pitot (Must be between 1.05 & 1.50 times O.D. of tubing)  
 Dt Diameter of pitot tube (0.375 inches on all pitots)  
 Zs Distance between the tip of the impact and static line along the length of the pitot (Must be < 1/8 inch (0.1250))  
 Ws Spacing between Pitot tubes where welded together (Must be < 1/32 inch (0.0313))  
 a1 Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 10 Deg)  
 a2 Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 10 Deg)  
 b1 Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 5 Deg)  
 b2 Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 5 Deg)  
 X Distance between side of nozzle and side of pitot tube (Must be > 3/4 inch)  
 Zp Distance from center of pitot opening back to tip of thermal couple (Must be >= 3/4 inch (0.75))  
 Y Distance from center of pitot opening back to probe (Must be >= 3 inches)



# THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/23/19 BY ANDREW CANNON Pb 28.76

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| ICE WATER           |           | BOILING WATER |           |     |
|---------------------|-----------|---------------|-----------|-----|
| TC                  | PRECISION | TC            | PRECISION | TC  |
| METER THERMOCOUPLES |           |               |           |     |
| 1M-1                | 32        | 31            | 212       | 211 |
| 1M-2                | 32        | 31            | 212       | 211 |
| 2M-1                | 32        | 32            | 212       | 212 |
| 2M-2                | 32        | 32            | 212       | 212 |
| 3M-1                | 32        | 32            | 212       | 212 |
| 3M-2                | 32        | 32            | 212       | 212 |
| 4M-1                | 32        | 33            | 212       | 213 |
| 4M-2                | 32        | 33            | 212       | 213 |
| 5M-1                | 32        | 32            | 212       | 212 |
| 5M-2                | 32        | 32            | 212       | 212 |
| 6M-1                | 32        | 32            | 212       | 212 |
| 6M-2                | 32        | 31            | 212       | 211 |
| 7M-1                | 32        | 31            | 212       | 211 |
| 7M-2                | 32        | 31            | 212       | 211 |
| 8M-1                | 32        | 31            | 212       | 211 |
| 8M-2                | 32        | 31            | 212       | 211 |
| 9M-1                | 32        | 31            | 212       | 211 |
| 9M-2                | 32        | 31            | 212       | 211 |
| 10M-1               | 32        | 32            | 212       | 212 |
| 10M-2               | 32        | 32            | 212       | 212 |
| 15M-1               | 32        | 32            | 212       | 212 |
| 15M-2               | 32        | 32            | 212       | 212 |
| 17M-1               | 32        | 32            | 212       | 212 |
| 17M-2               | 32        | 33            | 212       | 213 |
| 18M-1               | 32        | 32            | 212       | 212 |
| 18M-2               | 32        | 22            | 212       | 212 |

THERMOCOUPLE TEMPERATURES ARE READ ON THE DTI DURING TEST.  
DTI CALIBRATED BY ALTEK 22 TC SOURCE S# 148946 OR S# 243783 PRIOR TO TC CAL.

# **Appendix #4**

## **Monitoring Data**

Meggitt Aircraft Braking Systems Crporation  
North Afterburner Outlet

|      |       |
|------|-------|
| VOC  | Conc. |
| High | 47.05 |
| Mid  | 24.7  |
| Low  | 13.7  |

| VOC   | Time Stamp            |             |
|-------|-----------------------|-------------|
| 47.21 | 12/7/2020 11:46:59 AM | High        |
| 47.27 | 12/7/2020 11:48:00 AM |             |
| 46.81 | 12/7/2020 11:49:00 AM |             |
| 47.04 | 12/7/2020 11:50:01 AM |             |
| 46.75 | 12/7/2020 11:51:02 AM |             |
| 1.44  | 12/7/2020 11:52:02 AM |             |
| 0.15  | 12/7/2020 11:53:03 AM | Zero        |
| 0.15  | 12/7/2020 11:54:03 AM |             |
| 0.15  | 12/7/2020 11:55:04 AM |             |
| 0.15  | 12/7/2020 11:56:05 AM |             |
| 0.15  | 12/7/2020 11:57:05 AM |             |
| 8.87  | 12/7/2020 11:58:06 AM |             |
| 13.38 | 12/7/2020 11:59:06 AM |             |
| 13.43 | 12/7/2020 12:00:07 PM | Low         |
| 13.55 | 12/7/2020 12:01:08 PM |             |
| 13.44 | 12/7/2020 12:02:08 PM |             |
| 13.62 | 12/7/2020 12:03:09 PM |             |
| 13.49 | 12/7/2020 12:04:09 PM |             |
| 19.58 | 12/7/2020 12:05:10 PM |             |
| 24.60 | 12/7/2020 12:06:11 PM |             |
| 24.76 | 12/7/2020 12:07:11 PM | Bias        |
| 24.77 | 12/7/2020 12:08:12 PM |             |
| 24.20 | 12/7/2020 12:09:12 PM |             |
| 23.85 | 12/7/2020 12:10:13 PM |             |
| 23.63 | 12/7/2020 12:11:14 PM |             |
| 1.57  | 12/7/2020 12:12:14 PM |             |
| 0.16  | 12/7/2020 12:13:15 PM |             |
| 0.15  | 12/7/2020 12:14:15 PM | Start Run 1 |
| 0.15  | 12/7/2020 12:15:16 PM |             |
| 0.18  | 12/7/2020 12:16:11 PM |             |
| 0.15  | 12/7/2020 12:17:12 PM |             |
| 0.15  | 12/7/2020 12:18:12 PM |             |
| 0.15  | 12/7/2020 12:19:13 PM |             |
| 0.23  | 12/7/2020 12:20:13 PM |             |
| 0.19  | 12/7/2020 12:21:14 PM |             |
| 0.15  | 12/7/2020 12:22:14 PM |             |
| 0.15  | 12/7/2020 12:23:15 PM |             |
| 0.15  | 12/7/2020 12:24:16 PM |             |
| 0.40  | 12/7/2020 12:25:16 PM |             |
| 0.25  | 12/7/2020 12:26:17 PM |             |
| 0.17  | 12/7/2020 12:27:18 PM |             |
| 0.15  | 12/7/2020 12:28:18 PM |             |
| 0.15  | 12/7/2020 12:29:19 PM |             |
| 0.15  | 12/7/2020 12:30:19 PM |             |
| 0.15  | 12/7/2020 12:31:20 PM |             |
| 0.15  | 12/7/2020 12:32:20 PM |             |
| 0.15  | 12/7/2020 12:33:21 PM |             |
| 0.21  | 12/7/2020 12:34:22 PM |             |
| 0.15  | 12/7/2020 12:35:22 PM |             |
| 0.15  | 12/7/2020 12:36:23 PM |             |
| 0.15  | 12/7/2020 12:37:24 PM |             |
| 0.15  | 12/7/2020 12:38:24 PM |             |

|       |                                 |
|-------|---------------------------------|
| 0.24  | 12/7/2020 12:39:25 PM           |
| 0.38  | 12/7/2020 12:40:25 PM           |
| 0.16  | 12/7/2020 12:41:26 PM           |
| 0.26  | 12/7/2020 12:42:26 PM           |
| 0.15  | 12/7/2020 12:43:27 PM           |
| 0.15  | 12/7/2020 12:44:28 PM           |
| 0.18  | 12/7/2020 12:45:28 PM           |
| 0.16  | 12/7/2020 12:46:29 PM           |
| 0.15  | 12/7/2020 12:47:29 PM           |
| 0.15  | 12/7/2020 12:48:30 PM           |
| 0.15  | 12/7/2020 12:49:31 PM           |
| 0.15  | 12/7/2020 12:50:31 PM           |
| 0.24  | 12/7/2020 12:51:32 PM           |
| 0.17  | 12/7/2020 12:52:32 PM           |
| 0.35  | 12/7/2020 12:53:33 PM           |
| 0.57  | 12/7/2020 12:54:34 PM           |
| 0.15  | 12/7/2020 12:55:34 PM           |
| 0.15  | 12/7/2020 12:56:35 PM           |
| 0.15  | 12/7/2020 12:57:36 PM           |
| 0.15  | 12/7/2020 12:58:36 PM           |
| 0.15  | 12/7/2020 12:59:37 PM           |
| 0.15  | 12/7/2020 1:00:37 PM            |
| 0.15  | 12/7/2020 1:01:38 PM            |
| 0.15  | 12/7/2020 1:02:38 PM            |
| 0.15  | 12/7/2020 1:03:39 PM            |
| 0.22  | 12/7/2020 1:04:40 PM            |
| 0.15  | 12/7/2020 1:05:40 PM            |
| 0.15  | 12/7/2020 1:06:41 PM            |
| 0.16  | 12/7/2020 1:07:42 PM            |
| 0.15  | 12/7/2020 1:08:42 PM            |
| 0.15  | 12/7/2020 1:09:43 PM            |
| 0.15  | 12/7/2020 1:10:43 PM            |
| 0.15  | 12/7/2020 1:11:44 PM            |
| 0.20  | 12/7/2020 1:12:45 PM            |
| 0.15  | 12/7/2020 1:13:45 PM            |
| 0.15  | 12/7/2020 1:14:46 PM Stop Run 1 |
| 0.18  | Avg                             |
| 0.15  | 12/7/2020 1:15:46 PM            |
| 0.15  | 12/7/2020 1:16:47 PM            |
| 0.15  | 12/7/2020 1:17:48 PM            |
| 0.15  | 12/7/2020 1:18:48 PM            |
| 3.82  | 12/7/2020 1:19:49 PM            |
| 25.08 | 12/7/2020 1:20:49 PM            |
| 25.07 | 12/7/2020 1:21:50 PM Bias       |
| 24.90 | 12/7/2020 1:22:51 PM            |
| 25.10 | 12/7/2020 1:23:51 PM            |
| 25.06 | 12/7/2020 1:24:52 PM            |
| 25.05 | 12/7/2020 1:25:52 PM            |
| 25.12 | 12/7/2020 1:26:53 PM            |
| 22.29 | 12/7/2020 1:27:54 PM            |
| 0.16  | 12/7/2020 1:28:54 PM            |
| 0.15  | 12/7/2020 1:29:55 PM Zero       |
| 0.15  | 12/7/2020 1:30:55 PM            |
| 0.15  | 12/7/2020 1:31:56 PM            |
| 0.15  | 12/7/2020 1:32:57 PM            |
| 0.15  | 12/7/2020 1:33:57 PM            |
| 0.19  | 12/7/2020 1:34:58 PM            |
| 0.15  | 12/7/2020 1:35:58 PM            |
| 0.15  | 12/7/2020 1:36:59 PM            |
| 0.17  | 12/7/2020 1:38:00 PM            |
| 0.15  | 12/7/2020 1:39:00 PM            |
| 0.28  | 12/7/2020 1:40:01 PM            |

|      |                                  |
|------|----------------------------------|
| 0.28 | 12/7/2020 1:40:01 PM             |
| 0.20 | 12/7/2020 1:41:02 PM             |
| 0.15 | 12/7/2020 1:42:02 PM             |
| 0.15 | 12/7/2020 1:43:03 PM             |
| 0.15 | 12/7/2020 1:44:03 PM             |
| 0.18 | 12/7/2020 1:45:04 PM Start Run 2 |
| 0.23 | 12/7/2020 1:46:04 PM             |
| 0.16 | 12/7/2020 1:47:05 PM             |
| 0.15 | 12/7/2020 1:48:06 PM             |
| 0.15 | 12/7/2020 1:49:06 PM             |
| 0.15 | 12/7/2020 1:50:07 PM             |
| 0.15 | 12/7/2020 1:51:08 PM             |
| 0.15 | 12/7/2020 1:52:08 PM             |
| 0.25 | 12/7/2020 1:53:09 PM             |
| 0.18 | 12/7/2020 1:54:09 PM             |
| 0.15 | 12/7/2020 1:55:10 PM             |
| 0.15 | 12/7/2020 1:56:11 PM             |
| 0.15 | 12/7/2020 1:57:11 PM             |
| 0.15 | 12/7/2020 1:58:12 PM             |
| 0.15 | 12/7/2020 1:59:12 PM             |
| 0.15 | 12/7/2020 2:00:13 PM             |
| 0.15 | 12/7/2020 2:01:14 PM             |
| 0.15 | 12/7/2020 2:02:14 PM             |
| 0.15 | 12/7/2020 2:03:15 PM             |
| 0.15 | 12/7/2020 2:04:15 PM             |
| 0.15 | 12/7/2020 2:05:16 PM             |
| 0.17 | 12/7/2020 2:06:17 PM             |
| 0.31 | 12/7/2020 2:07:17 PM             |
| 0.18 | 12/7/2020 2:08:18 PM             |
| 0.15 | 12/7/2020 2:09:18 PM             |
| 0.15 | 12/7/2020 2:10:19 PM             |
| 0.15 | 12/7/2020 2:11:20 PM             |
| 0.15 | 12/7/2020 2:12:20 PM             |
| 0.15 | 12/7/2020 2:13:21 PM             |
| 0.15 | 12/7/2020 2:14:21 PM             |
| 0.15 | 12/7/2020 2:15:22 PM             |
| 0.15 | 12/7/2020 2:16:23 PM             |
| 0.21 | 12/7/2020 2:17:23 PM             |
| 0.17 | 12/7/2020 2:18:24 PM             |
| 0.15 | 12/7/2020 2:19:25 PM             |
| 0.15 | 12/7/2020 2:20:25 PM             |
| 0.15 | 12/7/2020 2:21:26 PM             |
| 0.15 | 12/7/2020 2:22:27 PM             |
| 0.15 | 12/7/2020 2:23:27 PM             |
| 0.15 | 12/7/2020 2:24:28 PM             |
| 0.15 | 12/7/2020 2:25:29 PM             |
| 0.27 | 12/7/2020 2:26:30 PM             |
| 0.34 | 12/7/2020 2:27:31 PM             |
| 0.16 | 12/7/2020 2:28:32 PM             |
| 0.15 | 12/7/2020 2:29:36 PM             |
| 0.15 | 12/7/2020 2:30:37 PM             |
| 0.15 | 12/7/2020 2:31:38 PM             |
| 0.15 | 12/7/2020 2:32:42 PM             |
| 0.15 | 12/7/2020 2:33:43 PM             |
| 0.18 | 12/7/2020 2:34:46 PM             |
| 0.15 | 12/7/2020 2:35:47 PM             |
| 0.15 | 12/7/2020 2:36:50 PM             |
| 0.15 | 12/7/2020 2:37:51 PM             |
| 0.15 | 12/7/2020 2:38:52 PM             |
| 0.15 | 12/7/2020 2:39:53 PM             |
| 0.24 | 12/7/2020 2:40:55 PM             |
| 0.18 | 12/7/2020 2:41:56 PM             |

|       |                                  |
|-------|----------------------------------|
| 0.15  | 12/7/2020 2:42:58 PM             |
| 0.15  | 12/7/2020 2:43:59 PM             |
| 0.15  | 12/7/2020 2:44:01 PM             |
| 0.15  | 12/7/2020 2:45:02 PM Stop Run 2  |
| 0.17  | Avg                              |
| 0.15  | 12/7/2020 2:46:03 PM             |
| 0.15  | 12/7/2020 2:47:04 PM             |
| 0.26  | 12/7/2020 2:48:05 PM             |
| 0.23  | 12/7/2020 2:49:06 PM             |
| 0.19  | 12/7/2020 2:50:07 PM             |
| 0.15  | 12/7/2020 2:51:08 PM             |
| 0.15  | 12/7/2020 2:52:08 PM             |
| 0.15  | 12/7/2020 2:53:09 PM             |
| 0.15  | 12/7/2020 2:54:10 PM             |
| 0.40  | 12/7/2020 2:55:10 PM             |
| 16.34 | 12/7/2020 2:56:11 PM             |
| 23.90 | 12/7/2020 2:57:12 PM             |
| 24.47 | 12/7/2020 2:58:12 PM Bias        |
| 24.70 | 12/7/2020 2:59:13 PM             |
| 24.62 | 12/7/2020 3:00:13 PM             |
| 24.46 | 12/7/2020 3:01:14 PM             |
| 24.44 | 12/7/2020 3:02:15 PM             |
| 24.69 | 12/7/2020 3:03:15 PM             |
| 21.88 | 12/7/2020 3:04:16 PM             |
| 0.15  | 12/7/2020 3:05:16 PM             |
| 0.15  | 12/7/2020 3:06:17 PM Zero        |
| 0.15  | 12/7/2020 3:07:18 PM             |
| 0.15  | 12/7/2020 3:08:18 PM             |
| 0.15  | 12/7/2020 3:09:19 PM             |
| 0.15  | 12/7/2020 3:10:19 PM             |
| 0.22  | 12/7/2020 3:11:20 PM             |
| 0.15  | 12/7/2020 3:12:21 PM             |
| 0.15  | 12/7/2020 3:13:21 PM Start Run 3 |
| 0.15  | 12/7/2020 3:14:22 PM             |
| 0.25  | 12/7/2020 3:15:22 PM             |
| 0.36  | 12/7/2020 3:16:23 PM             |
| 0.24  | 12/7/2020 3:17:24 PM             |
| 0.15  | 12/7/2020 3:18:24 PM             |
| 0.15  | 12/7/2020 3:19:25 PM             |
| 0.15  | 12/7/2020 3:20:26 PM             |
| 0.15  | 12/7/2020 3:21:26 PM             |
| 0.15  | 12/7/2020 3:22:27 PM             |
| 0.15  | 12/7/2020 3:23:27 PM             |
| 0.15  | 12/7/2020 3:24:28 PM             |
| 0.15  | 12/7/2020 3:25:29 PM             |
| 0.15  | 12/7/2020 3:26:29 PM             |
| 0.15  | 12/7/2020 3:27:30 PM             |
| 0.15  | 12/7/2020 3:28:30 PM             |
| 0.15  | 12/7/2020 3:29:31 PM             |
| 0.15  | 12/7/2020 3:30:31 PM             |
| 0.15  | 12/7/2020 3:31:32 PM             |
| 0.15  | 12/7/2020 3:32:33 PM             |
| 0.20  | 12/7/2020 3:33:33 PM             |
| 0.37  | 12/7/2020 3:34:34 PM             |
| 0.21  | 12/7/2020 3:35:35 PM             |
| 0.15  | 12/7/2020 3:36:35 PM             |
| 0.15  | 12/7/2020 3:37:36 PM             |
| 0.15  | 12/7/2020 3:38:36 PM             |
| 0.15  | 12/7/2020 3:39:37 PM             |
| 0.15  | 12/7/2020 3:40:38 PM             |
| 0.15  | 12/7/2020 3:41:38 PM             |

|       |                      |            |
|-------|----------------------|------------|
| 0.15  | 12/7/2020 3:41:38 PM |            |
| 0.15  | 12/7/2020 3:42:39 PM |            |
| 0.15  | 12/7/2020 3:43:39 PM |            |
| 0.15  | 12/7/2020 3:44:40 PM |            |
| 0.15  | 12/7/2020 3:45:41 PM |            |
| 0.15  | 12/7/2020 3:46:41 PM |            |
| 0.24  | 12/7/2020 3:47:42 PM |            |
| 0.46  | 12/7/2020 3:48:42 PM |            |
| 0.31  | 12/7/2020 3:49:43 PM |            |
| 0.18  | 12/7/2020 3:50:44 PM |            |
| 0.15  | 12/7/2020 3:51:44 PM |            |
| 0.15  | 12/7/2020 3:52:45 PM |            |
| 0.15  | 12/7/2020 3:53:45 PM |            |
| 0.15  | 12/7/2020 3:54:46 PM |            |
| 0.17  | 12/7/2020 3:55:47 PM |            |
| 0.15  | 12/7/2020 3:56:47 PM |            |
| 0.15  | 12/7/2020 3:57:48 PM |            |
| 0.15  | 12/7/2020 3:58:48 PM |            |
| 0.15  | 12/7/2020 3:59:49 PM |            |
| 0.15  | 12/7/2020 4:00:50 PM |            |
| 0.15  | 12/7/2020 4:01:50 PM |            |
| 0.15  | 12/7/2020 4:02:51 PM |            |
| 0.23  | 12/7/2020 4:03:51 PM |            |
| 0.29  | 12/7/2020 4:04:52 PM |            |
| 0.20  | 12/7/2020 4:05:53 PM |            |
| 0.15  | 12/7/2020 4:06:53 PM |            |
| 0.15  | 12/7/2020 4:07:54 PM |            |
| 0.15  | 12/7/2020 4:08:54 PM |            |
| 0.15  | 12/7/2020 4:09:55 PM |            |
| 0.16  | 12/7/2020 4:10:56 PM |            |
| 0.15  | 12/7/2020 4:11:56 PM |            |
| 0.15  | 12/7/2020 4:12:57 PM |            |
| 0.17  | 12/7/2020 4:13:57 PM | Stop Run 3 |
| 0.18  |                      | Avg        |
| 0.15  | 12/7/2020 4:14:58 PM |            |
| 0.15  | 12/7/2020 4:15:59 PM |            |
| 0.15  | 12/7/2020 4:16:59 PM |            |
| 0.27  | 12/7/2020 4:17:01 PM |            |
| 0.19  | 12/7/2020 4:18:02 PM |            |
| 0.15  | 12/7/2020 4:19:02 PM |            |
| 0.15  | 12/7/2020 4:20:03 PM |            |
| 0.15  | 12/7/2020 4:21:03 PM |            |
| 0.15  | 12/7/2020 4:22:04 PM |            |
| 1.05  | 12/7/2020 4:23:04 PM |            |
| 22.63 | 12/7/2020 4:24:05 PM |            |
| 24.79 | 12/7/2020 4:25:06 PM |            |
| 25.52 | 12/7/2020 4:26:06 PM | Bias       |
| 25.51 | 12/7/2020 4:27:07 PM |            |
| 25.05 | 12/7/2020 4:28:07 PM |            |
| 25.50 | 12/7/2020 4:29:08 PM |            |
| 25.64 | 12/7/2020 4:30:08 PM |            |
| 25.67 | 12/7/2020 4:31:09 PM |            |
| 10.69 | 12/7/2020 4:32:10 PM |            |
| 0.15  | 12/7/2020 4:33:10 PM | Zero       |
| 0.15  | 12/7/2020 4:34:11 PM |            |
| 0.15  | 12/7/2020 4:35:12 PM |            |

Meggitt Aircraft Braking Systems Corporation  
South Afterburner Outlet

|      |       |
|------|-------|
| VOC  | Conc. |
| High | 47.05 |
| Mid  | 24.7  |
| Low  | 13.7  |

| VOC   | Time Stamp                       |
|-------|----------------------------------|
| 46.92 | 12/8/2020 7:59:44 AM             |
| 47.22 | 12/8/2020 8:00:45 AM High        |
| 47.23 | 12/8/2020 8:01:45 AM             |
| 47.22 | 12/8/2020 8:02:46 AM             |
| 47.41 | 12/8/2020 8:03:46 AM             |
| 47.67 | 12/8/2020 8:04:47 AM             |
| 47.86 | 12/8/2020 8:05:48 AM             |
| 12.15 | 12/8/2020 8:06:48 AM             |
| 0.02  | 12/8/2020 8:07:49 AM             |
| 0.02  | 12/8/2020 8:08:50 AM Zero        |
| 0.02  | 12/8/2020 8:09:50 AM             |
| 0.02  | 12/8/2020 8:10:51 AM             |
| 0.79  | 12/8/2020 8:11:51 AM             |
| 0.02  | 12/8/2020 8:12:52 AM             |
| 0.02  | 12/8/2020 8:13:52 AM             |
| 1.08  | 12/8/2020 8:14:53 AM             |
| 12.10 | 12/8/2020 8:15:54 AM             |
| 13.10 | 12/8/2020 8:16:54 AM             |
| 13.40 | 12/8/2020 8:17:55 AM Low         |
| 13.43 | 12/8/2020 8:18:56 AM             |
| 13.36 | 12/8/2020 8:19:56 AM             |
| 12.95 | 12/8/2020 8:20:57 AM             |
| 12.75 | 12/8/2020 8:21:57 AM             |
| 12.80 | 12/8/2020 8:22:58 AM             |
| 12.03 | 12/8/2020 8:23:59 AM             |
| 19.00 | 12/8/2020 8:24:59 AM             |
| 23.96 | 12/8/2020 8:26:00 AM             |
| 24.87 | 12/8/2020 8:27:00 AM Bias        |
| 24.84 | 12/8/2020 8:28:01 AM             |
| 24.94 | 12/8/2020 8:29:02 AM             |
| 24.50 | 12/8/2020 8:30:02 AM             |
| 24.36 | 12/8/2020 8:31:03 AM             |
| 24.37 | 12/8/2020 8:32:03 AM             |
| 20.03 | 12/8/2020 8:33:04 AM             |
| 0.03  | 12/8/2020 8:34:05 AM             |
| 0.02  | 12/8/2020 8:35:05 AM             |
| 0.02  | 12/8/2020 8:36:06 AM             |
| 0.49  | 12/8/2020 8:37:06 AM             |
| 0.21  | 12/8/2020 8:38:07 AM             |
| 0.02  | 12/8/2020 8:39:08 AM             |
| 0.02  | 12/8/2020 8:40:08 AM Start Run 1 |
| 0.02  | 12/8/2020 8:41:09 AM             |
| 0.02  | 12/8/2020 8:42:10 AM             |
| 0.48  | 12/8/2020 8:43:10 AM             |
| 0.15  | 12/8/2020 8:44:11 AM             |
| 0.02  | 12/8/2020 8:45:11 AM             |
| 0.02  | 12/8/2020 8:46:12 AM             |
| 0.02  | 12/8/2020 8:47:12 AM             |
| 0.02  | 12/8/2020 8:48:13 AM             |
| 0.02  | 12/8/2020 8:49:14 AM             |
| 0.34  | 12/8/2020 8:50:14 AM             |

|       |                                 |
|-------|---------------------------------|
| 0.15  | 12/8/2020 8:51:15 AM            |
| 0.02  | 12/8/2020 8:52:15 AM            |
| 0.02  | 12/8/2020 8:53:16 AM            |
| 0.02  | 12/8/2020 8:54:17 AM            |
| 0.02  | 12/8/2020 8:55:17 AM            |
| 0.02  | 12/8/2020 8:56:18 AM            |
| 0.07  | 12/8/2020 8:57:18 AM            |
| 0.02  | 12/8/2020 8:58:19 AM            |
| 0.02  | 12/8/2020 8:59:20 AM            |
| 0.02  | 12/8/2020 9:00:20 AM            |
| 0.02  | 12/8/2020 9:01:21 AM            |
| 0.47  | 12/8/2020 9:02:22 AM            |
| 0.02  | 12/8/2020 9:03:22 AM            |
| 0.02  | 12/8/2020 9:04:23 AM            |
| 0.02  | 12/8/2020 9:05:23 AM            |
| 0.25  | 12/8/2020 9:06:24 AM            |
| 0.02  | 12/8/2020 9:07:25 AM            |
| 0.02  | 12/8/2020 9:08:25 AM            |
| 0.06  | 12/8/2020 9:09:26 AM            |
| 0.02  | 12/8/2020 9:10:26 AM            |
| 0.02  | 12/8/2020 9:11:27 AM            |
| 0.18  | 12/8/2020 9:12:27 AM            |
| 0.02  | 12/8/2020 9:13:28 AM            |
| 0.02  | 12/8/2020 9:14:29 AM            |
| 0.02  | 12/8/2020 9:15:29 AM            |
| 0.61  | 12/8/2020 9:16:30 AM            |
| 0.02  | 12/8/2020 9:17:31 AM            |
| 0.02  | 12/8/2020 9:18:31 AM            |
| 0.02  | 12/8/2020 9:19:32 AM            |
| 0.26  | 12/8/2020 9:20:32 AM            |
| 0.11  | 12/8/2020 9:21:33 AM            |
| 0.02  | 12/8/2020 9:22:34 AM            |
| 0.02  | 12/8/2020 9:23:34 AM            |
| 0.02  | 12/8/2020 9:24:35 AM            |
| 0.51  | 12/8/2020 9:25:35 AM            |
| 0.02  | 12/8/2020 9:26:36 AM            |
| 0.02  | 12/8/2020 9:27:37 AM            |
| 0.07  | 12/8/2020 9:28:37 AM            |
| 0.02  | 12/8/2020 9:29:38 AM            |
| 0.09  | 12/8/2020 9:30:39 AM            |
| 0.02  | 12/8/2020 9:31:39 AM            |
| 0.02  | 12/8/2020 9:32:40 AM            |
| 0.67  | 12/8/2020 9:33:40 AM            |
| 0.41  | 12/8/2020 9:34:41 AM            |
| 0.07  | 12/8/2020 9:35:42 AM            |
| 0.02  | 12/8/2020 9:36:42 AM            |
| 0.02  | 12/8/2020 9:37:43 AM            |
| 0.02  | 12/8/2020 9:38:43 AM            |
| 0.02  | 12/8/2020 9:39:44 AM            |
| 0.13  | 12/8/2020 9:40:44 AM Stop Run 1 |
| 0.10  | Avg                             |
| 0.02  | 12/8/2020 9:41:45 AM            |
| 0.02  | 12/8/2020 9:42:46 AM            |
| 0.37  | 12/8/2020 9:43:46 AM            |
| 0.16  | 12/8/2020 9:44:47 AM            |
| 0.02  | 12/8/2020 9:45:48 AM            |
| 0.61  | 12/8/2020 9:46:48 AM            |
| 22.83 | 12/8/2020 9:47:49 AM            |
| 19.05 | 12/8/2020 9:48:49 AM            |
| 24.41 | 12/8/2020 9:49:50 AM            |
| 24.37 | 12/8/2020 9:50:51 AM            |
| 24.55 | 12/8/2020 9:51:51 AM Bias       |

|       |                                   |
|-------|-----------------------------------|
| 24.44 | 12/8/2020 9:52:52 AM              |
| 24.95 | 12/8/2020 9:53:52 AM              |
| 25.10 | 12/8/2020 9:54:53 AM              |
| 24.86 | 12/8/2020 9:55:54 AM              |
| 19.80 | 12/8/2020 9:56:54 AM              |
| 0.02  | 12/8/2020 9:57:55 AM              |
| 0.02  | 12/8/2020 9:58:55 AM              |
| 0.02  | 12/8/2020 9:59:56 AM              |
| 0.02  | 12/8/2020 10:00:57 AM             |
| 0.02  | 12/8/2020 10:01:57 AM Zero        |
| 0.02  | 12/8/2020 10:02:58 AM             |
| 0.02  | 12/8/2020 10:03:58 AM             |
| 0.08  | 12/8/2020 10:04:59 AM             |
| 0.02  | 12/8/2020 10:06:00 AM             |
| 0.02  | 12/8/2020 10:07:00 AM             |
| 0.02  | 12/8/2020 10:08:01 AM             |
| 0.12  | 12/8/2020 10:09:02 AM             |
| 0.02  | 12/8/2020 10:10:02 AM             |
| 0.02  | 12/8/2020 10:11:03 AM             |
| 0.05  | 12/8/2020 10:12:03 AM             |
| 0.02  | 12/8/2020 10:13:04 AM             |
| 0.02  | 12/8/2020 10:14:04 AM             |
| 0.02  | 12/8/2020 10:15:05 AM             |
| 0.02  | 12/8/2020 10:16:06 AM             |
| 0.33  | 12/8/2020 10:17:06 AM             |
| 0.02  | 12/8/2020 10:18:07 AM             |
| 0.02  | 12/8/2020 10:19:07 AM             |
| 0.15  | 12/8/2020 10:20:08 AM             |
| 0.02  | 12/8/2020 10:21:09 AM             |
| 0.06  | 12/8/2020 10:22:09 AM             |
| 0.02  | 12/8/2020 10:23:10 AM             |
| 0.02  | 12/8/2020 10:24:11 AM             |
| 0.02  | 12/8/2020 10:25:11 AM             |
| 0.02  | 12/8/2020 10:26:12 AM             |
| 0.02  | 12/8/2020 10:27:12 AM             |
| 0.09  | 12/8/2020 10:28:13 AM             |
| 0.02  | 12/8/2020 10:29:14 AM             |
| 0.02  | 12/8/2020 10:30:14 AM             |
| 0.02  | 12/8/2020 10:31:15 AM             |
| 0.02  | 12/8/2020 10:32:15 AM             |
| 0.02  | 12/8/2020 10:33:16 AM             |
| 0.02  | 12/8/2020 10:34:17 AM             |
| 0.11  | 12/8/2020 10:35:17 AM             |
| 0.02  | 12/8/2020 10:36:18 AM             |
| 0.02  | 12/8/2020 10:37:18 AM             |
| 0.02  | 12/8/2020 10:38:19 AM             |
| 0.02  | 12/8/2020 10:39:19 AM             |
| 0.05  | 12/8/2020 10:40:20 AM Start Run 2 |
| 0.02  | 12/8/2020 10:41:21 AM             |
| 0.02  | 12/8/2020 10:42:21 AM             |
| 0.02  | 12/8/2020 10:43:22 AM             |
| 0.25  | 12/8/2020 10:44:23 AM             |
| 0.02  | 12/8/2020 10:45:23 AM             |
| 0.02  | 12/8/2020 10:46:24 AM             |
| 0.51  | 12/8/2020 10:47:24 AM             |
| 0.02  | 12/8/2020 10:48:25 AM             |
| 0.02  | 12/8/2020 10:49:26 AM             |
| 0.02  | 12/8/2020 10:50:26 AM             |
| 0.24  | 12/8/2020 10:51:27 AM             |
| 0.16  | 12/8/2020 10:52:27 AM             |
| 0.02  | 12/8/2020 10:53:28 AM             |
| 0.05  | 12/8/2020 10:54:29 AM             |

|       |                       |            |
|-------|-----------------------|------------|
| 0.02  | 12/8/2020 10:55:29 AM |            |
| 0.02  | 12/8/2020 10:56:30 AM |            |
| 0.02  | 12/8/2020 10:57:30 AM |            |
| 0.02  | 12/8/2020 10:58:31 AM |            |
| 0.27  | 12/8/2020 10:59:32 AM |            |
| 0.02  | 12/8/2020 11:00:32 AM |            |
| 0.02  | 12/8/2020 11:01:33 AM |            |
| 0.12  | 12/8/2020 11:02:33 AM |            |
| 0.02  | 12/8/2020 11:03:34 AM |            |
| 0.02  | 12/8/2020 11:04:35 AM |            |
| 0.08  | 12/8/2020 11:05:35 AM |            |
| 0.02  | 12/8/2020 11:06:36 AM |            |
| 0.02  | 12/8/2020 11:07:37 AM |            |
| 0.02  | 12/8/2020 11:08:37 AM |            |
| 0.02  | 12/8/2020 11:09:38 AM |            |
| 0.49  | 12/8/2020 11:10:38 AM |            |
| 0.24  | 12/8/2020 11:11:39 AM |            |
| 0.02  | 12/8/2020 11:12:40 AM |            |
| 0.02  | 12/8/2020 11:13:40 AM |            |
| 0.02  | 12/8/2020 11:14:41 AM |            |
| 0.02  | 12/8/2020 11:15:41 AM |            |
| 0.14  | 12/8/2020 11:16:42 AM |            |
| 0.42  | 12/8/2020 11:17:42 AM |            |
| 0.02  | 12/8/2020 11:18:43 AM |            |
| 0.02  | 12/8/2020 11:19:44 AM |            |
| 0.02  | 12/8/2020 11:20:44 AM |            |
| 0.02  | 12/8/2020 11:21:45 AM |            |
| 0.38  | 12/8/2020 11:22:45 AM |            |
| 0.02  | 12/8/2020 11:23:46 AM |            |
| 0.02  | 12/8/2020 11:24:47 AM |            |
| 0.02  | 12/8/2020 11:25:47 AM |            |
| 0.14  | 12/8/2020 11:26:48 AM |            |
| 0.02  | 12/8/2020 11:27:48 AM |            |
| 0.02  | 12/8/2020 11:28:49 AM |            |
| 0.02  | 12/8/2020 11:29:50 AM |            |
| 0.02  | 12/8/2020 11:30:50 AM |            |
| 0.02  | 12/8/2020 11:31:51 AM |            |
| 0.02  | 12/8/2020 11:32:52 AM |            |
| 0.23  | 12/8/2020 11:33:52 AM |            |
| 0.02  | 12/8/2020 11:34:53 AM |            |
| 0.02  | 12/8/2020 11:35:53 AM |            |
| 0.02  | 12/8/2020 11:36:54 AM |            |
| 0.07  | 12/8/2020 11:37:55 AM |            |
| 0.02  | 12/8/2020 11:38:55 AM |            |
| 0.02  | 12/8/2020 11:39:56 AM |            |
| 0.02  | 12/8/2020 11:40:57 AM | Stop Run 2 |
| 0.08  |                       | Avg        |
| 0.02  | 12/8/2020 11:41:57 AM |            |
| 0.06  | 12/8/2020 11:42:58 AM |            |
| 0.02  | 12/8/2020 11:43:58 AM |            |
| 0.02  | 12/8/2020 11:44:59 AM |            |
| 0.02  | 12/8/2020 11:46:00 AM |            |
| 0.09  | 12/8/2020 11:47:00 AM |            |
| 0.02  | 12/8/2020 11:48:01 AM |            |
| 0.05  | 12/8/2020 11:49:01 AM |            |
| 5.11  | 12/8/2020 11:50:02 AM |            |
| 24.40 | 12/8/2020 11:51:02 AM |            |
| 24.71 | 12/8/2020 11:52:03 AM |            |
| 25.01 | 12/8/2020 11:53:04 AM | Bias       |
| 24.95 | 12/8/2020 11:54:04 AM |            |
| 25.02 | 12/8/2020 11:55:05 AM |            |
| 25.03 | 12/8/2020 11:56:05 AM |            |

|       |                                   |
|-------|-----------------------------------|
| 25.04 | 12/8/2020 11:57:06 AM             |
| 25.05 | 12/8/2020 11:58:07 AM             |
| 7.72  | 12/8/2020 11:59:07 AM             |
| 0.02  | 12/8/2020 12:00:08 PM             |
| 0.02  | 12/8/2020 12:01:08 PM             |
| 0.02  | 12/8/2020 12:02:09 PM             |
| 0.02  | 12/8/2020 12:03:10 PM Zero        |
| 0.02  | 12/8/2020 12:04:10 PM             |
| 0.02  | 12/8/2020 12:05:11 PM             |
| 0.02  | 12/8/2020 12:06:11 PM             |
| 0.11  | 12/8/2020 12:07:12 PM             |
| 0.02  | 12/8/2020 12:08:13 PM             |
| 0.02  | 12/8/2020 12:09:13 PM             |
| 0.02  | 12/8/2020 12:10:14 PM             |
| 0.02  | 12/8/2020 12:11:14 PM             |
| 0.02  | 12/8/2020 12:12:15 PM             |
| 0.08  | 12/8/2020 12:13:16 PM             |
| 0.02  | 12/8/2020 12:14:16 PM             |
| 0.02  | 12/8/2020 12:15:17 PM Start Run 3 |
| 0.07  | 12/8/2020 12:16:18 PM             |
| 0.02  | 12/8/2020 12:17:18 PM             |
| 0.02  | 12/8/2020 12:18:19 PM             |
| 0.37  | 12/8/2020 12:19:19 PM             |
| 0.02  | 12/8/2020 12:20:20 PM             |
| 0.02  | 12/8/2020 12:21:21 PM             |
| 0.08  | 12/8/2020 12:22:21 PM             |
| 0.02  | 12/8/2020 12:23:22 PM             |
| 0.05  | 12/8/2020 12:24:22 PM             |
| 0.02  | 12/8/2020 12:25:23 PM             |
| 0.02  | 12/8/2020 12:26:24 PM             |
| 0.02  | 12/8/2020 12:27:24 PM             |
| 0.02  | 12/8/2020 12:28:25 PM             |
| 0.06  | 12/8/2020 12:29:25 PM             |
| 0.02  | 12/8/2020 12:30:26 PM             |
| 0.29  | 12/8/2020 12:31:27 PM             |
| 0.02  | 12/8/2020 12:32:27 PM             |
| 0.02  | 12/8/2020 12:33:28 PM             |
| 0.02  | 12/8/2020 12:34:28 PM             |
| 0.15  | 12/8/2020 12:35:29 PM             |
| 0.02  | 12/8/2020 12:36:30 PM             |
| 0.02  | 12/8/2020 12:37:30 PM             |
| 0.35  | 12/8/2020 12:38:31 PM             |
| 0.02  | 12/8/2020 12:39:31 PM             |
| 0.02  | 12/8/2020 12:40:32 PM             |
| 0.02  | 12/8/2020 12:41:33 PM             |
| 0.02  | 12/8/2020 12:42:33 PM             |
| 0.26  | 12/8/2020 12:43:34 PM             |
| 0.02  | 12/8/2020 12:44:35 PM             |
| 0.02  | 12/8/2020 12:45:35 PM             |
| 0.02  | 12/8/2020 12:46:36 PM             |
| 0.25  | 12/8/2020 12:47:36 PM             |
| 0.02  | 12/8/2020 12:48:37 PM             |
| 0.02  | 12/8/2020 12:49:38 PM             |
| 0.19  | 12/8/2020 12:50:38 PM             |
| 0.02  | 12/8/2020 12:51:39 PM             |
| 0.02  | 12/8/2020 12:52:39 PM             |
| 0.02  | 12/8/2020 12:53:40 PM             |
| 0.05  | 12/8/2020 12:54:40 PM             |
| 0.02  | 12/8/2020 12:55:41 PM             |
| 0.02  | 12/8/2020 12:56:42 PM             |
| 0.06  | 12/8/2020 12:57:42 PM             |
| 0.02  | 12/8/2020 12:58:43 PM             |

|       |                       |            |
|-------|-----------------------|------------|
| 0.02  | 12/8/2020 12:59:44 PM |            |
| 0.02  | 12/8/2020 1:00:44 PM  |            |
| 0.02  | 12/8/2020 1:01:45 PM  |            |
| 0.31  | 12/8/2020 1:02:45 PM  |            |
| 0.02  | 12/8/2020 1:03:46 PM  |            |
| 0.02  | 12/8/2020 1:04:47 PM  |            |
| 0.02  | 12/8/2020 1:05:47 PM  |            |
| 0.27  | 12/8/2020 1:06:48 PM  |            |
| 0.02  | 12/8/2020 1:07:48 PM  |            |
| 0.02  | 12/8/2020 1:08:49 PM  |            |
| 0.02  | 12/8/2020 1:09:50 PM  |            |
| 0.02  | 12/8/2020 1:10:50 PM  |            |
| 0.53  | 12/8/2020 1:11:51 PM  |            |
| 0.15  | 12/8/2020 1:12:51 PM  |            |
| 0.02  | 12/8/2020 1:13:52 PM  |            |
| 0.02  | 12/8/2020 1:14:53 PM  |            |
| 0.03  | 12/8/2020 1:15:53 PM  | Stop Run 3 |
| 0.07  |                       | Avg        |
| 0.02  | 12/8/2020 1:16:54 PM  |            |
| 0.02  | 12/8/2020 1:17:55 PM  |            |
| 0.10  | 12/8/2020 1:18:55 PM  |            |
| 0.02  | 12/8/2020 1:19:56 PM  |            |
| 0.02  | 12/8/2020 1:20:56 PM  |            |
| 0.02  | 12/8/2020 1:21:57 PM  |            |
| 0.13  | 12/8/2020 1:22:57 PM  |            |
| 0.02  | 12/8/2020 1:23:58 PM  |            |
| 18.19 | 12/8/2020 1:24:59 PM  |            |
| 23.99 | 12/8/2020 1:25:59 PM  |            |
| 24.91 | 12/8/2020 1:27:00 PM  |            |
| 25.63 | 12/8/2020 1:28:00 PM  |            |
| 25.77 | 12/8/2020 1:29:01 PM  |            |
| 25.89 | 12/8/2020 1:30:02 PM  | Bias       |
| 26.00 | 12/8/2020 1:31:02 PM  |            |
| 26.02 | 12/8/2020 1:32:03 PM  |            |
| 26.02 | 12/8/2020 1:33:04 PM  |            |
| 26.02 | 12/8/2020 1:34:04 PM  |            |
| 25.82 | 12/8/2020 1:35:05 PM  |            |
| 1.67  | 12/8/2020 1:36:05 PM  |            |
| 0.15  | 12/8/2020 1:37:06 PM  |            |
| 0.02  | 12/8/2020 1:38:07 PM  |            |
| 0.02  | 12/8/2020 1:39:07 PM  | Zero       |
| 0.03  | 12/8/2020 1:40:08 PM  |            |



Meggitt Aircraft Braking Systems Corporation  
1204 Massillon Road  
Akron, Ohio 44306

### Report

Performed Velocity, Moisture, Temperature, Volumetric Flow Rate,  
Oxygen, Carbon Dioxide, Nitrogen Oxide, Carbon Monoxide and  
Volatile Organic Compounds Emissions Testing

Sampling performed on the P039 Accutherm Thermal Oxidizer Outlet

Akron, OH

Test Date: 4/15/2021

**Meggitt Aircraft Braking Systems Corporation  
1204 Massillon Road  
Akron, Ohio 44306**

**Report**

**Performed Velocity, Moisture, Temperature, Volumetric Flow Rate,  
Oxygen, Carbon Dioxide, Nitrogen Oxide, Carbon Monoxide and  
Volatile Organic Compounds Emissions Testing**

**Sampling performed on the P039 Accutherm Thermal Oxidizer Outlet**

**Akron, OH**

**Test Date: 4/15/2021**

A handwritten signature in black ink, reading "Brian E. Lemasters". The signature is written in a cursive style with a large initial "B".

**Brian E. Lemasters  
Custom Stack Analysis, LLC.**

## REPORT CERTIFICATION

Custom Stack Analysis, LLC. has used its professional experience and best professional efforts in performing this compliance test. I have reviewed the results of these tests, and to the best of my knowledge and belief, they are true and correct.

A handwritten signature in black ink, reading "Brian E. Lemasters". The signature is written in a cursive style with a large initial "B".

Brian E. Lemasters

## **TABLE OF CONTENTS**

|                                 |       |
|---------------------------------|-------|
| Executive Summary .....         | 1-2   |
| Test Results .....              | 3     |
| Methods Description .....       | 4-8   |
| Sampling Train Diagrams .....   | 9-13  |
| Sampling Point Description..... | 14    |
| Calculations .....              | 15-22 |

## **APPENDIX**

|                        |   |
|------------------------|---|
| Test Data .....        | 1 |
| Laboratory Data .....  | 2 |
| Calibration Data ..... | 3 |
| Monitoring Data .....  | 4 |
| Process Data .....     | 5 |

## **EXECUTIVE SUMMARY**

Custom Stack Analysis, LLC. conducted emissions sampling using USEPA Methods 1-4, 3A, 7E, 10 and 25A. Testing was conducted on the P039 Accutherm Outlet on April 15<sup>th</sup>, 2021. The testing was conducted at Meggitt Aircraft Braking Systems Corporation (Facility ID – 16-77-01-0999) on P039 Accutherm Outlet to determine compliance status with Permit No. – P0121253 (see Table 1.2).

The Custom Stack Analysis, LLC. test crew consisted of Mr. James Gray, Mr. Dylan Gray and Mr. Brian Lemasters. The testing procedures were coordinated by Mr. Jim Davies of Meggitt Aircraft Braking Systems Corporation. All testing procedures were witnessed by Mr. Connor Moroney of the Akron Regional Air Quality Management District (see Table 1.1).

**Table 1.1: Emissions Testing Program Contact Personnel**

| Name, Title                                                                                                       | Company Address                                                                            | Phone, Fax, email                              |
|-------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|------------------------------------------------|
| Mr. Jim Davies                                                                                                    | Meggitt Aircraft Braking Systems Corporation<br>1204 Massillon Road<br>Akron, OH 44306     | (330) 796-1743 (Phone)                         |
| Mr. Connor Moroney                                                                                                | Akron Regional Air Quality<br>Management District<br>1867 W. Market St,<br>Akron, OH 44313 | (330) 812-3904 (Phone)                         |
| Mr. James Gray<br>Owner<br><br>Mr. Brian Lemasters<br>Project Manager<br><br>Mr. Dylan Gray<br>Project Technician | Custom Stack Analysis, LLC.<br>14614 Cenfield St. N.E.<br>Alliance, OH 44601               | (330) 525-5119 (Phone)<br>(330) 525-7908 (Fax) |

Test results are located on page 3. A description of the testing protocol is included on pages 4-8. All testing calculations are located on pages 15-22. Appendix 1 includes field test data. Appendix 2 contains laboratory data from Custom Stack Analysis, LLC. Appendix 3 contains calibration data for the equipment used on test day. Appendix 4 contains monitoring data. Appendix 5 contains process data.

Table 1.2 demonstrates how Meggitt Aircraft Braking Systems Corporation in Akron, OH is operating in compliance with the applicable emission standards.

**Table 1.2: Emission Limits and Test Results Summary**

| Pollutant                  | Emission Limitations | Test Result Average | Compliance Demonstrated |
|----------------------------|----------------------|---------------------|-------------------------|
| Nitrogen Oxide             |                      | 0.637 tons/yr       |                         |
| Volatile Organic Compounds | 0.36 tons/yr         | 0.0199 tons/yr      | Yes                     |
| Carbon Monoxide            |                      | 0.0023 tons/yr      |                         |

# Test Results

Meggitt Aircraft Braking Systems Corporation - P039 Accutherm Outlet  
4/15/2021

Methods 1-4, 3A, 7E, 10 and 25A

|                              | <u>Run #1</u> | <u>Run #2</u> | <u>Run #3</u> | <u>Avg.</u> |
|------------------------------|---------------|---------------|---------------|-------------|
| Stack Gas Velocity (ft/sec)  | 12.70         | 13.02         | 13.18         | 12.97       |
| Standard Cubic Feet an Hour  | 50,567        | 50,007        | 49,802        | 50,125      |
| Actual Cubic Feet per Minute | 2,394         | 2,454         | 2,484         | 2,444       |
| Moisture %                   | 5.33%         | 6.49%         | 6.14%         | 5.99%       |
| Carbon Dioxide %             | 3.24%         | 2.92%         | 3.32%         | 3.16%       |
| Oxygen %                     | 14.21%        | 14.76%        | 14.27%        | 14.41%      |
| Nitrogen %                   | 82.55%        | 82.33%        | 82.41%        | 82.43%      |
| CO (ppm)                     | 0.07          | 0.17          | 0.20          | 0.14        |
| CO (lbs/hr)                  | 0.0002        | 0.0006        | 0.0007        | 0.0005      |
| CO (tons/yr)                 | 0.0011        | 0.0026        | 0.0032        | 0.0023      |
| Nox (ppm)                    | 24.77         | 24.02         | 24.11         | 24.30       |
| Nox (lbs/hr)                 | 0.1496        | 0.1434        | 0.1433        | 0.1454      |
| Nox (tons/yr)                | 0.6551        | 0.6282        | 0.6278        | 0.6370      |
| VOC (ppm)                    | 0.86          | 1.28          | 0.77          | 0.97        |
| VOC (lbs/hr Carbon)          | 0.0040        | 0.0060        | 0.0036        | 0.0045      |
| VOC (tons/yr)                | 0.0177        | 0.0263        | 0.0157        | 0.0199      |

## **METHOD 1**

Sample and velocity traverses for stationary sources.

To aid in the representative measurement of pollutant emissions and/ or total volumetric flow rate from a stationary source, a measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas. A traverse point is then located within each of these equal areas.

## **METHOD 2**

Determination of stack gas velocity and volumetric flow rate.

The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Staustscheibe or reverse type) pitot tube.

## **METHOD 3**

Gas analysis for the determination of dry molecular weight.

This method is applicable for determining carbon dioxide and oxygen concentrations and dry molecular weight of a sample from a gas stream of a fossil-fuel combustion process.

## **METHOD 4**

Determination of moisture content in stack gases.

A gas sample is extracted at a constant rate from the source. It is determined either volumetrically or gravimetrically.

## METHOD 3A TESTING DESCRIPTION

A gas sample is continuously extracted from the stack, and a portion of the sample is conveyed to an instrumental analyzer for determination of O<sub>2</sub> gas concentration. The gases pass through a heated sampling probe and filter to prevent condensation. The gases then pass through a calibration valve to a heated sampling line. After the heated sampling line is a Universal Analyzers Model 530 air cooled single sample thermoelectric water condenser with a perostolic pump for moisture removal. The sample is then passed through to a California Analytical Instruments Model 100F for O<sub>2</sub> concentrations. Before the testing procedures commence the analyzer is left to warm up for a 90 minute period. It is then calibrated according to Method 7E specifications. To the extent practicable, the measured emissions should be between 20 to 100 percent of the selected calibration span. Three calibration gases are selected. The High-Level gas concentrations shall be equivalent to 20 to 100 percent of the calibration span. Mid-Level concentrations shall be equivalent to 40 to 60 percent of the calibration span. The Low-Level Gas concentrations of less than 20 percent of the span. Before the first run an analyzer calibration error check is conducted. If the low-level, mid, or high cal gases expected concentrations differ by more than  $\pm 2\%$  of the span then the procedure needs to be repeated until an acceptable 3 point calibration is obtained. After the analyzer calibration check the upscale and low level calibration gases are introduced to the sampling calibration valve and recorded. System bias calibration must be within 5.0% of the analyzer calibration span for low-scale and upscale calibration gases. At the conclusion of each of the test runs the low-level gas and an upscale gas closest to the concentrations are introduced to the calibration valve assembly. If either the low-level or upscale value exceeds  $\pm 3\%$  of the span, then the run is considered invalid.

## METHOD 7E TESTING DESCRIPTION

A gas sample is continuously extracted from the stack, and a portion of the sample is conveyed to an instrumental analyzer for determination of NO<sub>x</sub> gas concentration using a chemiluminescence analyzer. The gases pass through a heated sampling probe and filter to prevent condensation. The gases then pass through a calibration valve to a heated sampling line. After the heated sampling line is a condenser for moisture removal. The sample is then passed through to a Thermo Environmental Instruments Model 42 chemiluminescence analyzer where the gases are analyzed for NO<sub>x</sub> concentrations. Before the testing procedures commence the analyzer is left to warm up for a 90 minute period. It is then calibrated according to Method 7E specifications. To the extent practicable, the measured emissions should be between 20 to 100 percent of the selected calibration span. Three calibration gases are selected. The High-Level gas concentrations shall be equivalent to 20 to 100 percent of the calibration span. Mid-Level concentrations shall be equivalent to 40 to 60 percent of the calibration span. The Low-Level Gas concentrations of less than 20 percent of the span. Before the first run an analyzer calibration error check is conducted. If the low-level, mid, or high cal gases expected concentrations differ by more than  $\pm 2\%$  of the span then the procedure needs to be repeated until an acceptable 3 point calibration is obtained. After the analyzer calibration check the upscale and low level calibration gases are introduced to the sampling calibration valve and recorded. System bias calibration must be within 5.0% of the analyzer calibration span for low-scale and upscale calibration gases. At the conclusion of each of the test runs the low-level gas and an upscale gas closest to the concentrations are introduced to the calibration valve assembly. If either the low-level or upscale value exceeds  $\pm 3\%$  of the span, then the run is considered invalid.

## METHOD 10 TESTING DESCRIPTION

A gas sample is continuously extracted from the stack, and a portion of the sample is conveyed to an instrumental analyzer for determination of CO gas concentration using a Luft-type nondispersive infrared analyzer. The gases pass through a heated sampling probe and filter to prevent condensation. The gases then pass through a calibration valve to a heated sampling line. After the heated sampling line is a Universal Analyzers Model 530 air cooled single sample thermoelectric water condenser with a perostolic pump for moisture removal. The sample is then passed through an ascarite tube to a Thermo Environmental Instruments Model 48 Luft-type analyzer where the gases are analyzed for CO concentrations. Before the testing procedures commence the analyzer is left to warm up for a 90 minute period. It is then calibrated according to Method 7E specifications. To the extent practicable, the measured emissions should be between 20 to 100 percent of the selected calibration span. Three calibration gases are selected. The High-Level gas concentrations shall be equivalent to 20 to 100 percent of the calibration span. Mid-Level concentrations shall be equivalent to 40 to 60 percent of the calibration span. The Low-Level Gas concentrations of less than 20 percent of the span. Before the first run an analyzer calibration error check is conducted. If the low-level, mid, or high cal gases expected concentrations differ by more than  $\pm 2\%$  of the span then the procedure needs to be repeated until an acceptable 3 point calibration is obtained. After the analyzer calibration check the upscale and low level calibration gases are introduced to the sampling calibration valve and recorded. System bias calibration must be within 5.0% of the analyzer calibration span for low-scale and upscale calibration gases. At the conclusion of each of the test runs the low-level gas and an upscale gas closest to the concentrations are introduced to the calibration valve assembly. If either the low-level or upscale value exceeds  $\pm 3\%$  of the span, then the run is considered invalid.


## METHOD 25A TESTING DESCRIPTION

This method will be used to measure the total VOC concentration expressed in terms of ppm propane. A gas sample is extracted from the source through a stainless steel probe, through a heated sample line (teflon), to a flame ionization analyzer. The main components of Method 25A are the same as Method 204B with the exception of a non heated sample probe.


The sampling system is heated up to the proper operating temperature. Within two hours of the start of the test the FIA is calibrated. The calibration range or span is selected to be from 1.5 to 2.5 times the expected concentration. Three calibration ranges are then selected as follows: Low level 25-35% of the span, Mid level 45-55% of the span, and a High level 80-90% of the span. A zero and a high level calibration gas is then injected at the valve assembly and the FIA is adjusted to these levels. Then all four gases are introduced into the analyzer and recorded. If the responses are within 5% of the expected values then the analyzer is responding correctly. The sample probe is located in the center of the stack and sealed in place and the test is started. The test lasts for 60 minutes. At the end of the test run a drift check is ran. The zero gas and the mid level calibration gas is injected at the valve assembly. The analyzer responses are then recorded. The drift check is acceptable if the results are within 3% of the span value. These checks are performed before and after each test run.




# 3A Sampling System




# 7E Sampling System




# 10 Sampling System



# 25A Sampling System



## Location of Sampling Points



| Location       | Accutherm Outlet |
|----------------|------------------|
| Upstream       | 180.0 Inches     |
| Downstream     | 240 Inches       |
| Stack Diameter | 24 Inches        |
| Sample Point # |                  |
| 1              | 0.8 Inches       |
| 2              | 2.5              |
| 3              | 4.7              |
| 4              | 7.8              |
| 5              | 16.2             |
| 6              | 19.3             |
| 7              | 21.5             |
| 8              | 23.2             |

# CALCULATIONS

## Outlet

|                                                                             | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                    |
|-----------------------------------------------------------------------------|---------------|---------------|---------------|---|----------------------------------------------------|
| 1. Vm (std)                                                                 | 43.07         | 42.45         | 42.75         | = | $\frac{VM * 17.64 * \frac{PBAR + 13.6}{Tm} * Y}{}$ |
| Vm (std) = Volume of gas collected, corrected to standard conditions, cuft. |               |               |               | = | <u>RUN #1</u><br>43.07                             |
|                                                                             |               |               |               | = | <u>RUN #2</u><br>42.45                             |
|                                                                             |               |               |               | = | <u>RUN #3</u><br>42.75                             |
| Vm = Volume of gas sampled at meter box, cuft.                              |               |               |               | = | 45.02                                              |
| 17.64 = Standard temperature, 528 Rankine / std pressure, 29.92.            |               |               |               | = | 17.64                                              |
| Tm = Average dry gas meter temperature, + 460 Rankine.                      |               |               |               | = | 531.04167                                          |
| Pbar = Barometric pressure, inches of mercury (Hg)                          |               |               |               | = | 28.64                                              |
| ^H = Average pressure differential across orifice.                          |               |               |               | = | 2                                                  |
| 13.6 = Specific gravity of mercury.                                         |               |               |               | = | 13.6                                               |
| Y = Calibration factor of meter box.                                        |               |               |               | = | 1.0004                                             |

|                                                                    | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                             |
|--------------------------------------------------------------------|---------------|---------------|---------------|---|-------------------------------------------------------------|
| 2. Vw (std)                                                        | 2.43          | 2.95          | 2.80          | = | $Vlc * \frac{P H20}{Mh20} * \frac{R Tstd}{Pstd} = K2 * Vlc$ |
| Vlc = Volume of water and silica collected.                        |               |               |               | = | <u>RUN #1</u><br>51.5                                       |
|                                                                    |               |               |               | = | <u>RUN #2</u><br>62.5                                       |
|                                                                    |               |               |               | = | <u>RUN #3</u><br>59.4                                       |
| P H20 = Density of water, 0.002201 lb/ml.                          |               |               |               | = | 0.002201                                                    |
| M H20 = Molecular weight of water, 18.01 lb/lb-mole.               |               |               |               | = | 18.01                                                       |
| R = Ideal gas constant, 21.85 in. hg - ft <sup>3</sup> /R-lb-mole. |               |               |               | = | 21.85                                                       |
| Tstd = Standard absolute temperature, 528 R.                       |               |               |               | = | 528                                                         |
| Pstd = Standard absolute pressure, 29.92 in. Hg.                   |               |               |               | = | 29.92                                                       |
| K2 = 0.0471 ft <sup>3</sup> / ml.                                  |               |               |               | = | 0.0471                                                      |

|                                                         | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                     |
|---------------------------------------------------------|---------------|---------------|---------------|---|-------------------------------------|
| 3. Bws                                                  | 0.05334       | 0.06487       | 0.06145       | = | $\frac{Vw(std)}{Vm(std) + Vw(std)}$ |
| Bws = Water vapor in the gas stream, proportion.        |               |               |               | = | <u>RUN #1</u><br>0.05334            |
|                                                         |               |               |               | = | <u>RUN #2</u><br>0.06487            |
|                                                         |               |               |               | = | <u>RUN #3</u><br>0.06145            |
| Vw(std) = Volume of water vapor in the gas sample, scf. |               |               |               | = | 2.43                                |
|                                                         |               |               |               | = | 2.95                                |
|                                                         |               |               |               | = | 2.80                                |
| Vm(std) = Volume of gas sampled at meter box, scf.      |               |               |               | = | 43.07                               |
|                                                         |               |               |               | = | 42.45                               |
|                                                         |               |               |               | = | 42.75                               |

|    |           | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                  |
|----|-----------|---------------|---------------|---------------|---|------------------------------------------------------------------|
| 4. | <b>Md</b> | 29.086694     | 29.056811     | 29.102617     | = | $\frac{0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2) + \%CO}{100}$ |

|      |                                                | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|------|------------------------------------------------|---------------|---------------|---------------|
| Md   | = Dry molecular weight, lb / lb-mole.          | 29.09         | 29.06         | 29.10         |
| 0.44 | = Molecular weight of CO2 divided by 100.      | 0.44          | 0.44          | 0.44          |
| 0.32 | = Molecular weight of O2 divided by 100.       | 0.32          | 0.32          | 0.32          |
| 0.28 | = Molecular weight of N2 or CO divided by 100. | 0.28          | 0.28          | 0.28          |

CO2, O2, N2, and CO are in percent by volume, dry basis.

|    |           | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                   |
|----|-----------|---------------|---------------|---------------|---|-----------------------------------|
| 5. | <b>Ms</b> | 28.50         | 28.34         | 28.42         | = | $Md * (1-Bws) + M_{H_2O} * (Bws)$ |

|       |                                                     | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-------|-----------------------------------------------------|---------------|---------------|---------------|
| Ms    | = Molecular weight of gas , wet basis, lb /lb-mole. | 28.50         | 28.34         | 28.42         |
| M H2O | = Molecular weight of water, 18 lb / lb-mole.       | 18            | 18            | 18            |

|    |           | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                  |
|----|-----------|---------------|---------------|---------------|---|------------------------------------------------------------------|
| 6. | <b>Vs</b> | 12.70         | 13.02         | 13.18         | = | $85.49 * C_p \sqrt{\Delta p} \sqrt{\frac{T_s + 460}{P_s * M_s}}$ |

|       |                                                     | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-------|-----------------------------------------------------|---------------|---------------|---------------|
| Vs    | = Average stack gas velocity, ft / sec.             | 12.70         | 13.02         | 13.18         |
| 85.49 | = Pitot tube constant, ft / sec.                    | 85.49         | 85.49         | 85.49         |
| Cp    | = Pitot tube coefficient, dimensionless.            | 0.84          | 0.84          | 0.84          |
| ΔP    | = Velocity head of stack gas, avg. sq rt.           | 0.13704       | 0.13847       | 0.13895       |
| Ts    | = Temperature of stack gas, + 460 (Rankine).        | 1359.625      | 1393          | 1420          |
| Ps    | = Absolute stack gas pressure, barometric + static. | 28.65         | 28.65         | 28.65         |
| Ms    | = Molecular weight of stack gas, wet basis.         | 28.50         | 28.34         | 28.42         |

|    |             | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                        |
|----|-------------|---------------|---------------|---------------|---|------------------------|
| 7. | <b>ACFM</b> | 2393.78       | 2454.40       | 2483.86       | = | $Stack Area * 60 * Vs$ |

|    |                                         | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|----|-----------------------------------------|---------------|---------------|---------------|
| Vs | = Average stack gas velocity, ft / sec. | 12.70         | 13.02         | 13.18         |

|      |      | <u>RUN #1</u>                                     | <u>RUN #2</u> | <u>RUN #3</u> |               |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
|------|------|---------------------------------------------------|---------------|---------------|---------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|---------------|---------------|---------------|------|------|------|-----|-----------|-----------|-----------|---|------|------|------|------|-----|-----|-----|------|-------|-------|-------|----|----------|------|------|----|-------|-------|-------|----|-------|-------|-------|
| 8    | SCFH | 50567                                             | 50007         | 49802         | =             | <div><div><math display="block">3600 * ( 1 - Bws ) * Vs * A * \frac{Tstd}{Ts} * \frac{Ps}{Pstd}</math></div><table><tr><th></th><th><u>RUN #1</u></th><th><u>RUN #2</u></th><th><u>RUN #3</u></th></tr><tr><td>3600</td><td>3600</td><td>3600</td></tr><tr><td>Bws</td><td>0.0533415</td><td>0.0648732</td><td>0.0614459</td></tr><tr><td>A</td><td>3.14</td><td>3.14</td><td>3.14</td></tr><tr><td>Tstd</td><td>528</td><td>528</td><td>528</td></tr><tr><td>Pstd</td><td>29.92</td><td>29.92</td><td>29.92</td></tr><tr><td>Ts</td><td>1359.625</td><td>1393</td><td>1420</td></tr><tr><td>Ps</td><td>28.64</td><td>28.64</td><td>28.64</td></tr><tr><td>Vs</td><td>12.70</td><td>13.02</td><td>13.18</td></tr></table></div> |  | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> | 3600 | 3600 | 3600 | Bws | 0.0533415 | 0.0648732 | 0.0614459 | A | 3.14 | 3.14 | 3.14 | Tstd | 528 | 528 | 528 | Pstd | 29.92 | 29.92 | 29.92 | Ts | 1359.625 | 1393 | 1420 | Ps | 28.64 | 28.64 | 28.64 | Vs | 12.70 | 13.02 | 13.18 |
|      |      |                                                   | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
|      |      | 3600                                              | 3600          | 3600          |               |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
|      |      | Bws                                               | 0.0533415     | 0.0648732     | 0.0614459     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
|      |      | A                                                 | 3.14          | 3.14          | 3.14          |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
|      |      | Tstd                                              | 528           | 528           | 528           |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
|      |      | Pstd                                              | 29.92         | 29.92         | 29.92         |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
|      |      | Ts                                                | 1359.625      | 1393          | 1420          |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
|      |      | Ps                                                | 28.64         | 28.64         | 28.64         |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
|      |      | Vs                                                | 12.70         | 13.02         | 13.18         |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
| 3600 | =    | Seconds per hour.                                 | =             | 3600          | 3600          | 3600                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
| Bws  | =    | Water vapor in the gas stream, proportion.        | =             | 0.0533415     | 0.0648732     | 0.0614459                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
| A    | =    | Area of stack in sq ft.                           | =             | 3.14          | 3.14          | 3.14                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
| Tstd | =    | Standard absolute temperature, 528 R.             | =             | 528           | 528           | 528                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
| Pstd | =    | Standard absolute pressure, 29.92 in. Hg.         | =             | 29.92         | 29.92         | 29.92                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
| Ts   | =    | Temperature of stack gas, + 460 (Rankine).        |               | 1359.625      | 1393          | 1420                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
| Ps   | =    | Absolute stack gas pressure, barometric + static. |               | 28.64         | 28.64         | 28.64                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |
| Vs   | =    | Average stack gas velocity, ft / sec.             |               | 12.70         | 13.02         | 13.18                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |  |               |               |               |      |      |      |     |           |           |           |   |      |      |      |      |     |     |     |      |       |       |       |    |          |      |      |    |       |       |       |    |       |       |       |

# CALCULATIONS

| <u>VOC</u> |                           | <u>RUN #1</u> | <u>RUN #2</u>                                    | <u>RUN #3</u> |   |                                                                        |
|------------|---------------------------|---------------|--------------------------------------------------|---------------|---|------------------------------------------------------------------------|
| 1.         | <b>Lbs/Hr<br/>Propane</b> | 0.00495       | 0.00734                                          | 0.00437       | = | 0.11443 * SCFH * PPM * 10 <sup>-6</sup>                                |
|            | scfh                      | =             | Standard stack volumetric flow rate.             |               |   | = <u>RUN #1</u><br>50567 <u>RUN #2</u><br>50007 <u>RUN #3</u><br>49802 |
|            | PPM                       | =             | PPM                                              |               |   | = 0.8556412    1.2832484    0.7671375                                  |
| 2.         | <b>Lbs/Hr<br/>Carbon</b>  | 0.00405       | 0.00600                                          | 0.00357       | = | 0.031182 * SCFH * PPM * 3 * 10 <sup>-6</sup>                           |
|            | scfh                      | =             | Standard stack volumetric flow rate.             |               |   | = <u>RUN #1</u><br>50567 <u>RUN #2</u><br>50007 <u>RUN #3</u><br>49802 |
|            | PPM                       | =             | PPM                                              |               |   | = 0.8556412    1.2832484    0.7671375                                  |
|            | 3                         | =             | Carbon equivalent correction factor for propane. |               |   | = 3                    3                    3                          |

# CALCULATIONS

## NOX

|    |           | <u>RUN #1</u> | <u>RUN #2</u>                                                                                  | <u>RUN #3</u> |   |                                                |                        |                        |                        |
|----|-----------|---------------|------------------------------------------------------------------------------------------------|---------------|---|------------------------------------------------|------------------------|------------------------|------------------------|
| 1. | Lbs/Hr    | 0.14956       | 0.14341                                                                                        | 0.14333       | = | <div>1.194 * SCFH * PPM * 10^- 7</div>         |                        |                        |                        |
|    | scfh      | =             | Standard stack volumetric flow rate.                                                           |               |   | =                                              | <u>RUN #1</u><br>50567 | <u>RUN #2</u><br>50007 | <u>RUN #3</u><br>49802 |
|    | PPM       | =             | PPM corrected                                                                                  |               |   | =                                              | 24.77                  | 24.02                  | 24.10                  |
|    |           | <u>RUN #1</u> | <u>RUN #2</u>                                                                                  | <u>RUN #3</u> |   |                                                |                        |                        |                        |
| 2  | PPM Corr. | 24.77         | 24.02                                                                                          | 24.10         | = | $C_{gas} = (C - C_o) \frac{C_{ma}}{C_m - C_o}$ |                        |                        |                        |
|    | Co        | =             | Average of initial and final system calibration bias check responses for the zero gas, ppm.    |               |   | =                                              | <u>RUN #1</u><br>0.11  | <u>RUN #2</u><br>0.16  | <u>RUN #3</u><br>0.135 |
|    | C         | =             | Effluent gas concentration, dry basis, ppm.                                                    |               |   | =                                              | 24.73                  | 24.35                  | 24.2                   |
|    | Cm        | =             | Average of initial and final system calibration bias check responses for the upscale gas, ppm. |               |   | =                                              | 25.255                 | 25.64                  | 25.395                 |
|    | Cma       | =             | Actual concentration of the upscale calibration gas, ppm.                                      |               |   | =                                              | 25.3                   | 25.3                   | 25.3                   |

# CALCULATIONS

## CO

1

|               | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                                                      |
|---------------|---------------|---------------|---------------|---|----------------------------------------------------------------------------------------------------------------------|
| <b>Lbs/Hr</b> | 0.00          | 0.00          | 0.00          | = | <div style="border: 1px solid black; padding: 5px; display: inline-block;">.726 * SCFH * PPM * 10<sup>-7</sup></div> |

|      |   |                                      |   |               |               |               |
|------|---|--------------------------------------|---|---------------|---------------|---------------|
| scfh | = | Standard stack volumetric flow rate. | = | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|      |   |                                      |   | 50566.76      | 50007         | 49802         |
| PPM  | = | PPM                                  | = | 0.07          | 0.17          | 0.20          |

2

|                  | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                |
|------------------|---------------|---------------|---------------|---|------------------------------------------------|
| <b>PPM Corr.</b> | 0.0665        | 0.1662        | 0.2           | = | $C_{gas} = (C - C_o) \frac{C_{ma}}{C_m - C_o}$ |

|     |   |                                                                                               |   |               |               |               |
|-----|---|-----------------------------------------------------------------------------------------------|---|---------------|---------------|---------------|
| Co  | = | Average of initial and final system calibration bias check responses for the zero gas, ppm    | = | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|     |   |                                                                                               |   | -0.055        | -0.075        | -0.01         |
| C   | = | Effluent gas concentration, dry basis, ppm.                                                   | = | 0.01          | 0.09          | 0.19          |
| Cm  | = | Average of initial and final system calibration bias check responses for the upscale gas, ppm | = | 14.04         | 14.24         | 14.41         |
| Cma | = | Actual concentration of the upscale calibration gas, ppm.                                     | = | 14.42         | 14.42         | 14.42         |

# CALCULATIONS

O2

|          |                | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                |
|----------|----------------|---------------|---------------|---------------|---|------------------------------------------------|
| <b>1</b> | <b>% Corr.</b> | 14.21         | 14.76         | 14.27         | = | $C_{gas} = (C - C_o) \frac{C_{ma}}{C_m - C_o}$ |

|     |   |                                                                                      |   |  |  | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-----|---|--------------------------------------------------------------------------------------|---|--|--|---------------|---------------|---------------|
| Co  | = | Average of initial and final system calibration check responses for the zero gas     | = |  |  | 0.14          | 0.27          | 0.26          |
| C   | = | Effluent gas concentration, dry basis,                                               | = |  |  | 14.29         | 14.65         | 14.15         |
| Cm  | = | Average of initial and final system calibration bias check responses for the upscale | = |  |  | 10.095        | 10.015        | 9.995         |
| Cma | = | Actual concentration of the upscale calibration gas, ppm.                            | = |  |  | 10.00         | 10.00         | 10.00         |

# CALCULATIONS

## CO2

|   |         | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                      |
|---|---------|---------------|---------------|---------------|---|------------------------------------------------------|
| 1 | % Corr. | 3.24          | 2.92          | 3.32          | = | $C_{gas} = \frac{(C - C_o) \cdot C_{ma}}{C_m - C_o}$ |

|     |   |                                                                                  |   | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-----|---|----------------------------------------------------------------------------------|---|---------------|---------------|---------------|
| Co  | = | Average of initial and final system calibration check responses for the zero gas | = | -0.005        | 0.02          | 0.025         |
| C   | = | Effluent gas concentration, dry basis,                                           | = | 3.26          | 2.93          | 3.31          |
| Cm  | = | Average of initial and final system calibration check responses for the upscale  | = | 9.795         | 9.72          | 9.63          |
| Cma | = | Actual concentration of the upscale calibration gas, ppm.                        | = | 9.72          | 9.72          | 9.72          |

# **Appendix #1**

## **Test Data**

**Custom Stack Analysis, LLC.**  
**Pitot Traverse Data Sheet for Cyclonics**

Plant Meggitt Aircraft Braking

Date 4/15/2021

Location P039 Accutherm Outlet

By Jim G, Brian L, Dylan G

| Point # | Angle |
|---------|-------|
| 1       | 3     |
| 2       | 3     |
| 3       | 1     |
| 4       | 0     |
| 5       | 2     |
| 6       | 0     |
| 7       | 1     |
| 8       | 1     |
| B-1     | 2     |
| 2       | 1     |
| 3       | 3     |
| 4       | 4     |
| 5       | 2     |
| 6       | 2     |
| 7       | 1     |
| 8       | 0     |
| Avg     | 2     |

# Custom Stack Analysis, LLC.

## Pitot Traverse Data Sheet

Plant Meggitt Aircraft Braking Systems Corporation

Date 4/15/2021

Location P039 Accutherm Outlet

By Brian L

| Run No. | Pre 1     |     | Post 1    |     | Post 2    |     | Post 3    |      |
|---------|-----------|-----|-----------|-----|-----------|-----|-----------|------|
| Point # | Pitot Δ P | °F  | Pitot Δ P | °F  | Pitot Δ P | °F  | Pitot Δ P | °F   |
| A-1     | 0.022     | 878 | 0.023     | 892 | 0.019     | 921 | 0.022     | 942  |
| 2       | 0.024     | 881 | 0.023     | 895 | 0.021     | 926 | 0.025     | 948  |
| 3       | 0.019     | 882 | 0.020     | 908 | 0.022     | 935 | 0.021     | 953  |
| 4       | 0.025     | 883 | 0.023     | 915 | 0.022     | 940 | 0.024     | 958  |
| 5       | 0.018     | 884 | 0.019     | 921 | 0.020     | 947 | 0.020     | 969  |
| 6       | 0.016     | 882 | 0.018     | 926 | 0.018     | 951 | 0.017     | 974  |
| 7       | 0.015     | 880 | 0.017     | 931 | 0.016     | 958 | 0.016     | 979  |
| 8       | 0.012     | 881 | 0.015     | 933 | 0.014     | 966 | 0.014     | 985  |
| B-1     | 0.018     | 865 | 0.018     | 902 | 0.021     | 932 | 0.019     | 960  |
| 2       | 0.020     | 867 | 0.019     | 907 | 0.024     | 937 | 0.020     | 967  |
| 3       | 0.022     | 872 | 0.020     | 913 | 0.020     | 943 | 0.022     | 973  |
| 4       | 0.021     | 874 | 0.022     | 918 | 0.024     | 950 | 0.022     | 981  |
| 5       | 0.018     | 880 | 0.019     | 924 | 0.021     | 954 | 0.019     | 989  |
| 6       | 0.017     | 882 | 0.019     | 930 | 0.018     | 961 | 0.020     | 994  |
| 7       | 0.016     | 883 | 0.018     | 934 | 0.016     | 965 | 0.017     | 998  |
| 8       | 0.014     | 884 | 0.015     | 937 | 0.013     | 968 | 0.015     | 1002 |

|         |        |        |        |        |        |        |
|---------|--------|--------|--------|--------|--------|--------|
|         | Run #1 |        | Run #2 |        | Run #3 |        |
|         | 0.14   | 899.63 | 0.14   | 932.50 | 0.14   | 960.19 |
|         | 0.136  | 881    | 0.138  | 918    | 0.138  | 947    |
| Static: | 0.186  |        | 0.189  |        | 0.189  |        |
|         |        |        |        |        |        | 0.192  |

# TEST DATA

|              |                                                |
|--------------|------------------------------------------------|
| COMPANY NAME | Meggitt Aircraft Braking Systems Corporation - |
| ADDRESS      | 1204 Massillon Road                            |
| CITY         | Akron                                          |
| STATE        | OH                                             |
| ZIP          | 44306                                          |
| TEST METHODS | Methods 1-4, 3A, 7E, 10 and 25A                |
| CREW MEMBERS | Jim G, Brian L, Dylan G                        |
| LOCATION     | Outlet                                         |
| SOURCE       | P039 Accutherm                                 |
| CONTROL      |                                                |

|                     | RUN #1    | RUN #2    | RUN #3    |
|---------------------|-----------|-----------|-----------|
| DATE                | 4/15/2021 | 4/15/2021 | 4/15/2021 |
| RUN LENGTH (min)    | 60        | 60        | 60        |
| VOLUME (cubic feet) | 45.022    | 44.605    | 45.093    |
| Y FACTOR            | 1.0004    | 1.0004    | 1.0004    |
| BAROMETRIC          | 28.64     | 28.64     | 28.64     |
| METER TEMP. (R)     | 531.04    | 533.75    | 535.79    |
| STACK TEMP. (R)     | 1359.63   | 1392.50   | 1420.19   |
| AVERAGE ^P          | 0.137     | 0.138     | 0.139     |
| AVERAGE ^H          | 2.00      | 2.00      | 2.00      |
| IMPINGER VOLUME     | 51.50     | 62.50     | 59.40     |
|                     |           |           |           |
| PITOT COEF.         | 0.84      | 0.84      | 0.84      |
| STATIC PRESSURE     | 0.188     | 0.189     | 0.191     |
| STACK AREA          | 3.14      | 3.14      | 3.14      |
|                     |           |           |           |
| CARBON DIOXIDE      | 3.24      | 2.92      | 3.32      |
| OXYGEN              | 14.21     | 14.76     | 14.27     |
| NITROGEN            | 82.55     | 82.33     | 82.41     |

# TEST RESULTS

P039 Accutherm Outlet  
4/15/2021

|             | RUN #1   | RUN #2   | RUN #3   |
|-------------|----------|----------|----------|
| VM (std)    | 43.069   | 42.454   | 42.755   |
| VW (std)    | 2.427    | 2.945    | 2.799    |
| BWS         | 0.053    | 0.065    | 0.061    |
| MD          | 29.087   | 29.057   | 29.103   |
| MS          | 28.495   | 28.340   | 28.420   |
| VS (ft/sec) | 12.699   | 13.021   | 13.177   |
|             |          |          |          |
| SCFH        | 50566.76 | 50006.76 | 49802.36 |
| ACFM        | 2393.78  | 2454.40  | 2483.86  |
| DCFM        | 842.78   | 833.45   | 830.04   |

Vm (std) = Volume of gas sampled at standard conditions.

Vw (std) = Volume of water vapor collected at standard conditions.

Bws = Stack moisture content.

Md = Determination of dry molecular weight of stack gas.

Ms = Determination of stack gas molecular weight.

Vs = Average gas stack velocity. (ft/sec.)

ACFM = Actual cubic feet per minute of gas velocity.

DCFM = Dry standard cubic feet per minute of gas velocity.

# TEST RESULTS

P039 Accutherm Outlet

4/15/2021

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <b>CEM MONITORING</b> |        |        |        |
| VOC (lbs/hr propane)  | 0.005  | 0.007  | 0.004  |
| VOC (lbs/hr carbon)   | 0.004  | 0.006  | 0.004  |
| NOX (lbs/hr)          | 0.150  | 0.143  | 0.143  |
| CO (lbs/hr)           | 0.000  | 0.001  | 0.001  |
| O2 %                  | 14.214 | 14.756 | 14.268 |
| CO2 %                 | 3.238  | 2.916  | 3.324  |

# TEST DATA

P039 Accutherm Outlet

4/15/2021

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <b>CEM MONITORING</b> |        |        |        |
| VOC (ppm)             | 0.86   | 1.28   | 0.77   |
| NOX (ppm)             | 24.73  | 24.35  | 24.20  |
| CO (ppm)              | 0.01   | 0.09   | 0.19   |
| O2 (%)                | 14.29  | 14.65  | 14.15  |
| CO2 (%)               | 3.26   | 2.93   | 3.31   |

|                       |       |       |       |
|-----------------------|-------|-------|-------|
| <b>NOX CAL. CORR.</b> |       |       |       |
| INITIAL ZERO          | 0.04  | 0.18  | 0.14  |
| INITIAL UPSCALE       | 25.15 | 25.36 | 25.92 |
| FINAL ZERO            | 0.18  | 0.14  | 0.13  |
| FINAL UPSCALE         | 25.36 | 25.92 | 24.87 |
| ACTUAL UPSCALE        | 25.30 | 25.3  | 25.3  |
| NOX (ppm corrected)   | 24.77 | 24.02 | 24.10 |

|                      |       |       |       |
|----------------------|-------|-------|-------|
| <b>CO CAL. CORR.</b> |       |       |       |
| INITIAL ZERO         | 0.02  | -0.13 | -0.02 |
| INITIAL UPSCALE      | 14.02 | 14.06 | 14.42 |
| FINAL ZERO           | -0.13 | -0.02 | 0     |
| FINAL UPSCALE        | 14.06 | 14.42 | 14.4  |
| ACTUAL UPSCALE       | 14.42 | 14.42 | 14.42 |
| CO (ppm corrected)   | 0.07  | 0.17  | 0.20  |

|                     |       |       |       |
|---------------------|-------|-------|-------|
| <b>O2 CAL CORR.</b> |       |       |       |
| INITIAL ZERO        | 0.02  | 0.26  | 0.28  |
| INITIAL UPSCALE     | 10.07 | 10.12 | 9.91  |
| FINAL ZERO          | 0.26  | 0.28  | 0.24  |
| FINAL UPSCALE       | 10.12 | 9.91  | 10.08 |
| ACTUAL UPSCALE      | 10.00 | 10    | 10    |
| O2 (% corrected)    | 14.21 | 14.76 | 14.27 |

|                      |       |      |      |
|----------------------|-------|------|------|
| <b>CO2 CAL CORR.</b> |       |      |      |
| INITIAL ZERO         | -0.04 | 0.03 | 0.01 |
| INITIAL UPSCALE      | 9.79  | 9.8  | 9.64 |
| FINAL ZERO           | 0.03  | 0.01 | 0.04 |
| FINAL UPSCALE        | 9.80  | 9.64 | 9.62 |
| ACTUAL UPSCALE       | 9.72  | 9.72 | 9.72 |
| CO2 (% corrected)    | 3.24  | 2.92 | 3.32 |

# Custom Stack Analysis, L.L.C.

## Method 4

Plant: eggitt Aircraft Braking Systems Corporation Date : 4/15/2021

|                |       |                        |        |
|----------------|-------|------------------------|--------|
|                |       | Meter Box              |        |
| Barometer (Pg) | 28.64 | ID:                    | 1      |
| Ambient Temp   | 50    | Y                      | 1.0004 |
|                |       | $\Delta H$             | 1.986  |
|                |       | $\Delta H$ Set Point : | 2.0    |
|                | Time  | Run Time               |        |
| Start:         | 13:45 | 60                     |        |
| Stop:          | 14:45 |                        |        |

### Run #1

| Cold Box #         |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| <b>11</b>          | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| Time               |              |            |       |           |         |
| <b>0</b>           | 170.240      | 68         | 64.0  | 63        | 5       |
| <b>5</b>           | 174.012      | 71         | 66.0  | 56        | 5       |
| <b>10</b>          | 177.793      | 72         | 66.0  | 54        | 5       |
| <b>15</b>          | 181.546      | 74         | 67.0  | 53        | 5       |
| <b>20</b>          | 185.323      | 74         | 68.0  | 57        | 5       |
| <b>25</b>          | 189.058      | 75         | 68.0  | 57        | 5       |
| <b>30</b>          | 192.762      | 75         | 69.0  | 58        | 5       |
| <b>35</b>          | 196.477      | 75         | 69.0  | 60        | 5       |
| <b>40</b>          | 200.211      | 75         | 70.0  | 61        | 5       |
| <b>45</b>          | 203.991      | 76         | 70.0  | 62        | 5       |
| <b>50</b>          | 207.748      | 76         | 70.0  | 62        | 5       |
| <b>55</b>          | 211.510      | 76         | 71.0  | 63        | 5       |
| <b>60</b>          | 215.262      |            |       |           |         |
| <b>Vm</b>          | 45.022       |            |       |           |         |
|                    | AVG:         | 71         |       | 58.8      | 5.0     |
| <b>Leak Rate @</b> | 9.0          | " Hg =     | 0.000 |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 15:27 | 60       |
| Stop:  | 16:27 |          |

## Run #2

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>4</b>           | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 215.689      | 73         | 70    | 59        | 6       |
| <b>5</b>           | 219.412      | 74         | 71    | 52        | 6       |
| <b>10</b>          | 223.171      | 75         | 72    | 52        | 6       |
| <b>15</b>          | 226.841      | 75         | 71    | 52        | 6       |
| <b>20</b>          | 230.576      | 77         | 71    | 53        | 6       |
| <b>25</b>          | 234.243      | 76         | 71    | 55        | 6       |
| <b>30</b>          | 237.930      | 76         | 72    | 57        | 6       |
| <b>35</b>          | 241.628      | 77         | 70    | 56        | 6       |
| <b>40</b>          | 245.371      | 77         | 72    | 58        | 6       |
| <b>45</b>          | 249.025      | 77         | 72    | 57        | 6       |
| <b>50</b>          | 252.831      | 77         | 72    | 57        | 6       |
| <b>55</b>          | 256.558      | 77         | 75    | 58        | 6       |
| <b>60</b>          | 260.294      |            |       |           |         |
| <b>Vm</b>          | 44.605       |            |       |           |         |
|                    | AVG:         | 74         |       | 55.5      | 6.0     |
| <b>Leak Rate @</b> | 10.5         | " Hg =     | 0.004 |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 17:04 | 60       |
| Stop:  | 18:04 |          |

### Run #3

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>6</b>           | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 264.046      | 74         | 72    | 58        | 5       |
| <b>5</b>           | 267.823      | 76         | 73    | 53        | 5       |
| <b>10</b>          | 271.548      | 77         | 73    | 53        | 5       |
| <b>15</b>          | 275.332      | 78         | 73    | 54        | 5       |
| <b>20</b>          | 279.127      | 78         | 73    | 58        | 5       |
| <b>25</b>          | 282.879      | 78         | 74    | 58        | 5       |
| <b>30</b>          | 286.626      | 78         | 74    | 57        | 5       |
| <b>35</b>          | 290.390      | 79         | 74    | 57        | 5       |
| <b>40</b>          | 294.139      | 79         | 74    | 58        | 5       |
| <b>45</b>          | 297.893      | 79         | 74    | 56        | 5       |
| <b>50</b>          | 301.663      | 79         | 75    | 53        | 5       |
| <b>55</b>          | 305.358      | 80         | 75    | 54        | 5       |
| <b>60</b>          | 309.139      |            |       |           |         |
| <b>Vm</b>          | 45.093       |            |       |           |         |
|                    | AVG:         | 76         |       | 55.8      | 5.0     |
| <b>Leak Rate @</b> | 10.0         | " Hg =     | 0.000 |           |         |

# **Appendix #2**

## **Laboratory Data**

Lab Data Sheet For: Meggitt Aircraft Braking Systems Corporation - P039 Accutherm Outlet

By: Brian L

Moisture Weights

Moisture

| RUN # 1 |  | Box ID | grams   | grams | grams | grams | grams | grams |
|---------|--|--------|---------|-------|-------|-------|-------|-------|
|         |  |        | 1       | 2     | 3     | 4     | 5     | 6     |
|         |  |        | 11      | 812.6 | 563.0 | 537.8 |       |       |
|         |  |        | 11      | 726.3 | 610.3 | 536.6 |       |       |
|         |  |        |         | 86.3  | -47.3 | 1.2   | 0.0   | 0.0   |
|         |  |        | Reagent | H2O   | H2O   |       |       |       |
|         |  |        | mLs     | 100.0 | 100.0 |       |       |       |

|                  |       |                  |               |                       |
|------------------|-------|------------------|---------------|-----------------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>40.2 | grams<br>Total = 51.5 |
|------------------|-------|------------------|---------------|-----------------------|

| RUN # 2 |  | Box ID | grams   | grams | grams | grams | grams | grams |
|---------|--|--------|---------|-------|-------|-------|-------|-------|
|         |  |        | 1       | 2     | 3     | 4     | 5     | 6     |
|         |  |        | 4       | 677.5 | 755.0 | 626.3 |       |       |
|         |  |        | 4       | 628.1 | 752.7 | 625.2 |       |       |
|         |  |        |         | 49.4  | 2.3   | 1.1   | 0.0   | 0.0   |
|         |  |        | Reagent | H2O   | H2O   |       |       |       |
|         |  |        | mLs     | 100.0 | 100.0 |       |       |       |

|                  |       |                  |               |                       |
|------------------|-------|------------------|---------------|-----------------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>52.8 | grams<br>Total = 62.5 |
|------------------|-------|------------------|---------------|-----------------------|

| RUN # 3 |  | Box ID | grams   | grams | grams | grams | grams | grams |
|---------|--|--------|---------|-------|-------|-------|-------|-------|
|         |  |        | 1       | 2     | 3     | 4     | 5     | 6     |
|         |  |        | 6       | 792.8 | 655.7 | 488.4 |       |       |
|         |  |        | 6       | 750.5 | 650.4 | 487.0 |       |       |
|         |  |        |         | 42.3  | 5.3   | 1.4   | 0.0   | 0.0   |
|         |  |        | Reagent | H2O   | H2O   |       |       |       |
|         |  |        | mLs     | 100.0 | 100.0 |       |       |       |

|                  |       |                  |               |                       |
|------------------|-------|------------------|---------------|-----------------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>49.0 | grams<br>Total = 59.4 |
|------------------|-------|------------------|---------------|-----------------------|

Scale Serial # 1203240794

# **Appendix #3**

## **Calibration Data**



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 3415-10347847

Traceable® Certificate of Calibration for Digital Calipers

Manufactured for and distributed by: Control Company 12554 Galveston Rd B230, Webster, TX 77598

Instrument Identification:

Model: 3415,

S/N: 192125551

Manufacturer: Control Company

Standards/Equipment:

| Description    | Serial Number | Due Date    | NIST Traceable Reference |
|----------------|---------------|-------------|--------------------------|
| Gage Block Set | 99146223      | 06 Dec 2019 | 1000434942               |

Certificate Information:

Technician: 57

Procedure: CAL-05

Cal Date: 23 Apr 2019

Cal Due Date: 23 Apr 2021

Test Conditions: 57.01%RH 23.96°C 1018mBar

Calibration Data: (New Instrument)

| Unit(s)   | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U      | TUR    |
|-----------|---------|----------|--------|---------|---------|--------|-------|-------|---------|--------|
| in        | N.A.    | N.A.     |        | 0.1000  | 0.0995  | Y      | 0.099 | 0.101 | 0.0003  | 3.33:1 |
| in        | N.A.    | N.A.     |        | 2.0000  | 1.9985  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in        | N.A.    | N.A.     |        | 4.0000  | 3.998   | Y      | 3.996 | 4.004 | 0.0004  | >4:1   |
| in        | N.A.    | N.A.     |        | 6.0000  | 5.997   | Y      | 5.994 | 6.006 | 0.0005  | >4:1   |
| in depth  | N.A.    | N.A.     |        | 2.0000  | 1.998   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in inside | N.A.    | N.A.     |        | 1.0000  | 0.9995  | Y      | 0.999 | 1.001 | 0.00031 | 3.23:1 |
| in step   | N.A.    | N.A.     |        | 2.0000  | 2.000   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement": (GUM). The uncertainty represents an expanded uncertainty using a coverage factor  $k=2$  to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*  
Nicol Rodriguez, Quality Manager

*Aaron Justice*  
Aaron Justice, Technical Manager

Note:

Maintaining Accuracy:

In our opinion once calibrated your Digital Calipers should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Calipers change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.control3.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (AZLA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2008 Quality Certified by DNV GL, Certificate No. CERT-01805-2008-AQ-HOU-RvA.  
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).

B 22438B



AMERICAN WELDING AND GAS  
1210 GLENDALE-MILFORD  
CINCINNATI, OH 45215  
513-772-8786

|                         |                                   |                       |                  |
|-------------------------|-----------------------------------|-----------------------|------------------|
| Cylinder Number:        | EB0052956                         | Certification Date:   | 07 April 2019    |
| Mixture Grade:          | EPA Protocol Standard Gas Mixture | Expiration Date:      | 08 April 2027    |
| Certificate Number:     | 0889C-01T5-C01                    | Lot Number:           | 0889C-01T5       |
| Cylinder Fill Pressure: | 2015 PSIG                         | Customer Part Number: | T5E 4800001-A1-2 |

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

### Certified Concentrations

| Component      | Concentration | Uncertainty          | Assay Dates |
|----------------|---------------|----------------------|-------------|
| Oxygen         | 10.0%         | +/- 0.10% (absolute) | 4/7/2019    |
| Carbon Dioxide | 9.72%         | +/- 0.04% (absolute) | 4/7/2019    |
| Nitrogen       | Balance       |                      |             |

### Analytical Instrumentation

| Component      | Analytical Principle | Make     | Model | Serial         | MPC Date  |
|----------------|----------------------|----------|-------|----------------|-----------|
| Oxygen         | GC-TCD               | Shimadzu | GC-8A | C10495021497SA | 3/25/2019 |
| Carbon Dioxide | GC-TCD               | Shimadzu | GC-8A | C10495021497SA | 3/27/2019 |

### Reference Standards

| Serial Number | Lot    | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|--------|------------|------|-----------|---------|---------------|-----------------|----------------|
| D885109       | VSL    | 9/14/2023  | PRM  | O2        | N2      | 21.00%        | 0.100           | VSL            |
| FF13624       | 9-D-37 | 3/8/2021   | SRM  | CO2       | N2      | 16.08%        | 0.124           | 2745           |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of  $k=2$  to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. Mixture stability is certified according to maximum certification periods set forth by Table 2-3 of EPA 600/R-12/531 May 2012. The listed expiration date may be extended by special request. The nitrogen used as a component or balance gas as well as the oxygen used in air mixtures meets the requirements set forth in EPA 1085.750. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025:2005

Preparer: Allison Hanover

Reviewer: Abby Helman

Production Laboratory:

Tier 5 Labs, LLC  
5353 W. Southern Ave.  
Indianapolis, IN 46241  
PGVP Vendor ID R12019

B218561



Scott-Gross Co., Inc.  
664 Magnolia Ave.  
Lexington, KY 40505  
(859)231-0225 (888)431-5882

## Certificate of Analysis


Certification Date: 12 January 2017  
Certificate Number: 0097B-02T5-C01  
Mixture Grade: EPA Protocol Standard Gas Mixture  
Lot Number: 0097B-02T5  
Expiration Date: 12 January 2025  
Cylinder Number: EB0049442  
Part Number: T5L EPA2RATAP-14

| Mixture Components | Requested Composition | Certified Composition | U (Expanded Uncertainty, k=2) |
|--------------------|-----------------------|-----------------------|-------------------------------|
| Propane            | 43 ppm                | 47.05 PPM             | +/- 0.12 PPM (absolute)       |
| Air                | Balance               | Balance               |                               |

Cylinder Pressure: 1900 psi – Do not use below 100 psi (0.7 megapascals)  
Production Lab: Tier 5 Labs, LLC, Indianapolis, IN, PGVP Vendor ID R12017  
Procedure Used: EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012  
Analytical Method: C3H8: FTIR  
Multipoint Calibration Date: Propane: 12/29/2016

| Reference Standards |         |            |      |           |         |               |                 |                |
|---------------------|---------|------------|------|-----------|---------|---------------|-----------------|----------------|
| Serial Number       | Lot     | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
| CAL017809           | 83-J-12 | 8/17/2017  | SRM  | C3H8      | Air     | 48.83 PPM     | 0.225           | 1667b          |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025-2005.

  
Jeff Lynn



**LIQUID TECHNOLOGY CORPORATION**  
"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis  
**- EPA PROTOCOL GAS -**

Customer IE Monitoring Instruments (Worthington, OH)  
Date October 06, 2014  
Delivery Receipt DR-53322  
Gas Standard 13.8 ppm Propane/Air - EPA PROTOCOL  
Final Analysis Date October 06, 2014  
Expiration Date October 07, 2022

B21477B

Component Propane  
Balance Gas Air

Analytical Data:  
EPA Protocol, Section No. 2.2, Procedure G-1.

**DO NOT USE BELOW 100 psig**

Reported Concentrations  
**Propane: 13.7 ppm +/- 0.1 ppm**  
**Air: Balance**

Reference Standards:

SRM/GMIS: GMIS  
Cylinder Number: CC-165367  
Concentration: 20.21 ppm Propane (+/- 0.09 ppm)  
Expiration Date: 12/02/18  
NIST Sample Number: NA

GMIS Traceability

SRM-1667b  
XF-00385B  
49.54 ppm Propane (+/- 0.26 ppm)  
07/12/15  
83-I-14

Certification Instrumentation

Component: Propane  
Make/Model: Agilent 7890A  
Serial Number: CN10736166  
Principal of Measurement: GC-FID  
Last Calibration: September 28, 2014

Cylinder Data

Cylinder Serial Number: EB-0051537  
Cylinder Volume: 138 Cubic Feet  
Cylinder Outlet: CGA 590  
Cylinder Pressure: 1950 psig, 70°F

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-12/531.

Certified by:

*Cole Dylewski*  
Cole Dylewski

PGVP Vendor ID: E12014

**"UNMATCHED EXCELLENCE"**

B21925B


**GASES  
& EQUIPMENT**
**INDUSTRIAL  
MEDICAL  
SPECIALTY**

 Scott-Gross Co., Inc.  
 664 Magnolia Ave.  
 Lexington, KY 40505  
 (502) 231-6225 (502) 451-5862

 Cylinder Number: CC444889  
 Mixture Grade: EPA Protocol Standard Gas Mixture  
 Certificate Number: 1147B-02T5-C01  
 Cylinder Pressure: 2015 PSIG

 Certification Date: 28 April 2017  
 Expiration Date: 29 April 2025  
 Lot Number: 1147B-02T5  
 Customer Part Number: T5L EPA2RATAP-19

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

**Certified Concentrations**

| Component | Concentration | Uncertainty            | Assay Dates |
|-----------|---------------|------------------------|-------------|
| Propane   | 24.7 PPM      | +/- 0.2 PPM (absolute) | 4/28/2017   |
| Air       | Balance       |                        |             |

**Analytical Instrumentation**

| Component | Analytical Principle | Make   | Model       | Serial     | MPC Date  |
|-----------|----------------------|--------|-------------|------------|-----------|
| Propane   | FTIR                 | Thermo | Antaris IGS | AW21200-17 | 4/17/2017 |

**Reference Standards**

| Serial Number | Lot        | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|------------|------------|------|-----------|---------|---------------|-----------------|----------------|
| CC459851      | 2186A-01T5 | 11/10/2024 | GMIS | C3H8      | N2      | 247.7 PPM     | 0.411           | 2644a          |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of  $k=2$  to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid.

This calibration meets the requirements of ISO/IEC 17025:2005

Analyst: Allison Hanover

Reviewer: Jeff Lynn

Production Laboratory.

Tier 5 Labs, LLC

5353 W. Southern Ave.

Indianapolis, IN 46241

PGVP Vendor ID R12017



TIER 5 LABS  
6363 W. SOUTHERN AVE.  
INDIANAPOLIS, IN 46241  
317-438-8890

6225736

Cylinder Number: CC514251  
Mixture Grade: EPA Protocol Standard Gas Mixture  
Certificate Number: 1690A-07T5-C01  
Cylinder Fill Pressure: 2015 PSIG

Certification Date: 15 July 2020  
Expiration Date: 15 July 2023  
Lot Number: 1690A-07T5  
Customer Part Number: T5E AM0001-A1-15

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

### Certified Concentrations

| Component      | Concentration | Uncertainty             | Assay Dates          |
|----------------|---------------|-------------------------|----------------------|
| Sulfur Dioxide | 26.7 PPM      | +/- 0.2 PPM (absolute)  | 7/6/2020, 7/15/2020  |
| Nitric Oxide   | 25.3 PPM      | +/- 0.11 PPM (absolute) | 6/23/2020, 6/30/2020 |
| Nitrogen       | Balance       |                         |                      |

### Analytical Instrumentation

| Component      | Analytical Principle | Make   | Model   | Serial     | MPC Date  |
|----------------|----------------------|--------|---------|------------|-----------|
| Sulfur Dioxide | NDIR                 | Horiba | VA-3111 | PC062W1E   | 6/25/2020 |
| Nitric Oxide   | Chemiluminescence    | Thermo | 42iQ    | 1200906802 | 6/25/2020 |

### Reference Standards

| Serial Number | Lot        | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|------------|------------|------|-----------|---------|---------------|-----------------|----------------|
| CC473760      | 3108A-02T5 | 1/23/2027  | GMIS | SO2       | N2      | 102.13 PPM    | 0.798           | 1694a          |
| CC480411      | 1847A-02T5 | 10/4/2025  | GMIS | NO        | N2      | 300.03 PPM    | 0.437           | 2735           |

### Notes

NOx = 25.6 ppm REFERENCE VALUE ONLY

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. The nitrogen used as a component or balance gas as well as the oxygen used in air mixtures meets the requirements set forth in EPA 1065.750. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025:2005

Prepared: Christopher Haas

Reviewer: Allison Martinez

Production Laboratory:  
Tier 5 Labs, LLC  
5353 W. Southern Ave.  
Indianapolis, IN 46241  
PGVP Vendor ID R12020

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

|                  |                          |                     |                  |
|------------------|--------------------------|---------------------|------------------|
| Part Number:     | E02NI99E15A0163          | Reference Number:   | 54-401724343-1   |
| Cylinder Number: | CC265467                 | Cylinder Volume:    | 144.3 Cubic Feet |
| Laboratory:      | 124 - Chicago (SAP) - IL | Cylinder Pressure:  | 2015 PSIG        |
| PGVP Number:     | B12020                   | Valve Outlet:       | 660              |
| Gas Code:        | NO,NOX,BALN              | Certification Date: | Feb 18, 2020     |

**Expiration Date: Feb 18, 2023**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 800/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

### ANALYTICAL RESULTS

| Component    | Requested Concentration | Actual Concentration | Protocol Method | Total Relative Uncertainty | Assay Dates            |
|--------------|-------------------------|----------------------|-----------------|----------------------------|------------------------|
| NOX          | 45.00 PPM               | 46.93 PPM            | G1              | +/- 1.1% NIST Traceable    | 02/10/2020, 02/18/2020 |
| NITRIC OXIDE | 45.00 PPM               | 46.93 PPM            | G1              | +/- 1.1% NIST Traceable    | 02/10/2020, 02/18/2020 |
| NITROGEN     | Balance                 |                      |                 |                            |                        |

### CALIBRATION STANDARDS

| Type | Lot ID     | Cylinder No | Concentration                       | Uncertainty | Expiration Date |
|------|------------|-------------|-------------------------------------|-------------|-----------------|
| NTRM | 16060650   | CC442691    | 50.42 PPM NITRIC OXIDE/NITROGEN     | +/- 0.8%    | Jun 27, 2020    |
| PRM  | 12386      | D685025     | 9.91 PPM NITROGEN DIOXIDE/AIR       | +/- 2.0%    | Feb 20, 2020    |
| GMIS | 7302017104 | CC506604    | 4.426 PPM NITROGEN DIOXIDE/NITROGEN | +/- 2.1%    | Jul 03, 2022    |

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

### ANALYTICAL EQUIPMENT

| Instrument/Make/Model   | Analytical Principle | Last Multipoint Calibration |
|-------------------------|----------------------|-----------------------------|
| Nicolet 6700 AMP0900100 | FTIR                 | Feb 03, 2020                |
| Nicolet 6700 AMP0900100 | FTIR                 | Feb 03, 2020                |

Triad Data Available Upon Request



*[Signature]*

Approved for Release

# **CERTIFICATE OF ANALYSIS**

## **Grade of Product: EPA Protocol**

|                  |                          |                     |                |
|------------------|--------------------------|---------------------|----------------|
| Part Number:     | E02NI99E15A1129          | Reference Number:   | 54-401830766-1 |
| Cylinder Number: | CC267139                 | Cylinder Volume:    | 144.3 CF       |
| Laboratory:      | 124 - Chicago (SAP) - IL | Cylinder Pressure:  | 2015 PSIG      |
| PGVP Number:     | B12020                   | Valve Outlet:       | 350            |
| Gas Code:        | CO,BALN                  | Certification Date: | Jun 11, 2020   |

**Expiration Date: Jun 11, 2028**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

| ANALYTICAL RESULTS |                         |                      |                 |                            |             |
|--------------------|-------------------------|----------------------|-----------------|----------------------------|-------------|
| Component          | Requested Concentration | Actual Concentration | Protocol Method | Total Relative Uncertainty | Assay Dates |
| CARBON MONOXIDE    | 15.00 PPM               | 14.42 PPM            | G1              | +/- 0.4% NIST Traceable    | 06/11/2020  |
| NITROGEN           | Balance                 |                      |                 |                            |             |

| CALIBRATION STANDARDS |        |             |                                    |             |                 |
|-----------------------|--------|-------------|------------------------------------|-------------|-----------------|
| Type                  | Lot ID | Cylinder No | Concentration                      | Uncertainty | Expiration Date |
| NTRM                  | 150102 | KAL004704   | 24.35 PPM CARBON MONOXIDE/NITROGEN | +/- 0.3%    | Sep 04, 2021    |

| ANALYTICAL EQUIPMENT             |                      |                             |
|----------------------------------|----------------------|-----------------------------|
| Instrument/Make/Model            | Analytical Principle | Last Multipoint Calibration |
| (CO-4) Thermo 48i-TLE 1406960657 | NDIR                 | Jun 01, 2020                |

Triad Data Available Upon Request



*Alan Camp*  
Approved for Release

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

|                  |                          |                     |                |
|------------------|--------------------------|---------------------|----------------|
| Part Number:     | E02NI99E15A0497          | Reference Number:   | 54-401871452-1 |
| Cylinder Number: | XC026367B                | Cylinder Volume:    | 144.3 CF       |
| Laboratory:      | 124 - Chicago (SAP) - IL | Cylinder Pressure:  | 2015 PSIG      |
| PGVP Number:     | B12020                   | Valve Outlet:       | 350            |
| Gas Code:        | CO,BALN                  | Certification Date: | Aug 03, 2020   |

**Expiration Date: Aug 03, 2028**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

| ANALYTICAL RESULTS |                         |                      |                 |                            |             |
|--------------------|-------------------------|----------------------|-----------------|----------------------------|-------------|
| Component          | Requested Concentration | Actual Concentration | Protocol Method | Total Relative Uncertainty | Assay Dates |
| CARBON MONOXIDE    | 30.00 PPM               | 29.76 PPM            | G1              | +/- 0.6% NIST Traceable    | 08/03/2020  |
| NITROGEN           | Balance                 |                      |                 |                            |             |

| CALIBRATION STANDARDS |          |             |                                    |             |                 |
|-----------------------|----------|-------------|------------------------------------|-------------|-----------------|
| Type                  | Lot ID   | Cylinder No | Concentration                      | Uncertainty | Expiration Date |
| NTRM                  | 09010228 | KAL004841   | 98.48 PPM CARBON MONOXIDE/NITROGEN | +/- 0.5%    | Oct 16, 2024    |

| ANALYTICAL EQUIPMENT             |                      |                             |
|----------------------------------|----------------------|-----------------------------|
| Instrument/Make/Model            | Analytical Principle | Last Multipoint Calibration |
| CO-1 SIEMENS ULTRAMAT 6E N1J5700 | NDIR                 | Jul 15, 2020                |

Triad Data Available Upon Request



*[Signature]*

Approved for Release

APEX INSTRUMENTS

EPA Method 5

560 Series Meter Box Calibration

Pre-Test Orifice Method

Metric Meter Box Volume Units, English K Factor

Filename: C:\Customer Project Files\APPENDIX\Cal Sheets\Meter Boxes\Meter Box 1 5-7-20.xlsJA

Revised: 7/25/95 Version: 2.2

Model #: 1

Serial #:

Date: 5/7/2020

Barometric Pressure: 28.44 (in. Hg)

Theoretical Critical Vacuum: 13.42 (in. Hg)

|||||

IMPORTANT! For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

IMPORTANT! The Critical Orifice Coefficient, K, must be entered in English units, (ft<sup>3</sup>/3"deg R)<sup>0.5</sup>/(in Hg)<sup>1/4</sup>(min).

|||||

CONVERSION FACTORS

1 mm Hg = 0.13330 kPa

1 inch = 0.39370 cm

1 inch = 0.03937 mm

1 cu ft = 28.32 liters

----- DRY GAS METER READINGS -----

-CRITICAL ORIFICE READINGS-

| dH<br>(in H <sub>2</sub> O) | Time<br>(min) | Volume                        |                             | Initial Temps.   |                   | Final Temps      |                   | Orifice K Orifice<br>Serial# Coefficient<br>(number) (see above) | Actual -- Ambient Temperature -- |                    | Average Temperatures -- |                    |
|-----------------------------|---------------|-------------------------------|-----------------------------|------------------|-------------------|------------------|-------------------|------------------------------------------------------------------|----------------------------------|--------------------|-------------------------|--------------------|
|                             |               | Initial<br>(ft <sup>3</sup> ) | Final<br>(ft <sup>3</sup> ) | Inlet<br>(deg F) | Outlet<br>(deg F) | Inlet<br>(deg F) | Outlet<br>(deg F) |                                                                  | Vacuum<br>(in Hg)                | Initial<br>(deg F) | Final<br>(deg F)        | Average<br>(deg F) |
| 0.5                         | 10            | 311.555                       | 315.488                     | 62               | 61                | 65               | 62                | 12                                                               | 0.30390681                       | 15                 | 64                      | 64                 |
| 0.93                        | 10            | 315.488                       | 320.81                      | 67               | 63                | 66               | 63                | 16                                                               | 0.41080925                       | 15                 | 64                      | 65                 |
| 1.4                         | 10            | 320.81                        | 327.085                     | 68               | 64                | 68               | 65                | 19                                                               | 0.48449779                       | 15                 | 65                      | 65                 |
| 2.1                         | 5             | 327.085                       | 331.027                     | 68               | 65                | 69               | 66                | 23                                                               | 0.60910402                       | 15                 | 66                      | 66                 |
| 3.8                         | 5             | 331.027                       | 336.224                     | 68               | 66                | 70               | 67                | 31                                                               | 0.80595932                       | 15                 | 66                      | 66                 |

\*\*\*\*\* RESULTS \*\*\*\*\*

-- DRY GAS METER --

----- ORIFICE -----

-- DRY GAS METER --

----- ORIFICE -----

| VOLUME<br>CORRECTED<br>Vm(std)<br>(cu ft) | VOLUME<br>CORRECTED<br>Vm(std)<br>(liters) | VOLUME<br>CORRECTED<br>Vm(std)<br>(cu ft) | VOLUME<br>CORRECTED<br>Vm(std)<br>(liters) | VOLUME<br>CORRECTED<br>Vm(std)<br>(cu ft) | VOLUME<br>CORRECTED<br>Vm(std)<br>(liters) | CALIBRATION FACTOR |                       | CALIBRATION FACTOR             |                                    |
|-------------------------------------------|--------------------------------------------|-------------------------------------------|--------------------------------------------|-------------------------------------------|--------------------------------------------|--------------------|-----------------------|--------------------------------|------------------------------------|
|                                           |                                            |                                           |                                            |                                           |                                            | Value<br>(number)  | Variation<br>(number) | Value<br>(in H <sub>2</sub> O) | Variation<br>(in H <sub>2</sub> O) |
| 3.7611759                                 | 107.08                                     | 3.77576                                   | 106.92952                                  | 3.94373                                   | 0.99857                                    | -0.00186           |                       | 1.89856015                     | 48.22                              |
| 5.1002748                                 | 144.44                                     | 5.1014902                                 | 144.4742                                   | 5.33353                                   | 1.00024                                    | -0.00019           |                       | 1.92887722                     | 48.99                              |
| 6.0034088                                 | 170.19                                     | 6.0136998                                 | 170.30798                                  | 6.29322                                   | 1.00071                                    | 0.00029            |                       | 2.08361031                     | 52.92                              |
| 3.7729909                                 | 106.85                                     | 3.7765756                                 | 106.95262                                  | 3.95864                                   | 1.00095                                    | 0.00052            |                       | 1.97745971                     | 50.23                              |
| 4.9888287                                 | 141.28                                     | 4.9971208                                 | 141.51846                                  | 5.23935                                   | 1.00166                                    | 0.00124            |                       | 2.03987228                     | 51.81                              |
| Average Y ----->                          |                                            |                                           |                                            |                                           |                                            | 1.00043            |                       | 1.98567594                     | 50.44                              |

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H<sub>2</sub>O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

SIGNED: Brian Lemasters

Date: 5/7/2020



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 3415-11278230

Traceable® Certificate of Calibration for Digital Calipers

Customer: Custom Stack Analysis, LLC, 14614 Cenfield Street NE, Alliance, OH-44601, U.S.A.

Instrument Identification:

Model: 3415,

S/N: 101856179

Manufacturer: Control Company

Standards/Equipment:

| Description | Serial Number | Due Date    | NIST Traceable Reference |
|-------------|---------------|-------------|--------------------------|
| Gage Set    | 99146223      | 17 Dec 2020 | 1000449283               |

Certificate Information:

Technician: 57

Procedure: CAL-05

Cal Date: 12 May 2020

Cal Due Date: 12 May 2021

Test Conditions: 55.18%RH 22.45°C 1018mBar

Calibration Data:

| Unit(s)   | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U      | TUR    |
|-----------|---------|----------|--------|---------|---------|--------|-------|-------|---------|--------|
| in        | N.A.    | N.A.     |        | 0.1000  | 0.1005  | Y      | 0.099 | 0.101 | 0.0003  | 3.33:1 |
| in        | N.A.    | N.A.     |        | 2.0000  | 2.0005  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in        | N.A.    | N.A.     |        | 4.0000  | 4.0005  | Y      | 3.996 | 4.004 | 0.0004  | >4:1   |
| in        | N.A.    | N.A.     |        | 6.0000  | 6.0005  | Y      | 5.994 | 6.006 | 0.0005  | >4:1   |
| In depth  | N.A.    | N.A.     |        | 2.0000  | 2.000   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| In inside | N.A.    | N.A.     |        | 1.0000  | 1.0005  | Y      | 0.999 | 1.001 | 0.00031 | 3.23:1 |
| In step   | N.A.    | N.A.     |        | 2.0000  | 1.9985  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement": (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio;  
Accuracy= $\pm(\text{Max}-\text{Min})/2$ ; Min=As Left Nominal(Rounded) - Tolerance; Max=As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*

Nicol Rodriguez, Quality Manager

*Marisa Elms*

Marisa Elms, Technical Manager

Note:

Maintaining Accuracy:

In our opinion once calibrated your Digital Calipers should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Calipers change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

Issue Date: 12 May 2020

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.traceable.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2015 Quality Certified by DNV GL, Certificate No. CERT-01806-2006-AQ-HOU-ANAB.  
International Laboratory Accreditation Cooperation - Multilateral Recognition Arrangement (ILAC-MRA).



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 1870-11290275

## Traceable® Certificate of Calibration for Digital Barometer Module

Customer: Custom Slack Analysis, LLC, 14614 Cenfield Street NE, Alliance, OH 44601, U.S.A.

### Instrument Identification:

Model: 1870,

S/N: 90724105

Manufacturer: Control Company

### Standards/Equipment:

| Description               | Serial Number  | Due Date    | NIST Traceable Reference |
|---------------------------|----------------|-------------|--------------------------|
| Digital Thermometer       | 221197993      | 10 Oct 2020 | 4000-10785768            |
| Chilled Mirror Hygrometer | 31874/1H2048MR | 22 Jan 2021 | 18004                    |
| Digital Barometer         | D4540001       | 01 Nov 2020 | 1000447551               |

### Certificate Information:

Technician: 57

Procedure: CAL-31

Cal Date: 17 May 2020

Cal Due Date: 17 May 2021

Test Conditions: 57.18%RH 22.6°C 1012mBar

### Calibration Data:

| Unit(s) | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U   | TUR  |
|---------|---------|----------|--------|---------|---------|--------|-------|-------|------|------|
| %RH     | N.A.    | N.A.     |        | 48.33   | 32      | N      | 43    | 53    | 0.74 | >4:1 |
| °C      | N.A.    | N.A.     |        | 24.29   | 24      | Y      | 23.29 | 25.29 | 0.05 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 806.00  | 812     | Y      | 795   | 817   | 0.62 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 909.98  | 914     | Y      | 899   | 921   | 0.62 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 1018.72 | 1022    | Y      | 1008  | 1030  | 0.62 | >4:1 |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO 'Guide to the Expression of Uncertainty in Measurement': (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*

Nicol Rodriguez, Quality Manager

*Marisa Elms*

Marisa Elms, Technical Manager

Note:

### Maintaining Accuracy:

In our opinion once calibrated your Digital Barometer Module should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Barometer Module change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

### Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

Issue Date: 17 May 2020

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.traceable.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2015 Quality Certified by DNV GL, Certificate No. CERT-01805-2008-AQ-HOU-ANAB.  
International Laboratory Accreditation Cooperation - Multilateral Recognition Arrangement (ILAC-MRA).

**MATHESON**

The Gas Professionals™

1650 Enterprise Parkway  
Twinsburg, OH 44087  
215-648-4000

## Certificate of Analysis – EPA Protocol Mixtures

Customer: YOUNGSTOWN OXYGEN

Cylinder Number: SD-13278

Cylinder pressure: 2000 psig

Last Analysis date: 4/3/2017

Expiration Date: 4/3/2025

| Protocol: | Reference # | Lot #        |
|-----------|-------------|--------------|
| G1        | 15143972    | 109-96-38369 |

**DO NOT USE THIS CYLINDER WHEN THE  
PRESSURE FALLS BELOW 100 PSIG**

## REPLICATE RESPONSES

Component: Carbon Dioxide

Certified Conc: 20.04% ± 0.04%

Date: 4/3/2017

Date:

20.04%

20.04%

20.04%

Component: Oxygen

Certified Conc: 20.00% ± 0.03%

Date: 4/3/2017

Date:

20.02%

20.00%

19.98%

BALANCE GAS: Nitrogen

## REFERENCE STANDARDS

Component: Carbon Dioxide

SRM #: SRM-2745

Sample #: 9-D-41

Cylinder #: FF-13582

Concentration: 16.080%

Oxygen

SRM-2659a

71-E-31

FF-22194

20.863%

## CERTIFICATION INSTRUMENTS

Component: Carbon Dioxide

Make/Model: Varian 3800 GC

Serial Number: LR-92489

Measurement Principle: TCD, FID

Last Calibration: 3/13/2017

Oxygen

Horiba MPA-510

9XUJXODW

Paramagnetic

3/14/2017

Notes: G2695116X

The certification was performed according to EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards May 2012, using procedure G1 and/or G2. U.S EPA Vendor ID Number: D42017, PGVP Participation Date: 01/01/17, PGVP Renewal Date: 01/01/18. The expanded uncertainty listed for each component was calculated at a coverage factor of k=2 and at a level of confidence of 95%.

*Philip D. Mant.*Analyst \_\_\_\_\_ Date 4/4/2017



7410 Worthington-Galena Rd  
Worthington, Ohio 43085  
Phone: (614) 436-4933

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.icrents.com](http://www.icrents.com)

### Temperature RTD Calibrator Certificate of Calibration

Instrument: Altek Series 22 T/C  
Serial#: 243783  
Technician: Sam Shults

Date: 11/3/2020  
Due: 11/3/2021

#### Custom Stack Analysis

| <u>Left Slide</u>   |                    | <u>Right Slide</u>  |                    |
|---------------------|--------------------|---------------------|--------------------|
| <u>Lab Standard</u> | <u>UUT Reading</u> | <u>Lab Standard</u> | <u>UUT Reading</u> |
| 0.0                 | -0.5               | 100.0               | 99.7               |
| 1000.0              | 1000.6             | 1100.0              | 1099.6             |
| 2000.0              | 2000.5             | 2100.0              | 2099.2             |

Accuracy  
+/- 1.0 F

#### Reference Standards

PIE 525B sn.116763 Cal Due:9/28/2021

Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable



7410 Worthington-Galena Rd  
Worthington, Ohio 43085  
Phone: (614) 436-4933

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.iemts.com](http://www.iemts.com)

### Dwyer Digital Manometer Certificate of Calibration

Instrument: Dwyer 475 Digital Manometer  
Serial#: E46Z

Date: 11/3/2020  
Technician: Sam Shults

#### Custom Stack

##### Positive Port

| <u>Calibrated Source</u> | <u>Dwyer Mark III</u> | <u>% Accuracy</u> |
|--------------------------|-----------------------|-------------------|
| 0.500                    | 0.498                 | +/- 0.04" H2O     |
| 2.000                    | 2.005                 | 0.3               |
| 3.000                    | 3.008                 | 0.3               |
| 4.000                    | 4.009                 | 0.2               |

##### Negative Port

| <u>Calibrated Source</u> | <u>Dwyer Mark III</u> | <u>% Accuracy</u> |
|--------------------------|-----------------------|-------------------|
| 0.500                    | 0.501                 | +/- 0.04" H2O     |
| 2.000                    | 2.008                 | 0.4               |
| 3.000                    | 3.009                 | 0.3               |
| 4.000                    | 4.005                 | 0.1               |

Allowable Tolerance +/- 1.0% "H2O FS

#### Reference Standards

Druck 740 DPI sn.74001549, Cal Due: 12/13/2020

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**

**MATHESON**

ask...The Gas Professionals™

1700 Scepter Rd

Waverly, TN 37185

931-296-3357

**Certificate of Analysis - EPA Protocol Mixtures**Customer: WHS 109  
Y-TOWN

Part # G2695803

Cylinder Number: CC78213

Cylinder Pressure: 2000 psig

Last Analysis Date: 8/24/2020

Expiration Date: 8/24/2023

Protocol: Reference #: Lot#:  
G1 T270458-01 9090406167**DO NOT USE THIS CYLINDER WHEN THE  
PRESSURE FALLS BELOW 100 PSIG****REPLICATE RESPONSES**

|                                          | Date: 8/17/2020 | Date: 8/24/2020 |
|------------------------------------------|-----------------|-----------------|
| Component: Nitrogen Dioxide              | 49.4            | 49.6            |
|                                          | 49.3            | 49.5            |
| Certified Conc: 49.5 ppm +/- 0.9 ppm ABS | 49.3            | 49.7            |

BALANCE GAS: AIR

**REFERENCE STANDARDS:**Component: Nitrogen Dioxide  
Reference Standard: GMIS  
Cylinder #: E80097397  
Concentration: 47.8 +/- 0.8 ppm ABS  
Exp Date: 9/21/2021Component: Nitrogen Dioxide  
Reference Standard: PRM  
Cylinder #: D562925  
Concentration: 75.0 +/- 1.1 ppm ABS  
Exp Date: 2/2/2019  
SRM #: -  
NIST Sample #: -**CERTIFICATION INSTRUMENTS**Component: Nitrogen Dioxide  
Make/Model: CAI 600  
Serial Number: Y09003  
Measurement Principle: CHEMI  
Last Calibration: 8/24/2020**Notes:**

The certification was performed by Global Calibration Gases, LLC, Sarasota, FL and according to EPA Traceability Protocol for Assay and Certification Standards May 2012, using procedure G1 and/or G2, U.S. EPA PGVP Vendor ID number: N22020  
The expanded uncertainty listed for each component was calculated at a coverage factor of k=2 and at level of confidence of 95%

Analyst:

Signature on file

Date: 8/24/2020

QA:

Ashley Smallwood

Date: 9/1/2020



## Page 1 of 1

**MATHESON**

ask...The Gas Professionals®

**Certificate of Batch Analysis**

| <b>Manufacturing Location</b><br>Matheson<br>1055 Garden Street<br>Greensburg, PA 15601<br><br><b>CYLINDER NUMBER(S)</b><br><br>748203Y<br>30-872<br>W-450273<br>TWC-563435<br>279432Y<br>3041791Y<br><br>24596<br>BA-1423<br>NK00455<br><br>7899<br>Q8572<br><br>784182<br>3887456Y<br>SG904256<br><br>935783<br>46-1392                                                                                                                                                                                                      | <b>To:</b> Matheson                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                         | <b>Sales Order No:</b><br><b>Purchase Order:</b>  |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------|---------------------------------------------------|-------------------|-----------|---------------|-------------------------|-------|-------------------|--------|---------|------|---|---|-----|------|------|-----|---|-------|----|-----|-----|---|----------------|----|----|-----|---|-----------------|----|----|-----|---|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | <b>Product:</b> Air                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |                         | <b>Cylinder Size:</b> 1L<br><b>Valve:</b> CGA 580 |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | <b>Grade:</b> Ultra Zero<br><b>Part No:</b> G2001312                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                         | <b>Pressure:</b> 2400 PSIG                        |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | <table border="1"><thead><tr><th>Component</th><th>Specification</th><th>Certified Concentration</th><th>Units</th><th>Analytical Method</th></tr></thead><tbody><tr><td>Oxygen</td><td>20 - 22</td><td>20.8</td><td>%</td><td>J</td></tr><tr><td>THC</td><td>&lt;0.1</td><td>0.01</td><td>ppm</td><td>E</td></tr><tr><td>Water</td><td>&lt;2</td><td>1.6</td><td>ppm</td><td>F</td></tr><tr><td>Carbon Dioxide</td><td>&lt;1</td><td>ND</td><td>ppm</td><td>H</td></tr><tr><td>Carbon Monoxide</td><td>&lt;1</td><td>ND</td><td>ppm</td><td>H</td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr></tbody></table> |                         |                                                   |                   | Component | Specification | Certified Concentration | Units | Analytical Method | Oxygen | 20 - 22 | 20.8 | % | J | THC | <0.1 | 0.01 | ppm | E | Water | <2 | 1.6 | ppm | F | Carbon Dioxide | <1 | ND | ppm | H | Carbon Monoxide | <1 | ND | ppm | H |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Component                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      | Specification                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | Certified Concentration | Units                                             | Analytical Method |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Oxygen                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | 20 - 22                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               | 20.8                    | %                                                 | J                 |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| THC                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | <0.1                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | 0.01                    | ppm                                               | E                 |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Water                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | <2                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 1.6                     | ppm                                               | F                 |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Carbon Dioxide                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | <1                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | ND                      | ppm                                               | H                 |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Carbon Monoxide                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | <1                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | ND                      | ppm                                               | H                 |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| <b>COMMENTS</b><br>Product Composition verified by instrumentation calibrated with at least one of the following: NIST traceable weights, gas mixtures traceable to NIST weights, NIST gas standards such as NTRM's or SRM's manufacturer NIST calibrations.                                                                                                                                                                                                                                                                   |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| <b>Analytical Method Key</b><br>A Trace oxygen analyzer<br>B Gas chromatograph with thermal conductivity detector<br>C Gas chromatograph with flame ionization detector<br>D Trace nitrogen analyzer<br>E Total hydrocarbon analyzer<br>F Specific mixture analyzer<br>G Gas chromatograph with mass spectrometric detector<br>H Gas chromatograph with mass spectrometric detector<br>I Specific carbon monoxide analyzer<br>J Percent oxygen analyzer<br>K Specific carbon dioxide analyzer<br>L Binary gas mixture analyzer |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| <b>Lot No:</b> 118K41520<br><b>Fill Date:</b> 4/28/2015                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                         |                                                   |                   |           |               |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |

**IMPORTANT**

The information contained herein has been prepared at your request by qualified experts within Matheson. While we believe that the information is accurate within the limits of the analytical methods employed and is complex to the extent of the specified analysis performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Matheson arising out of the use of the information contained herein exceed the fee established for providing such information.

The undersigned certifies that the product(s) listed above reflect gas phase by volume (unless otherwise indicated) and meet or exceed the minimum purity specification(s).

Analyst

12/20/16  
Date

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

595572

FOR Custom Stack 593P

14614 CenField St Alliance Ohio

P.O. DATE 3/12/20

☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5525 Gallileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Penimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 1001 Findlay Rd.  
 LIMA, OH 45801  
 419-228-5021  
☐ 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7180  
☐ 528 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46814  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 43089  
 513-777-5800  
☐ 100 McClunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF Ohio TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT Colam lot #3

S/N'S 1192529404

PARTS USED Colam lot #3

SCALE TECHNICIAN: MR. [Signature]

ACCEPTED BY: [Signature]

| TAG NO.       | MFG           | MOD NO.          | S/N               | LOC.       | CAP.          | GRAD. SIZE  | NORM RING                     | CAL FRO         | CLEAN TEST | CAL STICK  | NEXT CAL       |
|---------------|---------------|------------------|-------------------|------------|---------------|-------------|-------------------------------|-----------------|------------|------------|----------------|
|               | <u>Chaus</u>  | <u>Navigator</u> | <u>1192529404</u> | <u>Lab</u> | <u>2,100g</u> | <u>0.1g</u> | <u>HI 2000</u><br><u>LO 0</u> | <u>6 months</u> | <u>YES</u> | <u>YES</u> | <u>11/2020</u> |
| WGT USED      | AS FOUND      | DEV.             | TOL. +/-          | ADJUSTED   | AS LEFT       | COMMENTS    |                               |                 |            |            |                |
| 1 <u>200</u>  | <u>200.0</u>  | <u>0</u>         |                   | <u>NO</u>  | <u>200.0</u>  |             |                               |                 |            |            |                |
| 2 <u>500</u>  | <u>500.0</u>  | <u>0</u>         |                   | <u>NO</u>  | <u>500.0</u>  |             |                               |                 |            |            |                |
| 3 <u>1000</u> | <u>1000.0</u> | <u>0</u>         |                   | <u>NO</u>  | <u>1000.0</u> |             |                               |                 |            |            |                |
| 4             |               |                  |                   |            |               |             |                               |                 |            |            |                |
| 5             |               |                  |                   |            |               |             |                               |                 |            |            |                |
| 6             |               |                  |                   |            |               |             |                               |                 |            |            |                |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584495

FOR CUSTOM STACK 393P - CODI/III

14614 CENFIELD ST ALLIANCE, OH 44601

☐ 14941 Liberty Hill Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 43228  
 216-661-2660  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1782  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 2351 Jaclyn Court  
 SOUTH BEND, IN 46814  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5800  
☐ 100 McClunkin Road  
 NITRO, WV 25143  
 304-755-0686

P.O. DATE 5/12/20

CODI/III

STATE OF OHIO

TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 3019.0187

WEIGHT  
S/N'S

GLAM HITE #3

SCALE  
TECHNICIAN: MR.

ACCEPTED BY: [Signature] SIGNATURE

PARTS USED

| TAG NO.    | MFG    | MOD NO.    | S/N        | LOC.     | CAP.    | GRAD. SIZE | NORM RING        | CAL FRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|------------|--------|------------|------------|----------|---------|------------|------------------|----------|------------|-----------|----------|
|            | CHALIS | ADVENTURER | 1203240794 | LAB      | 4100 g  | .1 g       | H# - 0<br>LO - 9 | 6 Months | YES        | NO        | 11/2020  |
| WIGHT USED |        |            |            |          |         |            |                  |          |            |           |          |
| 1          | 10g    | 10.0       | +/- 2%     | ADJUSTED | AS LEFT | 10.0       | CAL. BOXED       |          |            |           |          |
| 2          | 20g    | 20.0       | +/- 2%     | YES / NO | 20.0    | 20.0       |                  |          |            |           |          |
| 3          | 50g    | 50.0       | +/- 2%     | YES / NO | 50.0    | 50.0       |                  |          |            |           |          |
| 4          | 100g   | 100.0      | +/- 2%     | YES / NO | 100.0   | 100.0      |                  |          |            |           |          |
| 5          | 1kg    | 999.7      | +/- 2%     | YES / NO | 1000.0  | 1000.0     |                  |          |            |           |          |
| 6          | 2kg    | 1999.4     | +/- 2%     | YES / NO | 2000.0  | 2000.0     |                  |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584497

FOR CUSTOM STACK 593P - COD!!!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-239-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3308 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-498-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5525 Galileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-289-7960  
☐ 1001 Findlay Rd.  
 LIMA, OH 45601  
 419-228-5021  
☐ 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7180  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46614  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5900  
☐ 100 McJunkin Road  
 NITRO, WV 25143  
 304-755-0686

P.O. COD!!!!

DATE 5/12/20

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187WEIGHT  
S/N'SColan kit #3SCALE  
TECHNICIAN: M.P.

SIGNATURE

ACCEPTED BY: [Signature] SIGNATURE

PARTS USED

| TAG NO.   | MFG     | MOD NO.   | S/N        | LOC.     | CAP.    | GRAD. SIZE | NORM RNG                | CAL PRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|-----------|---------|-----------|------------|----------|---------|------------|-------------------------|----------|------------|-----------|----------|
|           | OH/HAUS | SCOUT PRO | 7124111434 | LAB      | 2000 -- | .1 --      | HF 2000 --<br>LO 500 -- | 6 Months | YES        | YES       | 11/2020  |
| WGHT USED |         |           |            | ADJUSTED | AS LEFT | COMMENTS   |                         |          |            |           |          |
| 1         | 500     | 500.0     | 0          | YES / NO | 500.0   |            |                         |          |            |           |          |
| 2         | 1000    | 1000.0    | 0          | YES / NO | 1000.0  |            |                         |          |            |           |          |
| 3         | 1500    | 1500.0    | 0          | YES / NO | 1500.0  |            |                         |          |            |           |          |
| 4         | 2000    | 2000.0    | 0          | YES / NO | 2000.0  |            |                         |          |            |           |          |
| 5         |         |           |            | YES / NO |         |            |                         |          |            |           |          |
| 6         |         |           |            | YES / NO |         |            |                         |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechtbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584496

FOR CUSTOM STACK 593P - CODHIII

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. CODHIII

DATE 5/12/20

- ☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 424 Scale St S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8468  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7180  
☐ 1080 National Parkway  
 MAHNSFIELD, OH 44806  
 419-529-3006  
☐ 528 31<sup>st</sup> St  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jaclyn Court  
 SOUTH BEND, IN 46614  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45089  
 513-777-5800  
☐ 100 McClunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

2019-0182

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO.

WEIGHT  
S/N'S

Columbus #3

SCALE  
TECHNICIAN: M.P.

ACCEPTED BY: *[Signature]*  
SIGNATURE

PARTS USED

| TAG NO. | MFG       | MOD NO. | S/N      | LOC.     | CAP.     | GRAD. SIZE | NORM RING        | CAL FRQ  | CLEAN TEST | CAL STICK | NEXT CAL |
|---------|-----------|---------|----------|----------|----------|------------|------------------|----------|------------|-----------|----------|
|         | SARTORIUS | A2005   | 39080133 | LAB      | 100 GM g | 0.1 g      | HI - g<br>LO - g | 6 Months | YES        | NO        | 11/2020  |
| 1       | 10000.9   | 10.9    | +/- 2%   | ADJUSTED | AS LEFT  | 10000.0    | CAL. BREAD       |          |            |           |          |
| 2       | 20001.3   | 1.3     | +/- 2%   | YES / NO | 20000.0  |            |                  |          |            |           |          |
| 3       | 50004.5   | 4.5     | +/- 2%   | YES / NO | 50000.0  |            |                  |          |            |           |          |
| 4       | 100010.8  | 10.8    | +/- 2%   | YES / NO | 100000.0 |            |                  |          |            |           |          |
| 5       |           |         |          | YES / NO |          |            |                  |          |            |           |          |
| 6       |           |         |          | YES / NO |          |            |                  |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER Scales, Inc.

## SCALE INSPECTION REPORT

584489

FOR CUSTOM STACK 593P - CODIIIIII

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. CODIIIIII

DATE 5/12/20

☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 State St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7190  
☐ 1080 National Parkway  
 MANSFIELD, OH 44806  
 419-529-3006  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jaclyn Court  
 SOUTH BEND, IN 46814  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5800  
☐ 100 McLunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

2019-0186

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO.

WEIGHT  
S/N'S

Colam hit #3

SCALE  
TECHNICIAN: M.L.

ACCEPTED BY: *[Signature]*  
SIGNATURE

PARTS USED

| TAG NO. | MFG  | MOD NO.  | S/N     | LOC.     | CAP.    | GRAD. SIZE | NORM RNG            | CAL FRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|---------|------|----------|---------|----------|---------|------------|---------------------|----------|------------|-----------|----------|
| 1       | 10g  | 9.9995   | -0.0005 | YES / NO | 210 g   | 0.0001 g   | HI 200 g<br>LO 10 g | 6 Months | YES        | NO        | 11/2020  |
| 2       | 20g  | 19.9996  | -0.0004 | YES / NO | AS LEFT |            |                     |          |            |           |          |
| 3       | 50g  | 49.9997  | -0.0003 | YES / NO |         |            |                     |          |            |           |          |
| 4       | 100g | 99.9980  | -0.0020 | YES / NO |         |            |                     |          |            |           |          |
| 5       | 200g | 199.9970 | -0.0030 | YES / NO |         |            |                     |          |            |           |          |
| 6       | g    |          |         | YES / NO |         |            |                     |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584490

FOR CUSTOM STACK 593P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/12/20

☐ 14941 Liberty Hi Rd.  
BOWLING GREEN, OH 43402  
419-354-2030

☐ 1424 Scale St. S.W.  
CANTON, OH 44706-3096  
330-453-2424

☐ 4005 South Ave.  
YOUNGSTOWN, OH 44512  
330-259-0414

☐ 7550 Jacks Lane  
CLAYTON, OH 45315  
937-832-2040

☐ 3308 Cavalier Dr.  
FORT WAYNE, IN 46808  
260-496-8469

☐ 520 Brookpark Rd.  
CLEVELAND, OH 44109-5898  
216-661-2660

☐ 5525 Galasso Court  
INDIANAPOLIS, IN 46241  
317-548-7821

☐ 4070 Perimeter Dr.  
COLUMBUS, OH 43228  
614-274-9009

☐ 5200 Grand Avenue  
PITTSBURGH, PA 15225  
412-299-7960

☐ 1001 Findlay Rd.  
LIMA, OH 45801  
419-228-5021

☐ 477 North Pike Rd.  
SARVER, PA 16055  
724-224-7180

☐ 2351 Jaclyn Court  
SOUTH BEND, IN 46814

☐ 9930 Crescent Park Drive  
WEST CHESTER, OH 45069  
513-777-5800

☐ 1080 National Parkway  
MANSFIELD, OH 44906  
419-529-3006

☐ 526 31st St.  
PARKERSBURG, WV 26101  
304-428-1792

☐ 100 McJunkin Road  
NITRO, WV 25143  
304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT  
S/N'S

Glam brt #3

SCALE  
TECHNICIAN: MT.

SIGNATURE

ACCEPTED BY: *[Signature]*

SIGNATURE

PARTS USED

| TAG NO.  | MFG      | MOD NO.  | S/N     | LOC.      | CAP.    | GRAD. SIZE | NORM. RING          | CAL. FRO | CLEAN TEST | CAL. STICK | NEXT CAL. |
|----------|----------|----------|---------|-----------|---------|------------|---------------------|----------|------------|------------|-----------|
|          | US SOLID | NONE     | NONE    | TRAVELLER | 500 g   | 0.001 g    | HI 200 g<br>LO 10 g | 6 Months | YES        | YES        | 11/2020   |
| COMMENTS |          |          |         |           |         |            |                     |          |            |            |           |
| 1        | 10g      | AS FOUND | AS LEFT | YES / NO  | 10.000  |            |                     |          |            |            |           |
| 2        | 20g      | AS FOUND | AS LEFT | YES / NO  | 20.000  |            |                     |          |            |            |           |
| 3        | 50g      | AS FOUND | AS LEFT | YES / NO  | 50.000  |            |                     |          |            |            |           |
| 4        | 100g     | AS FOUND | AS LEFT | YES / NO  | 100.000 |            |                     |          |            |            |           |
| 5        | 200g     | AS FOUND | AS LEFT | YES / NO  | 200.000 |            |                     |          |            |            |           |
| 6        | g        | AS FOUND | AS LEFT | YES / NO  |         |            |                     |          |            |            |           |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584488

FOR CUSTOM STACK 503P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/12/20

- ☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5525 Galileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-298-7860  
☐ 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7180  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5900  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46614  
☐ 100 McLunkin Road  
 NITRO, WV 25143  
 304-755-0686

STATE OF Ohio TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT GRAM  
S/N'S bit #3

SCALE TECHNICIAN: M.P.

ACCEPTED BY: [Signature]  
SIGNATURE

PARTS USED

| TAG NO.  | MFG   | MOD NO. | S/N      | LOC.     | CAP.    | GRAD. SIZE | NORM RING |          | CAL FRQ  | CLEAN TEST | CAL STICK | NEXT CAL |
|----------|-------|---------|----------|----------|---------|------------|-----------|----------|----------|------------|-----------|----------|
| -        | A&D   | GF1200  | 14632225 | LAB      | 1210 g  | 0.01 g     | HI 1000 g | LO 200 g | 6 Months | YES        | YES       | 11/2020  |
| WGT USED |       |         |          |          |         |            |           |          |          |            |           |          |
| 1        | 200g  | 200.00  | 0        | YES / NO | AS LEFT | 200.00     | COMMENTS  |          |          |            |           |          |
| 2        | 500g  | 500.00  | 0        | YES / NO | 500.00  |            |           |          |          |            |           |          |
| 3        | 1000g | 1000.00 | 0        | YES / NO | 1000.00 |            |           |          |          |            |           |          |
| 4        | g     |         |          | YES / NO |         |            |           |          |          |            |           |          |
| 5        | g     |         |          | YES / NO |         |            |           |          |          |            |           |          |
| 6        | g     |         |          | YES / NO |         |            |           |          |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.



7410 Worthington-Galena Road  
Worthington, Ohio 43085  
Phone: (614) 436-4933  
Fax: (614) 436-9144

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.ierents.com](http://www.ierents.com)

### Temperature Calibration Certificate

Instrument: H-B Thermometer  
Serial #: 4A6108

Date: 4/6/2020  
Technician: Sam Shults

| <u>Lab Standard</u> | <u>Thermometer Mark</u> |
|---------------------|-------------------------|
| 169.9               | 170.0                   |
| 190.0               | 190.0                   |
| 204.8               | 205.0                   |
| 214.6               | 215.0                   |

Accuracy = 1 F

Reference Standards  
PIE 525B sn. 116765 Cal Due: 9/6/2020  
Hart 9103 Temp Dry Well

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**



7410 Worthington-Galena Road  
Worthington, Ohio 43085  
Phone: (614) 436-4933  
Fax: (614) 436-9144

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.ierents.com](http://www.ierents.com)

### Temperature Calibration Certificate

Instrument: H-B Thermometer  
Serial #: 485200

Date: 4/6/2020  
Technician: Sam Shults

| <u>Lab Standard</u> | <u>Thermometer Mark</u> |
|---------------------|-------------------------|
| 30.1                | 30.0                    |
| 50.1                | 50.0                    |
| 70.0                | 70.0                    |
| 88.0                | 88.0                    |

Accuracy = 1 F

#### Reference Standards

PIE 525B sn. 116765 Cal Due: 9/6/2020  
Hart 9103 Temp Dry Well

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**

# THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/28/2020 BY Matt Ashbrook Pb 28,73

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| <u>ICE WATER</u>           |                  | <u>BOILING WATER</u> |                  |            |
|----------------------------|------------------|----------------------|------------------|------------|
| <u>TC</u>                  | <u>PRECISION</u> | <u>TC</u>            | <u>PRECISION</u> | <u>TC</u>  |
| <u>OVEN THERMOCOUPLES</u>  |                  |                      |                  |            |
| <u>O-1</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-2</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-3</u>                 | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-4</u>                 | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-5</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-6</u>                 | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-7</u>                 | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-8</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-9</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-10</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-11</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-12</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>STACK THERMOCOUPLES</u> |                  |                      |                  |            |
| <u>2S-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>2S-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>2S-3</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>3S-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3S-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>3S-3</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3S-4</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3S-5</u>                | 32               | <u>33</u>            | 212              | <u>313</u> |
| <u>4S-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4S-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4S-3</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4S-4</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>4S-5</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4S-6</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>5S-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>5S-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>5S-3</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>6S-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6S-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6S-3</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>6S-4</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>8S-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>8S-2</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>10S-1</u>               | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>10S-2</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>12S-1</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |

# **THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS**

CALIBRATION DATE 12/28/2020 BY Matt Ashbrooke PB 28.73

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| <u>ICE WATER</u>               |                  | <u>BOILING WATER</u> |                  |            |
|--------------------------------|------------------|----------------------|------------------|------------|
| <u>TC</u>                      | <u>PRECISION</u> | <u>TC</u>            | <u>PRECISION</u> | <u>TC</u>  |
| <b>CONDENSOR THERMOCOUPLES</b> |                  |                      |                  |            |
| <u>C-1</u>                     | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>C-2</u>                     | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>C-3</u>                     | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>C-4</u>                     | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>C-5</u>                     | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>C-6</u>                     | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>C-7</u>                     | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>C-8</u>                     | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>C-9</u>                     | 32               | <u>31</u>            | 212              | <u>211</u> |
| <b>PROBE THERMOCOUPLES</b>     |                  |                      |                  |            |
| <u>2P-1</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>2P-2</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>2P-3</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>3P-1</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>3P-2</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>3P-3</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3P-4</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3P-5</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>4P-1</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4P-2</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4P-3</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4P-4</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4P-5</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4P-6</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>5P-1</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>5P-2</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>5P-3</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6P-1</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6P-2</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>6P-3</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>6P-4</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>8P-1</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>8P-2</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>10P-1</u>                   | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>10P-2</u>                   | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>12P-1</u>                   | 32               | <u>32</u>            | 212              | <u>212</u> |

## THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/28/2020 BY Matt Ashrade Pb 28.73

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 485200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

[illegible]

# **THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS**

CALIBRATION DATE 12/28/2020

BY Matt Ashbrook

Pb 28,73

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER

No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| <u>ICE WATER</u>           |                  | <u>BOILING WATER</u> |                  |            |
|----------------------------|------------------|----------------------|------------------|------------|
| <u>TC</u>                  | <u>PRECISION</u> | <u>TC</u>            | <u>PRECISION</u> | <u>TC</u>  |
| <u>METER THERMOCOUPLES</u> |                  |                      |                  |            |
| <u>1M-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>1M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>2M-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>2M-2</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>3M-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4M-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4M-2</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>5M-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>5M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6M-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6M-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>7M-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>7M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>8M-1</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>8M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>9M-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>9M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>10M-1</u>               | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>10M-2</u>               | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>15M-1</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>15M-2</u>               | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>17M-1</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>17M-2</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>18M-1</u>               | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>18M-2</u>               | 32               | <u>31</u>            | 212              | <u>211</u> |

THERMOCOUPLE TEMPERATURES ARE READ ON THE DTI DURING TEST.

DTI CALIBRATED BY ALTEK 22 TC SOURCE S# 148946 OR S# 243783 PRIOR TO TC CAL.

Client: Megs:77

## Pitot Tube Inspection


Date: 4-14-22

|                                               |             |                            |              |
|-----------------------------------------------|-------------|----------------------------|--------------|
| Probe/Pitot Number                            | <u>6P-4</u> | A (Pa + Pb)                | <u>1.027</u> |
| Level and Perpendicular                       | <u>yes</u>  | Zs = A tan Y (< 0.125")    | <u>0</u>     |
| Obstruction?                                  | <u>no</u>   | Ws = A tan 0 (< 0.03125")  | <u>0</u>     |
| Damaged?                                      | <u>no</u>   | Dt (0.1875" < Dt < 0.375") | <u>.375</u>  |
| a <sub>1</sub> (-10° < a <sub>1</sub> < +10°) | <u>0</u>    | Pa (1.05 Dt < Pa < 1.5 Dt) | <u>.511</u>  |
| a <sub>2</sub> (-10° < a <sub>2</sub> < +10°) | <u>0</u>    | Pb (1.05 Dt < Pb < 1.5 Dt) | <u>.516</u>  |
| b <sub>1</sub> (-5° < b <sub>1</sub> < +5°)   | <u>0</u>    | Pa = Pb ± 0.063"           | <u>.005</u>  |
| b <sub>2</sub> (-5° < b <sub>2</sub> < +5°)   | <u>0</u>    |                            |              |
|                                               | <u>0</u>    |                            |              |

## Probe Minimum Interferences

|              |  |                            |  |
|--------------|--|----------------------------|--|
| Y (>= 3.0")  |  | D <sub>n</sub>             |  |
| X (> .75")   |  | X/D <sub>n</sub> (>= 1.5") |  |
| Zp (>= .75") |  |                            |  |

- Pa Distance between where pitots adjoin to tip of pitot (Must be between 1.05 & 1.50 times O.D. of tubing)  
 Pb Distance between where pitots adjoin to tip of pitot (Must be between 1.05 & 1.50 times O.D. of tubing)  
 Dt Diameter of pitot tube (0.375 inches on all pitots)  
 Zs Distance between the tip of the impact and static line along the length of the pitot (Must be < 1/8 inch (0.1250))  
 Ws Spacing between Pitot tubes where welded together (Must be < 1/32 inch (0.0313))  
 a<sub>1</sub> Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 10 Deg)  
 a<sub>2</sub> Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 10 Deg)  
 b<sub>1</sub> Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 5 Deg)  
 b<sub>2</sub> Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 5 Deg)  
 X Distance between side of nozzle and side of pitot tube (Must be > 3/4 inch)  
 Zp Distance from center of pitot opening back to tip of thermal couple (Must be >= 3/4 inch (0.75))  
 Y Distance from center of pitot opening back to probe (Must be >= 3 inches)



# **Appendix #4**

## **Monitoring Data**

Meggitt Aircraft Braking Systems Corporation  
P039 Accutherm Outlet

| Nox  | Gas   | Cal   | O2   | Gas   | Cal  |
|------|-------|-------|------|-------|------|
| High | 46.93 | 47.20 | High | 20    | 20   |
| Mid  | 25.30 | 25.10 | Mid  | 10    | 10.1 |
| Zero | 0.00  | 0.40  | Zero | 0     | 0.1  |
| NO2  | Gas   | Cal   | CO2  | Gas   | Cal  |
|      | 49.50 | 48.70 | High | 20.04 | 20   |
| VOC  | Gas   |       | Mid  | 9.72  | 9.8  |
| High | 47.05 |       | Zero | 0     | 0    |
| Mid  | 24.70 |       | CO   | Gas   | Cal  |
| Low  | 13.70 |       | High | 29.76 | 30   |
| Zero | 0.00  |       | Mid  | 14.42 | 14.6 |
|      |       |       | Zero | 0     | 0    |

| CO2   | O2    | CO    | VOC   | NOx   | Time Stamp                                 |
|-------|-------|-------|-------|-------|--------------------------------------------|
| -0.03 | 0.04  | -0.01 | 0.14  | 25.15 | 4/15/2021 11:43:53 AM Nox Bias VOC Zero    |
| -0.04 | 0.41  | -0.02 | 0.57  | 25.12 | 4/15/2021 11:44:53 AM                      |
| -0.01 | 11.35 | -0.02 | 2.22  | 22.73 | 4/15/2021 11:45:53 AM                      |
| 0.02  | 15.53 | 0.04  | 44.22 | 12.51 | 4/15/2021 11:46:54 AM                      |
| -0.02 | 20.96 | 0.03  | 47.13 | 0.58  | 4/15/2021 11:47:54 AM                      |
| -0.03 | 20.91 | -0.02 | 47.42 | 0.04  | 4/15/2021 11:48:55 AM VOC High             |
| -0.03 | 20.91 | 0.00  | 46.91 | 0.04  | 4/15/2021 11:49:55 AM                      |
| -0.03 | 20.92 | -0.01 | 46.96 | 0.04  | 4/15/2021 11:50:55 AM                      |
| -0.03 | 18.42 | 0.13  | 4.36  | 0.04  | 4/15/2021 11:51:56 AM                      |
| -0.04 | 0.75  | 6.99  | 0.33  | 0.04  | 4/15/2021 11:52:56 AM                      |
| -0.04 | 0.17  | 13.92 | 0.27  | 0.04  | 4/15/2021 11:53:57 AM                      |
| -0.04 | 0.02  | 14.02 | 0.24  | 0.04  | 4/15/2021 11:54:57 AM Co Bias CO2 O2 Zero  |
| -0.04 | 0.02  | 13.97 | 0.23  | 0.04  | 4/15/2021 11:55:58 AM                      |
| -0.04 | 0.02  | 13.96 | 0.18  | 0.04  | 4/15/2021 11:56:58 AM                      |
| -0.03 | 4.09  | 13.93 | 4.77  | 0.04  | 4/15/2021 11:57:58 AM                      |
| -0.02 | 13.18 | 6.60  | 13.08 | 0.04  | 4/15/2021 11:58:59 AM                      |
| -0.04 | 20.81 | 0.26  | 13.19 | 0.04  | 4/15/2021 11:59:59 AM VOC Low              |
| -0.03 | 20.93 | 0.10  | 10.59 | 0.04  | 4/15/2021 12:01:00 PM                      |
| -0.02 | 20.93 | 0.10  | 6.79  | 0.04  | 4/15/2021 12:02:00 PM                      |
| -0.01 | 20.97 | 0.10  | 24.55 | 0.04  | 4/15/2021 12:03:00 PM                      |
| -0.04 | 21.05 | 0.02  | 24.62 | 0.04  | 4/15/2021 12:04:01 PM VOC Bias CO Zero     |
| -0.04 | 21.04 | 0.04  | 18.16 | 0.04  | 4/15/2021 12:05:01 PM                      |
| -0.02 | 20.99 | 0.00  | 1.89  | 0.04  | 4/15/2021 12:06:02 PM                      |
| 0.13  | 20.72 | 0.01  | 2.44  | 0.04  | 4/15/2021 12:07:02 PM                      |
| 8.34  | 11.94 | -0.05 | 0.32  | 0.04  | 4/15/2021 12:08:03 PM                      |
| 9.79  | 10.07 | -0.20 | 0.25  | 0.04  | 4/15/2021 12:09:03 PM O2 CO2 Bias Nox Zero |
| 9.80  | 10.09 | -0.15 | 0.48  | 0.04  | 4/15/2021 12:10:03 PM                      |
| 5.51  | 14.40 | -0.23 | 0.65  | 0.04  | 4/15/2021 12:11:04 PM                      |
| 0.38  | 20.91 | -0.07 | 0.80  | 0.04  | 4/15/2021 12:12:04 PM                      |
| 0.09  | 20.93 | 0.01  | 0.81  | 0.04  | 4/15/2021 12:13:05 PM                      |
| 0.07  | 20.93 | 0.00  | 0.79  | 0.04  | 4/15/2021 12:14:05 PM                      |
| 0.06  | 20.93 | 0.03  | 0.72  | 0.04  | 4/15/2021 12:15:05 PM                      |
| 0.05  | 20.93 | 0.01  | 0.72  | 0.04  | 4/15/2021 12:16:06 PM                      |
| 0.04  | 20.93 | 0.03  | 0.71  | 0.04  | 4/15/2021 12:17:06 PM                      |
| 0.04  | 20.93 | 0.02  | 0.72  | 0.04  | 4/15/2021 12:18:07 PM                      |
| 0.04  | 20.93 | 0.03  | 0.72  | 0.04  | 4/15/2021 12:19:07 PM                      |
| 0.03  | 20.93 | 0.07  | 0.72  | 0.04  | 4/15/2021 12:20:08 PM                      |
| 0.03  | 20.93 | 0.00  | 0.72  | 0.04  | 4/15/2021 12:21:08 PM                      |
| 0.04  | 20.93 | -0.01 | 0.68  | 0.04  | 4/15/2021 12:22:08 PM                      |
| 0.04  | 20.93 | 0.01  | 0.71  | 0.04  | 4/15/2021 12:23:09 PM                      |
| 0.04  | 20.93 | -0.02 | 0.64  | 0.04  | 4/15/2021 12:24:09 PM                      |
| 0.03  | 20.93 | -0.04 | 0.61  | 0.04  | 4/15/2021 12:25:10 PM                      |
| 0.04  | 20.93 | 0.02  | 0.65  | 0.04  | 4/15/2021 12:26:10 PM                      |
| 0.04  | 20.93 | 0.00  | 0.66  | 0.04  | 4/15/2021 12:27:11 PM                      |

|      |       |       |      |      |                       |
|------|-------|-------|------|------|-----------------------|
| 0.04 | 20.93 | -0.01 | 0.68 | 0.04 | 4/15/2021 12:28:11 PM |
| 0.04 | 20.93 | 0.01  | 0.69 | 0.04 | 4/15/2021 12:29:11 PM |
| 0.04 | 20.93 | 0.01  | 0.65 | 0.04 | 4/15/2021 12:30:12 PM |
| 0.04 | 20.93 | -0.01 | 0.67 | 0.04 | 4/15/2021 12:31:12 PM |
| 0.04 | 20.93 | 0.06  | 0.71 | 0.04 | 4/15/2021 12:32:13 PM |
| 0.04 | 20.93 | 0.01  | 0.71 | 0.04 | 4/15/2021 12:33:13 PM |
| 0.04 | 20.93 | 0.01  | 0.71 | 0.04 | 4/15/2021 12:34:14 PM |
| 0.05 | 20.93 | 0.04  | 0.71 | 0.04 | 4/15/2021 12:35:14 PM |
| 0.05 | 20.93 | 0.02  | 0.68 | 0.04 | 4/15/2021 12:36:14 PM |
| 0.04 | 20.93 | -0.03 | 0.68 | 0.04 | 4/15/2021 12:37:15 PM |
| 0.04 | 20.93 | 0.00  | 0.70 | 0.04 | 4/15/2021 12:38:15 PM |
| 0.05 | 20.93 | -0.01 | 0.70 | 0.04 | 4/15/2021 12:39:16 PM |
| 0.05 | 20.94 | -0.01 | 0.65 | 0.04 | 4/15/2021 12:40:16 PM |
| 0.05 | 20.94 | -0.02 | 0.64 | 0.04 | 4/15/2021 12:41:17 PM |
| 0.05 | 20.94 | -0.01 | 0.70 | 0.04 | 4/15/2021 12:42:17 PM |
| 0.05 | 20.94 | 0.00  | 0.69 | 0.04 | 4/15/2021 12:43:17 PM |
| 0.05 | 20.94 | 0.01  | 0.69 | 0.04 | 4/15/2021 12:44:18 PM |
| 0.05 | 20.93 | 0.02  | 0.66 | 0.04 | 4/15/2021 12:45:18 PM |
| 0.05 | 20.93 | 0.02  | 0.64 | 0.04 | 4/15/2021 12:46:19 PM |
| 0.06 | 20.93 | 0.02  | 0.70 | 0.04 | 4/15/2021 12:47:19 PM |
| 0.06 | 20.93 | 0.00  | 0.69 | 0.04 | 4/15/2021 12:48:19 PM |
| 0.06 | 20.93 | 0.02  | 0.71 | 0.04 | 4/15/2021 12:49:20 PM |
| 0.06 | 20.93 | -0.02 | 0.71 | 0.05 | 4/15/2021 12:50:20 PM |
| 0.06 | 20.93 | 0.01  | 0.72 | 0.04 | 4/15/2021 12:51:21 PM |
| 0.06 | 20.93 | 0.01  | 0.70 | 0.05 | 4/15/2021 12:52:21 PM |
| 0.06 | 20.93 | 0.00  | 0.69 | 0.06 | 4/15/2021 12:53:22 PM |
| 0.06 | 20.93 | -0.03 | 0.70 | 0.06 | 4/15/2021 12:54:22 PM |
| 0.06 | 20.94 | 0.01  | 0.74 | 0.04 | 4/15/2021 12:55:22 PM |
| 0.07 | 20.94 | 0.00  | 0.72 | 0.04 | 4/15/2021 12:56:23 PM |
| 0.07 | 20.93 | 0.00  | 0.77 | 0.04 | 4/15/2021 12:57:23 PM |
| 0.07 | 20.93 | 0.03  | 0.72 | 0.04 | 4/15/2021 12:58:24 PM |
| 0.07 | 20.93 | 0.03  | 0.75 | 0.04 | 4/15/2021 12:59:24 PM |
| 0.07 | 20.93 | 0.02  | 0.73 | 0.04 | 4/15/2021 1:00:25 PM  |
| 0.08 | 20.93 | 0.03  | 0.71 | 0.05 | 4/15/2021 1:01:25 PM  |
| 0.08 | 20.93 | 0.02  | 0.71 | 0.06 | 4/15/2021 1:02:25 PM  |
| 0.08 | 20.93 | 0.01  | 0.71 | 0.05 | 4/15/2021 1:03:26 PM  |
| 0.08 | 20.93 | 0.02  | 0.71 | 0.06 | 4/15/2021 1:04:26 PM  |
| 0.08 | 20.93 | -0.02 | 0.73 | 0.05 | 4/15/2021 1:05:27 PM  |
| 0.08 | 20.93 | 0.02  | 0.72 | 0.06 | 4/15/2021 1:06:27 PM  |
| 0.08 | 20.93 | 0.00  | 0.70 | 0.06 | 4/15/2021 1:07:27 PM  |
| 0.08 | 20.93 | -0.02 | 0.68 | 0.06 | 4/15/2021 1:08:28 PM  |
| 0.08 | 20.93 | -0.02 | 0.72 | 0.04 | 4/15/2021 1:09:28 PM  |
| 0.09 | 20.93 | -0.02 | 0.76 | 0.04 | 4/15/2021 1:10:29 PM  |
| 0.09 | 20.93 | -0.02 | 0.75 | 0.04 | 4/15/2021 1:11:29 PM  |
| 0.09 | 20.93 | -0.02 | 0.72 | 0.04 | 4/15/2021 1:12:30 PM  |
| 0.09 | 20.93 | 0.00  | 0.72 | 0.04 | 4/15/2021 1:13:30 PM  |
| 0.09 | 20.93 | -0.02 | 0.73 | 0.04 | 4/15/2021 1:14:30 PM  |
| 0.09 | 20.93 | -0.03 | 0.76 | 0.05 | 4/15/2021 1:15:31 PM  |
| 0.09 | 20.93 | -0.01 | 0.74 | 0.05 | 4/15/2021 1:16:31 PM  |
| 0.09 | 20.93 | 0.02  | 0.74 | 0.04 | 4/15/2021 1:17:32 PM  |
| 0.09 | 20.93 | -0.01 | 0.75 | 0.05 | 4/15/2021 1:18:32 PM  |
| 0.09 | 20.93 | -0.01 | 0.69 | 0.05 | 4/15/2021 1:19:32 PM  |
| 0.10 | 20.93 | 0.00  | 0.72 | 0.04 | 4/15/2021 1:20:33 PM  |
| 0.09 | 20.93 | -0.01 | 0.74 | 0.04 | 4/15/2021 1:21:33 PM  |
| 0.10 | 20.93 | 0.00  | 0.72 | 0.04 | 4/15/2021 1:22:34 PM  |
| 0.10 | 20.93 | 0.01  | 0.72 | 0.04 | 4/15/2021 1:23:34 PM  |
| 0.10 | 20.93 | 0.00  | 0.73 | 0.06 | 4/15/2021 1:24:35 PM  |
| 0.10 | 20.93 | -0.02 | 0.74 | 0.05 | 4/15/2021 1:25:35 PM  |
| 0.10 | 20.93 | 0.00  | 0.77 | 0.06 | 4/15/2021 1:26:35 PM  |
| 0.11 | 20.93 | -0.06 | 0.79 | 0.04 | 4/15/2021 1:27:36 PM  |
| 0.11 | 20.93 | -0.03 | 0.80 | 0.04 | 4/15/2021 1:28:36 PM  |
| 0.11 | 20.93 | -0.02 | 0.80 | 0.04 | 4/15/2021 1:29:37 PM  |
| 0.11 | 20.93 | -0.05 | 0.77 | 0.04 | 4/15/2021 1:30:37 PM  |

|      |       |       |      |       |                                  |
|------|-------|-------|------|-------|----------------------------------|
| 0.11 | 20.93 | -0.06 | 0.80 | 0.04  | 4/15/2021 1:31:38 PM             |
| 0.11 | 20.93 | -0.05 | 0.81 | 0.04  | 4/15/2021 1:32:38 PM             |
| 0.11 | 20.93 | -0.03 | 0.81 | 0.04  | 4/15/2021 1:33:38 PM             |
| 0.11 | 20.93 | -0.05 | 0.80 | 0.04  | 4/15/2021 1:34:39 PM             |
| 0.11 | 20.93 | -0.03 | 0.79 | 0.04  | 4/15/2021 1:35:39 PM             |
| 0.11 | 20.93 | -0.04 | 0.76 | 0.04  | 4/15/2021 1:36:40 PM             |
| 0.10 | 20.94 | -0.06 | 0.79 | 0.04  | 4/15/2021 1:37:40 PM             |
| 0.09 | 20.94 | -0.10 | 0.76 | 0.04  | 4/15/2021 1:38:40 PM             |
| 0.11 | 20.93 | -0.02 | 1.49 | 0.04  | 4/15/2021 1:39:41 PM             |
| 1.25 | 17.26 | -0.04 | 1.54 | 13.12 | 4/15/2021 1:40:41 PM             |
| 2.80 | 15.06 | 0.60  | 1.18 | 22.64 | 4/15/2021 1:41:42 PM             |
| 2.94 | 14.85 | 0.62  | 0.96 | 23.14 | 4/15/2021 1:42:42 PM             |
| 3.32 | 14.31 | 0.42  | 0.88 | 24.48 | 4/15/2021 1:43:43 PM             |
| 3.50 | 14.05 | 0.53  | 0.82 | 25.35 | 4/15/2021 1:44:43 PM             |
| 3.52 | 14.03 | 0.34  | 0.82 | 25.65 | 4/15/2021 1:45:43 PM Start Run 1 |
| 3.49 | 14.08 | 0.19  | 0.82 | 25.44 | 4/15/2021 1:46:44 PM             |
| 3.51 | 14.06 | 0.07  | 0.82 | 25.33 | 4/15/2021 1:47:44 PM             |
| 3.57 | 13.99 | 0.13  | 0.82 | 25.47 | 4/15/2021 1:48:45 PM             |
| 3.54 | 14.04 | 0.09  | 0.81 | 25.24 | 4/15/2021 1:49:45 PM             |
| 3.54 | 14.04 | 0.09  | 0.82 | 25.26 | 4/15/2021 1:50:46 PM             |
| 3.55 | 14.02 | 0.06  | 0.82 | 25.32 | 4/15/2021 1:51:46 PM             |
| 3.57 | 13.98 | 0.05  | 0.82 | 25.47 | 4/15/2021 1:52:46 PM             |
| 3.56 | 14.00 | 0.09  | 0.82 | 25.46 | 4/15/2021 1:53:47 PM             |
| 3.53 | 14.03 | 0.04  | 0.82 | 25.34 | 4/15/2021 1:54:47 PM             |
| 3.54 | 14.03 | 0.08  | 0.82 | 25.25 | 4/15/2021 1:55:48 PM             |
| 3.56 | 14.00 | 0.05  | 0.82 | 25.42 | 4/15/2021 1:56:48 PM             |
| 3.57 | 14.00 | 0.04  | 0.82 | 25.43 | 4/15/2021 1:57:48 PM             |
| 3.55 | 14.02 | 0.05  | 0.82 | 25.20 | 4/15/2021 1:58:49 PM             |
| 3.52 | 14.07 | 0.04  | 0.82 | 25.21 | 4/15/2021 1:59:49 PM             |
| 3.55 | 14.03 | -0.01 | 0.82 | 25.28 | 4/15/2021 2:00:50 PM             |
| 3.48 | 14.13 | 0.02  | 0.82 | 25.04 | 4/15/2021 2:01:50 PM             |
| 3.54 | 14.03 | 0.01  | 0.82 | 25.21 | 4/15/2021 2:02:51 PM             |
| 3.52 | 14.05 | 0.07  | 0.82 | 25.37 | 4/15/2021 2:03:51 PM             |
| 3.53 | 14.03 | 0.07  | 0.82 | 25.29 | 4/15/2021 2:04:51 PM             |
| 3.56 | 13.99 | 0.04  | 0.82 | 25.37 | 4/15/2021 2:05:52 PM             |
| 3.53 | 14.06 | 0.05  | 0.82 | 25.44 | 4/15/2021 2:06:52 PM             |
| 3.55 | 14.02 | 0.05  | 0.82 | 25.39 | 4/15/2021 2:07:53 PM             |
| 3.42 | 14.07 | 0.04  | 0.82 | 25.23 | 4/15/2021 2:08:53 PM             |
| 3.49 | 14.06 | 0.02  | 0.80 | 25.15 | 4/15/2021 2:09:54 PM             |
| 3.49 | 14.06 | 0.02  | 0.82 | 25.07 | 4/15/2021 2:10:54 PM             |
| 3.45 | 14.07 | 0.02  | 0.82 | 25.08 | 4/15/2021 2:11:54 PM             |
| 3.20 | 14.32 | 0.00  | 0.83 | 24.76 | 4/15/2021 2:12:55 PM             |
| 3.03 | 14.53 | -0.06 | 0.82 | 24.25 | 4/15/2021 2:13:55 PM             |
| 2.91 | 14.56 | -0.02 | 0.84 | 23.96 | 4/15/2021 2:14:56 PM             |
| 2.87 | 14.69 | -0.05 | 0.85 | 23.85 | 4/15/2021 2:15:56 PM             |
| 2.74 | 14.82 | -0.03 | 0.87 | 23.30 | 4/15/2021 2:16:56 PM             |
| 2.61 | 14.89 | -0.04 | 0.84 | 23.18 | 4/15/2021 2:17:57 PM             |
| 2.62 | 14.84 | -0.05 | 0.85 | 23.15 | 4/15/2021 2:18:57 PM             |
| 2.86 | 14.69 | -0.04 | 0.82 | 23.27 | 4/15/2021 2:19:58 PM             |
| 2.97 | 14.50 | -0.03 | 0.82 | 23.91 | 4/15/2021 2:20:58 PM             |
| 2.95 | 14.46 | -0.05 | 0.82 | 24.09 | 4/15/2021 2:21:59 PM             |
| 2.94 | 14.45 | -0.02 | 0.82 | 24.11 | 4/15/2021 2:22:59 PM             |
| 3.05 | 14.49 | -0.05 | 0.81 | 24.15 | 4/15/2021 2:23:59 PM             |
| 3.07 | 14.50 | -0.04 | 0.79 | 23.90 | 4/15/2021 2:25:00 PM             |
| 3.48 | 14.12 | -0.12 | 0.78 | 25.37 | 4/15/2021 2:26:00 PM             |
| 3.28 | 14.25 | -0.05 | 0.80 | 25.13 | 4/15/2021 2:27:01 PM             |
| 3.23 | 14.39 | -0.09 | 0.82 | 24.54 | 4/15/2021 2:28:01 PM             |
| 3.04 | 14.53 | -0.06 | 0.78 | 24.27 | 4/15/2021 2:29:02 PM             |
| 3.06 | 14.55 | -0.08 | 0.79 | 23.98 | 4/15/2021 2:30:02 PM             |
| 3.05 | 14.49 | -0.05 | 0.79 | 23.98 | 4/15/2021 2:31:03 PM             |
| 3.03 | 14.56 | -0.05 | 0.81 | 24.12 | 4/15/2021 2:32:03 PM             |
| 3.05 | 14.60 | -0.08 | 0.80 | 23.76 | 4/15/2021 2:33:03 PM             |

|      |       |       |       |       |                                           |
|------|-------|-------|-------|-------|-------------------------------------------|
| 3.07 | 14.57 | -0.05 | 0.80  | 23.91 | 4/15/2021 2:34:04 PM                      |
| 3.07 | 14.52 | -0.06 | 0.78  | 23.90 | 4/15/2021 2:35:04 PM                      |
| 2.74 | 14.82 | -0.06 | 1.32  | 23.84 | 4/15/2021 2:36:05 PM                      |
| 3.05 | 14.49 | -0.05 | 0.76  | 23.85 | 4/15/2021 2:37:05 PM                      |
| 3.38 | 14.18 | -0.11 | 0.81  | 24.60 | 4/15/2021 2:38:06 PM                      |
| 3.24 | 14.33 | -0.08 | 0.80  | 25.24 | 4/15/2021 2:39:06 PM                      |
| 3.14 | 14.35 | -0.05 | 0.77  | 25.15 | 4/15/2021 2:40:06 PM                      |
| 3.14 | 14.34 | -0.06 | 0.67  | 25.13 | 4/15/2021 2:41:07 PM                      |
| 3.05 | 14.47 | -0.09 | 0.70  | 25.16 | 4/15/2021 2:42:07 PM                      |
| 3.07 | 14.47 | 0.05  | 0.66  | 24.79 | 4/15/2021 2:43:07 PM                      |
| 3.32 | 14.21 | 0.23  | 0.67  | 25.18 | 4/15/2021 2:44:08 PM                      |
| 3.28 | 14.30 | 0.05  | 0.67  | 24.76 | 4/15/2021 2:45:08 PM Stop Run 1           |
| 3.26 | 14.29 | 0.01  | 0.81  | 24.73 | Avg                                       |
| 3.25 | 14.35 | 0.00  | 0.63  | 24.58 | 4/15/2021 2:46:09 PM                      |
| 3.21 | 14.30 | -0.02 | 0.62  | 24.62 | 4/15/2021 2:47:09 PM                      |
| 3.23 | 14.34 | -0.02 | 0.92  | 24.64 | 4/15/2021 2:48:10 PM                      |
| 1.29 | 16.64 | -0.08 | 0.65  | 22.90 | 4/15/2021 2:49:10 PM                      |
| 0.05 | 20.93 | -0.12 | 0.68  | 13.62 | 4/15/2021 2:50:10 PM                      |
| 0.05 | 20.94 | -0.09 | 0.74  | 0.15  | 4/15/2021 2:51:11 PM                      |
| 0.85 | 17.70 | -0.08 | 0.80  | 0.18  | 4/15/2021 2:52:11 PM                      |
| 9.49 | 10.39 | -0.20 | 0.72  | 0.35  | 4/15/2021 2:53:12 PM                      |
| 9.80 | 10.12 | -0.31 | 0.67  | 0.18  | 4/15/2021 2:54:12 PM O2 CO2 Bias Nox Zero |
| 9.76 | 10.14 | -0.31 | 0.67  | 0.13  | 4/15/2021 2:55:13 PM                      |
| 8.85 | 10.87 | -0.32 | 0.98  | 0.14  | 4/15/2021 2:56:13 PM                      |
| 0.10 | 5.50  | 1.29  | 0.80  | 0.13  | 4/15/2021 2:57:13 PM                      |
| 0.04 | 0.44  | 13.98 | 0.73  | 0.12  | 4/15/2021 2:58:14 PM                      |
| 0.03 | 0.26  | 14.06 | 0.72  | 0.13  | 4/15/2021 2:59:14 PM Co Bias CO2 O2 Zero  |
| 0.03 | 0.26  | 14.12 | 0.88  | 0.13  | 4/15/2021 3:00:15 PM                      |
| 0.02 | 9.54  | 12.06 | 15.26 | 0.13  | 4/15/2021 3:01:15 PM                      |
| 0.04 | 19.83 | 1.79  | 23.83 | 0.14  | 4/15/2021 3:02:16 PM                      |
| 0.05 | 20.93 | -0.10 | 24.08 | 0.14  | 4/15/2021 3:03:16 PM                      |
| 0.05 | 20.94 | -0.13 | 24.17 | 0.14  | 4/15/2021 3:04:16 PM VOC Bias CO Zero     |
| 0.04 | 20.94 | -0.11 | 20.11 | 0.14  | 4/15/2021 3:05:17 PM                      |
| 0.05 | 13.11 | -0.13 | 0.92  | 12.95 | 4/15/2021 3:06:17 PM                      |
| 0.05 | 0.46  | -0.14 | 0.81  | 23.29 | 4/15/2021 3:07:18 PM                      |
| 0.05 | 0.30  | -0.14 | 0.81  | 25.42 | 4/15/2021 3:08:18 PM                      |
| 0.04 | 0.30  | -0.19 | 0.80  | 25.36 | 4/15/2021 3:09:18 PM Nox Bias VOC Zero    |
| 0.05 | 1.30  | -0.16 | 1.06  | 25.18 | 4/15/2021 3:10:19 PM                      |
| 0.05 | 11.67 | -0.16 | 0.80  | 22.94 | 4/15/2021 3:11:19 PM                      |
| 0.05 | 20.72 | -0.06 | 0.73  | 12.62 | 4/15/2021 3:12:20 PM                      |
| 0.05 | 20.92 | -0.03 | 0.81  | 0.13  | 4/15/2021 3:13:20 PM                      |
| 0.05 | 20.92 | -0.06 | 0.81  | 0.13  | 4/15/2021 3:14:21 PM                      |
| 0.05 | 20.92 | -0.08 | 0.81  | 0.13  | 4/15/2021 3:15:21 PM                      |
| 0.05 | 20.92 | -0.05 | 0.81  | 0.13  | 4/15/2021 3:16:21 PM                      |
| 0.05 | 20.92 | -0.05 | 0.80  | 0.13  | 4/15/2021 3:17:22 PM                      |
| 0.05 | 20.92 | -0.03 | 0.81  | 0.13  | 4/15/2021 3:18:22 PM                      |
| 0.05 | 20.92 | -0.08 | 0.81  | 0.13  | 4/15/2021 3:19:23 PM                      |
| 0.05 | 20.92 | -0.09 | 0.81  | 0.13  | 4/15/2021 3:20:23 PM                      |
| 0.05 | 20.92 | -0.05 | 0.82  | 0.13  | 4/15/2021 3:21:23 PM                      |
| 0.05 | 20.92 | -0.06 | 0.81  | 0.13  | 4/15/2021 3:22:24 PM                      |
| 0.05 | 20.91 | -0.05 | 1.10  | 0.13  | 4/15/2021 3:23:24 PM                      |
| 2.55 | 14.96 | 0.07  | 0.89  | 17.86 | 4/15/2021 3:24:25 PM                      |
| 3.15 | 14.38 | 0.40  | 0.71  | 23.84 | 4/15/2021 3:25:25 PM                      |
| 3.63 | 13.89 | 0.39  | 0.70  | 25.15 | 4/15/2021 3:26:26 PM                      |
| 3.48 | 13.97 | 0.35  | 0.63  | 25.13 | 4/15/2021 3:27:26 PM Start Run 2          |
| 3.52 | 13.96 | 0.26  | 0.63  | 24.87 | 4/15/2021 3:28:27 PM                      |
| 3.45 | 14.00 | 0.23  | 0.63  | 24.72 | 4/15/2021 3:29:27 PM                      |
| 3.65 | 14.06 | 0.20  | 0.63  | 24.54 | 4/15/2021 3:30:27 PM                      |
| 3.47 | 14.11 | 0.17  | 0.64  | 24.34 | 4/15/2021 3:31:28 PM                      |
| 3.40 | 14.17 | 0.20  | 0.66  | 24.24 | 4/15/2021 3:32:28 PM                      |
| 3.30 | 14.27 | 0.17  | 0.64  | 24.03 | 4/15/2021 3:33:29 PM                      |

|      |       |       |      |       |                      |
|------|-------|-------|------|-------|----------------------|
| 3.33 | 14.16 | 0.17  | 0.64 | 24.07 | 4/15/2021 3:34:29 PM |
| 3.30 | 14.24 | 0.18  | 0.67 | 24.25 | 4/15/2021 3:35:29 PM |
| 3.35 | 14.22 | 0.19  | 0.65 | 23.97 | 4/15/2021 3:36:30 PM |
| 3.36 | 14.18 | 0.18  | 0.66 | 24.31 | 4/15/2021 3:37:30 PM |
| 3.32 | 14.16 | 0.20  | 0.65 | 24.29 | 4/15/2021 3:38:31 PM |
| 3.33 | 14.17 | 0.17  | 0.67 | 24.37 | 4/15/2021 3:39:31 PM |
| 3.25 | 14.27 | 0.15  | 0.72 | 24.20 | 4/15/2021 3:40:32 PM |
| 3.21 | 14.37 | 0.17  | 0.74 | 23.93 | 4/15/2021 3:41:32 PM |
| 3.09 | 14.53 | 0.17  | 0.74 | 23.45 | 4/15/2021 3:42:32 PM |
| 3.05 | 14.49 | 0.19  | 0.78 | 23.44 | 4/15/2021 3:43:33 PM |
| 2.83 | 14.74 | 0.14  | 0.81 | 23.16 | 4/15/2021 3:44:33 PM |
| 2.62 | 14.90 | 0.15  | 0.83 | 22.67 | 4/15/2021 3:45:34 PM |
| 2.52 | 15.03 | 0.14  | 0.89 | 23.34 | 4/15/2021 3:46:34 PM |
| 3.03 | 14.42 | 0.14  | 0.94 | 23.74 | 4/15/2021 3:47:34 PM |
| 3.07 | 14.43 | 0.12  | 0.99 | 24.04 | 4/15/2021 3:48:35 PM |
| 2.87 | 14.67 | 0.11  | 1.02 | 24.10 | 4/15/2021 3:49:35 PM |
| 3.05 | 14.95 | 0.09  | 1.07 | 24.29 | 4/15/2021 3:50:36 PM |
| 3.48 | 15.08 | 0.08  | 1.06 | 23.71 | 4/15/2021 3:51:36 PM |
| 3.48 | 15.09 | 0.05  | 1.14 | 23.83 | 4/15/2021 3:52:37 PM |
| 3.05 | 14.51 | 0.08  | 1.18 | 24.28 | 4/15/2021 3:53:37 PM |
| 2.90 | 14.69 | 0.09  | 1.26 | 24.63 | 4/15/2021 3:54:37 PM |
| 2.48 | 15.02 | 0.03  | 1.25 | 24.89 | 4/15/2021 3:55:38 PM |
| 3.50 | 14.92 | 0.02  | 1.25 | 24.68 | 4/15/2021 3:56:38 PM |
| 2.48 | 14.99 | 0.07  | 1.32 | 24.84 | 4/15/2021 3:57:39 PM |
| 3.21 | 14.32 | 0.05  | 1.35 | 24.26 | 4/15/2021 3:58:39 PM |
| 3.03 | 14.46 | 0.04  | 1.34 | 24.57 | 4/15/2021 3:59:39 PM |
| 3.11 | 14.41 | 0.05  | 1.29 | 24.65 | 4/15/2021 4:00:40 PM |
| 3.33 | 14.12 | 0.04  | 1.32 | 25.06 | 4/15/2021 4:01:40 PM |
| 3.02 | 14.47 | 0.04  | 1.39 | 24.89 | 4/15/2021 4:02:41 PM |
| 2.97 | 14.68 | 0.02  | 1.41 | 25.07 | 4/15/2021 4:03:41 PM |
| 2.97 | 14.68 | 0.01  | 1.44 | 24.82 | 4/15/2021 4:04:42 PM |
| 2.85 | 14.77 | 0.04  | 1.49 | 24.90 | 4/15/2021 4:05:42 PM |
| 2.66 | 14.82 | 0.06  | 1.43 | 24.46 | 4/15/2021 4:06:43 PM |
| 2.73 | 14.78 | 0.09  | 1.53 | 24.71 | 4/15/2021 4:07:43 PM |
| 2.54 | 15.04 | 0.07  | 1.53 | 25.24 | 4/15/2021 4:08:43 PM |
| 2.53 | 15.03 | 0.06  | 1.56 | 25.09 | 4/15/2021 4:09:44 PM |
| 2.42 | 15.10 | 0.02  | 1.57 | 24.95 | 4/15/2021 4:10:44 PM |
| 2.38 | 15.17 | 0.01  | 1.53 | 24.64 | 4/15/2021 4:11:45 PM |
| 2.33 | 15.09 | 0.02  | 1.57 | 24.95 | 4/15/2021 4:12:45 PM |
| 2.23 | 15.29 | 0.02  | 1.62 | 24.67 | 4/15/2021 4:13:45 PM |
| 2.11 | 15.41 | 0.03  | 1.57 | 24.14 | 4/15/2021 4:14:46 PM |
| 2.27 | 15.25 | 0.02  | 1.61 | 24.48 | 4/15/2021 4:15:46 PM |
| 2.51 | 15.14 | 0.02  | 1.60 | 24.26 | 4/15/2021 4:16:47 PM |
| 2.51 | 14.94 | -0.02 | 1.61 | 24.24 | 4/15/2021 4:17:47 PM |
| 2.60 | 14.84 | -0.02 | 1.62 | 24.13 | 4/15/2021 4:18:48 PM |
| 2.71 | 14.84 | 0.01  | 1.62 | 24.09 | 4/15/2021 4:19:48 PM |
| 2.62 | 14.84 | 0.00  | 1.65 | 24.19 | 4/15/2021 4:20:48 PM |
| 2.62 | 14.85 | 0.00  | 1.73 | 24.22 | 4/15/2021 4:21:49 PM |
| 2.82 | 14.66 | 0.00  | 1.78 | 24.61 | 4/15/2021 4:22:49 PM |
| 2.64 | 14.84 | 0.01  | 1.78 | 24.20 | 4/15/2021 4:23:50 PM |
| 2.73 | 14.79 | 0.00  | 1.79 | 24.13 | 4/15/2021 4:24:50 PM |
| 2.71 | 14.78 | 0.01  | 1.76 | 24.03 | 4/15/2021 4:25:51 PM |
| 2.73 | 14.76 | 0.04  | 1.81 | 24.29 | 4/15/2021 4:26:51 PM |
| 2.52 | 14.95 | -0.01 | 1.79 | 24.86 | 4/15/2021 4:27:51 PM |
| 2.93 | 14.65 | 0.09  | 1.20 | 24.35 | Stop Run 2<br>Avg    |
| 2.54 | 14.93 | 0.01  | 1.79 | 24.79 | 4/15/2021 4:28:52 PM |
| 2.57 | 14.89 | 0.01  | 1.80 | 24.78 | 4/15/2021 4:29:52 PM |
| 2.60 | 14.88 | 0.00  | 1.79 | 24.93 | 4/15/2021 4:30:53 PM |
| 2.64 | 14.83 | 0.00  | 1.77 | 24.96 | 4/15/2021 4:31:53 PM |
| 2.84 | 14.74 | 0.01  | 1.78 | 24.22 | 4/15/2021 4:32:53 PM |
| 2.75 | 14.79 | 0.02  | 1.81 | 24.26 | 4/15/2021 4:33:54 PM |
| 1.05 | 18.93 | -0.02 | 9.26 | 12.87 | 4/15/2021 4:34:54 PM |

|      |       |       |       |       |                                           |
|------|-------|-------|-------|-------|-------------------------------------------|
| 0.03 | 20.92 | 0.01  | 24.74 | 0.46  | 4/15/2021 4:35:55 PM                      |
| 0.02 | 20.93 | -0.02 | 24.73 | 0.13  | 4/15/2021 4:36:55 PM VOC Bias CO Zero     |
| 0.01 | 20.93 | -0.06 | 20.93 | 0.13  | 4/15/2021 4:37:56 PM                      |
| 0.01 | 14.60 | 0.23  | 0.67  | 0.13  | 4/15/2021 4:38:56 PM                      |
| 0.01 | 1.44  | 6.43  | 0.63  | 0.13  | 4/15/2021 4:39:56 PM                      |
| 0.01 | 0.27  | 14.41 | 0.59  | 0.13  | 4/15/2021 4:40:57 PM                      |
| 0.01 | 0.28  | 14.42 | 0.53  | 0.14  | 4/15/2021 4:41:57 PM Co Bias CO2 O2 Zero  |
| 0.00 | 0.31  | 14.23 | 0.61  | 0.14  | 4/15/2021 4:42:58 PM                      |
| 0.86 | 7.00  | 11.15 | 0.46  | 0.14  | 4/15/2021 4:43:58 PM                      |
| 9.02 | 9.90  | 0.23  | 0.44  | 0.14  | 4/15/2021 4:44:58 PM                      |
| 9.64 | 9.91  | -0.44 | 0.43  | 0.14  | 4/15/2021 4:45:59 PM O2 CO2 Bias Nox Zero |
| 9.63 | 9.91  | -0.44 | 0.42  | 0.15  | 4/15/2021 4:46:59 PM                      |
| 9.22 | 9.23  | -0.45 | 0.72  | 1.06  | 4/15/2021 4:48:00 PM                      |
| 1.40 | 1.98  | -0.37 | 0.54  | 21.83 | 4/15/2021 4:49:00 PM                      |
| 0.05 | 0.22  | -0.20 | 0.52  | 25.86 | 4/15/2021 4:50:01 PM                      |
| 0.05 | 0.21  | -0.22 | 0.50  | 25.92 | 4/15/2021 4:51:01 PM Nox Bias VOC Zero    |
| 0.05 | 0.34  | -0.18 | 0.79  | 25.79 | 4/15/2021 4:52:01 PM                      |
| 0.05 | 12.28 | -0.17 | 0.85  | 22.64 | 4/15/2021 4:53:02 PM                      |
| 0.05 | 20.72 | -0.09 | 0.84  | 1.52  | 4/15/2021 4:54:02 PM                      |
| 0.05 | 20.92 | -0.14 | 0.81  | 0.13  | 4/15/2021 4:55:03 PM                      |
| 0.05 | 20.92 | -0.09 | 0.81  | 0.13  | 4/15/2021 4:56:03 PM                      |
| 0.05 | 20.92 | -0.08 | 0.81  | 0.13  | 4/15/2021 4:57:03 PM                      |
| 0.05 | 20.92 | -0.05 | 0.81  | 0.13  | 4/15/2021 4:58:04 PM                      |
| 0.05 | 20.92 | -0.12 | 0.79  | 0.13  | 4/15/2021 4:59:04 PM                      |
| 1.22 | 17.50 | -0.04 | 0.85  | 1.59  | 4/15/2021 5:00:05 PM                      |
| 3.74 | 13.81 | 0.57  | 0.82  | 23.73 | 4/15/2021 5:01:05 PM                      |
| 3.75 | 13.71 | 2.68  | 0.79  | 26.16 | 4/15/2021 5:02:06 PM                      |
| 3.75 | 13.76 | 3.44  | 0.72  | 26.14 | 4/15/2021 5:03:06 PM                      |
| 3.81 | 13.71 | 2.30  | 0.72  | 25.90 | 4/15/2021 5:04:07 PM Start Run 3          |
| 3.80 | 13.74 | 1.41  | 0.72  | 25.76 | 4/15/2021 5:05:07 PM                      |
| 3.80 | 13.72 | 0.96  | 0.72  | 25.67 | 4/15/2021 5:06:07 PM                      |
| 3.80 | 13.72 | 0.69  | 0.71  | 25.35 | 4/15/2021 5:07:08 PM                      |
| 3.81 | 13.71 | 0.53  | 0.71  | 25.32 | 4/15/2021 5:08:08 PM                      |
| 3.79 | 13.72 | 0.54  | 0.71  | 25.20 | 4/15/2021 5:09:09 PM                      |
| 3.77 | 13.72 | 0.42  | 0.69  | 25.10 | 4/15/2021 5:10:09 PM                      |
| 3.77 | 13.73 | 0.38  | 0.68  | 24.96 | 4/15/2021 5:11:10 PM                      |
| 3.80 | 13.72 | 0.29  | 0.72  | 24.85 | 4/15/2021 5:12:10 PM                      |
| 3.80 | 13.72 | 0.31  | 0.70  | 24.89 | 4/15/2021 5:13:10 PM                      |
| 3.75 | 13.70 | 0.25  | 0.71  | 24.81 | 4/15/2021 5:14:11 PM                      |
| 3.79 | 13.70 | 0.25  | 0.71  | 24.92 | 4/15/2021 5:15:11 PM                      |
| 3.85 | 13.68 | 0.22  | 0.71  | 24.77 | 4/15/2021 5:16:11 PM                      |
| 3.78 | 13.73 | 0.25  | 0.71  | 24.86 | 4/15/2021 5:17:12 PM                      |
| 3.77 | 13.72 | 0.25  | 0.71  | 24.73 | 4/15/2021 5:18:12 PM                      |
| 3.78 | 13.72 | 0.17  | 0.72  | 24.90 | 4/15/2021 5:19:13 PM                      |
| 3.84 | 13.68 | 0.15  | 0.72  | 24.92 | 4/15/2021 5:20:13 PM                      |
| 3.80 | 13.73 | 0.17  | 0.71  | 24.86 | 4/15/2021 5:21:14 PM                      |
| 3.80 | 13.75 | 0.15  | 0.71  | 24.76 | 4/15/2021 5:22:14 PM                      |
| 3.73 | 13.75 | 0.16  | 0.69  | 24.73 | 4/15/2021 5:23:15 PM                      |
| 3.65 | 13.75 | 0.14  | 0.72  | 24.71 | 4/15/2021 5:24:15 PM                      |
| 3.62 | 13.77 | 0.15  | 0.71  | 24.86 | 4/15/2021 5:25:15 PM                      |
| 3.63 | 13.81 | 0.12  | 0.70  | 24.81 | 4/15/2021 5:26:16 PM                      |
| 3.50 | 13.84 | 0.15  | 0.72  | 24.82 | 4/15/2021 5:27:16 PM                      |
| 3.50 | 13.85 | 0.13  | 0.72  | 24.73 | 4/15/2021 5:28:17 PM                      |
| 3.61 | 13.84 | 0.10  | 0.70  | 24.80 | 4/15/2021 5:29:17 PM                      |
| 3.49 | 13.85 | 0.12  | 0.67  | 24.80 | 4/15/2021 5:30:18 PM                      |
| 3.57 | 13.92 | 0.05  | 0.67  | 24.75 | 4/15/2021 5:31:18 PM                      |
| 3.54 | 13.87 | 0.05  | 0.69  | 24.70 | 4/15/2021 5:32:18 PM                      |
| 3.51 | 13.96 | 0.11  | 0.70  | 24.73 | 4/15/2021 5:33:19 PM                      |
| 3.53 | 13.93 | 0.07  | 0.68  | 24.63 | 4/15/2021 5:34:19 PM                      |
| 3.53 | 13.92 | 0.12  | 0.68  | 24.76 | 4/15/2021 5:35:20 PM                      |
| 3.51 | 13.99 | 0.11  | 0.67  | 24.55 | 4/15/2021 5:36:20 PM                      |
| 3.52 | 13.94 | 0.09  | 0.71  | 24.66 | 4/15/2021 5:37:20 PM                      |

|      |       |       |       |       |                      |                      |
|------|-------|-------|-------|-------|----------------------|----------------------|
| 3.44 | 13.96 | 0.08  | 0.67  | 24.70 | 4/15/2021 5:38:21 PM |                      |
| 3.52 | 14.00 | 0.08  | 0.69  | 24.59 | 4/15/2021 5:39:21 PM |                      |
| 3.40 | 14.03 | 0.09  | 0.65  | 24.55 | 4/15/2021 5:40:22 PM |                      |
| 3.42 | 14.04 | 0.04  | 0.65  | 24.43 | 4/15/2021 5:41:22 PM |                      |
| 3.41 | 14.07 | 0.05  | 0.67  | 24.53 | 4/15/2021 5:42:22 PM |                      |
| 3.40 | 14.17 | 0.01  | 0.69  | 24.34 | 4/15/2021 5:43:23 PM |                      |
| 3.29 | 14.21 | 0.04  | 0.71  | 24.20 | 4/15/2021 5:44:23 PM |                      |
| 3.03 | 14.40 | 0.02  | 0.70  | 23.84 | 4/15/2021 5:45:24 PM |                      |
| 3.15 | 14.40 | 0.00  | 0.71  | 23.86 | 4/15/2021 5:46:24 PM |                      |
| 2.87 | 14.57 | -0.02 | 0.71  | 23.38 | 4/15/2021 5:47:25 PM |                      |
| 2.83 | 14.59 | -0.03 | 0.72  | 23.39 | 4/15/2021 5:48:25 PM |                      |
| 2.81 | 14.60 | -0.02 | 0.73  | 23.25 | 4/15/2021 5:49:25 PM |                      |
| 2.82 | 14.63 | -0.03 | 0.72  | 23.15 | 4/15/2021 5:50:26 PM |                      |
| 2.71 | 14.75 | -0.01 | 0.68  | 23.17 | 4/15/2021 5:51:26 PM |                      |
| 2.83 | 14.60 | 0.00  | 0.74  | 22.97 | 4/15/2021 5:52:27 PM |                      |
| 2.60 | 14.82 | -0.03 | 0.76  | 23.03 | 4/15/2021 5:53:27 PM |                      |
| 2.59 | 14.82 | -0.04 | 0.74  | 22.63 | 4/15/2021 5:54:28 PM |                      |
| 2.53 | 14.81 | -0.03 | 0.76  | 22.87 | 4/15/2021 5:55:28 PM |                      |
| 2.55 | 14.86 | -0.03 | 0.79  | 22.69 | 4/15/2021 5:56:28 PM |                      |
| 2.55 | 14.89 | -0.04 | 0.77  | 22.45 | 4/15/2021 5:57:29 PM |                      |
| 2.55 | 14.90 | 0.00  | 0.77  | 22.83 | 4/15/2021 5:58:29 PM |                      |
| 2.53 | 14.81 | -0.03 | 0.77  | 22.54 | 4/15/2021 5:59:30 PM |                      |
| 2.57 | 14.78 | 0.00  | 0.82  | 22.99 | 4/15/2021 6:00:30 PM |                      |
| 2.43 | 14.99 | -0.03 | 0.81  | 22.45 | 4/15/2021 6:01:31 PM |                      |
| 2.46 | 15.02 | -0.01 | 0.87  | 22.55 | 4/15/2021 6:02:31 PM |                      |
| 2.11 | 15.43 | -0.03 | 0.88  | 21.67 | 4/15/2021 6:03:32 PM |                      |
| 2.09 | 15.35 | -0.02 | 0.83  | 21.34 | 4/15/2021 6:04:32 PM | Stop Run 3           |
| 3.31 | 14.15 | 0.19  | 0.72  | 24.20 |                      | Avg                  |
| 2.31 | 15.03 | -0.02 | 0.84  | 21.85 | 4/15/2021 6:05:32 PM |                      |
| 2.15 | 15.29 | -0.03 | 0.89  | 22.32 | 4/15/2021 6:06:33 PM |                      |
| 1.89 | 15.58 | -0.06 | 1.10  | 21.16 | 4/15/2021 6:07:33 PM |                      |
| 0.87 | 16.90 | -0.05 | 2.02  | 20.38 | 4/15/2021 6:08:34 PM |                      |
| 0.05 | 20.81 | -0.05 | 1.99  | 1.13  | 4/15/2021 6:09:34 PM |                      |
| 0.05 | 17.69 | -0.09 | 1.07  | 0.36  | 4/15/2021 6:10:34 PM |                      |
| 0.05 | 5.50  | -0.11 | 0.81  | 8.81  | 4/15/2021 6:11:35 PM |                      |
| 0.05 | 0.53  | -0.10 | 0.81  | 24.51 | 4/15/2021 6:12:35 PM |                      |
| 0.05 | 0.35  | -0.10 | 0.81  | 24.92 | 4/15/2021 6:13:36 PM |                      |
| 0.05 | 0.28  | -0.10 | 0.74  | 24.87 | 4/15/2021 6:14:36 PM | Nox Bias VOC Zero    |
| 0.05 | 0.21  | -0.10 | 0.92  | 24.91 | 4/15/2021 6:15:37 PM |                      |
| 0.05 | 6.85  | -0.09 | 0.63  | 24.03 | 4/15/2021 6:16:37 PM |                      |
| 1.22 | 10.27 | -0.15 | 0.63  | 14.15 | 4/15/2021 6:17:37 PM |                      |
| 9.61 | 10.15 | -0.31 | 0.63  | 0.22  | 4/15/2021 6:18:38 PM |                      |
| 9.62 | 10.14 | -0.25 | 0.63  | 0.20  | 4/15/2021 6:19:38 PM |                      |
| 9.62 | 10.08 | -0.29 | 0.63  | 0.13  | 4/15/2021 6:20:38 PM | O2 CO2 Bias Nox Zero |
| 9.62 | 10.07 | -0.24 | 0.70  | 0.13  | 4/15/2021 6:21:39 PM |                      |
| 8.48 | 10.75 | 0.16  | 1.69  | 0.15  | 4/15/2021 6:22:39 PM |                      |
| 0.05 | 19.55 | 0.60  | 24.83 | 0.15  | 4/15/2021 6:23:40 PM |                      |
| 0.05 | 20.92 | 0.00  | 24.87 | 0.13  | 4/15/2021 6:24:40 PM |                      |
| 0.05 | 20.92 | 0.00  | 24.92 | 0.13  | 4/15/2021 6:25:41 PM | VOC Bias CO Zero     |
| 0.05 | 20.92 | 0.09  | 24.91 | 0.19  | 4/15/2021 6:26:41 PM |                      |
| 0.05 | 20.93 | 0.10  | 24.86 | 0.17  | 4/15/2021 6:27:42 PM |                      |
| 0.05 | 11.73 | 6.06  | 1.87  | 0.13  | 4/15/2021 6:28:42 PM |                      |
| 0.04 | 0.45  | 14.40 | 0.97  | 0.13  | 4/15/2021 6:29:42 PM |                      |
| 0.04 | 0.24  | 14.40 | 0.90  | 0.14  | 4/15/2021 6:30:43 PM | Co Bias CO2 O2 Zero  |
| 0.05 | 0.24  | 14.40 | 0.90  | 0.14  | 4/15/2021 6:31:43 PM |                      |
| 0.04 | 0.23  | 14.40 | 0.91  | 0.14  | 4/15/2021 6:32:44 PM |                      |
| 0.04 | 8.46  | 6.02  | 0.93  | 0.14  | 4/15/2021 6:33:44 PM |                      |
| 0.04 | 20.17 | 0.02  | 0.92  | 0.14  | 4/15/2021 6:34:45 PM |                      |
| 0.04 | 20.92 | 0.00  | 0.91  | 0.14  | 4/15/2021 6:35:45 PM |                      |
| 0.04 | 20.92 | -0.05 | 0.90  | 0.14  | 4/15/2021 6:36:45 PM |                      |


## **Appendix #5**

### **Process Data**

# ACCUTHERM RAMP CHART

Run Start Date: 4/13/2021

Run # CB1-10321



**Public Notice**  
**Ohio Environmental Protection Agency**  
**Draft State Implementation Plan**  
**VOC Reasonably Available Control Technology (RACT)**  
**for Meggitt Aircraft Braking Systems Corp. (Facility ID1677010999)**

**Summit County**

Notice is hereby given that the Director of the Ohio Environmental Protection Agency, (Ohio EPA) is submitting to the United States Environmental Protection Agency (U.S. EPA) Reasonably Available Control Technology (RACT) for Meggitt Aircraft Braking Systems Corp, LLC (Facility ID 1677010999) for approval into Ohio's state implementation plan (SIP) for the 2015 ozone National Ambient Air Quality Standard (NAAQS).

On March 17, 2025, Ohio submitted a revision to Ohio's SIP to address RACT requirements for the 2015 8-hour ozone NAAQS. As noted in this submittal, Ohio Administrative Code (OAC) rule 3745-21-11(B) requires facilities that have the potential to emit of fifty tons per year or more, but less than one hundred tons per year of volatile organic compounds (VOC) and are located in nonattainment counties to submit a RACT study for sources not controlled by Ohio's Control Technique Guideline (CTG) regulations in OAC Chapter 3745-21 or by categorical non-CTG RACT in OAC rules 3745-21-12, 3745-21-14, 3745-21-16, 3745-21-21 and 3745-21-25.

Ohio is now submitting source-specific VOC RACT for Meggitt Aircraft Braking Systems Corp (Facility ID 1677010999) for approval into Ohio's SIP. This facility is located in the Cleveland 2015 ozone maintenance area and has no prior existing source-specific RACT established in OAC rule 3745-21-09.

The updated RACT Study was submitted per OAC rule 3745-21-11(B). Ohio has determined that the updated RACT study, along with supplemental information submitted subsequently, is sufficient to justify the continued use of the existing thermal oxidizer with an overall control efficiency of at least 99% pursuant to OAC rule 3745-31-05(D) proposed by the facility to act as RACT for the carbon furnaces under the 2015 ozone standard.

Ohio EPA is now requesting approval of the proposed RACT for Meggitt Aircraft Braking Systems Corp into Ohio's SIP.

Ohio EPA is seeking public comment to satisfy U.S. EPA requirements for public involvement in SIP related activities in accordance with 40 CFR 51.102.

The public comment period will run until October 12, 2026. Written comments should be submitted at: <https://ohioepa.commentinput.com> - Search by entering the permit # (P0129464 for Meggitt Aircraft Braking Systems Corp) in the "Search Projects" search box.

A public hearing on this action may be requested by contacting Kathryn Jobe at 614-728-0671 or [kathryn.jobe@epa.ohio.gov](mailto:kathryn.jobe@epa.ohio.gov) no later than 30 days from the draft public notice. If a public hearing is requested, a new notification will be published to identify the time and location of the public hearing. The public hearing will be held at least 30 days after the date of the new notification.

All interested persons are entitled to comment on these changes. All comments submitted to the above address by the close of business 30 days from when the draft public notice is issued will be considered by Ohio EPA prior to final action on this action. Written statements submitted after this time period may be considered as time and circumstances permit but will not be part of the official record.

Questions or comments about this document should be directed to Kathryn Jobe at 614-728-0671 or [kathryn.jobe@epa.ohio.gov](mailto:kathryn.jobe@epa.ohio.gov).



**DATE**

Ms. Anne Vogel  
Regional Administrator  
U.S. EPA, Region 5  
77 West Jackson Blvd.  
Chicago, Illinois 60604

**Re: Revision to Ohio's Reasonably Available Control Technology (RACT) State Implementation Plan for the 2015 Ozone National Ambient Air Quality Standards – Source-Specific Volatile Organic Compound (VOC) RACT for Meggitt Aircraft Braking Systems Corp. (Facility ID 1677010999)**

Dear Administrator Vogel:

On March 17, 2025, Ohio submitted a revision to Ohio's State Implementation Plan (SIP) to address Reasonably Available Control Technology (RACT) requirements for the 2015 8-hour ozone National Ambient Air Quality Standards (NAAQS) for areas classified as serious. As noted in this submittal, Ohio EPA adopted requirements in Ohio Administrative Code (OAC) rule 3745-21-11 for facilities in the nonattainment areas that emit fifty tons per year or more, but less than one hundred tons per year of volatile organic compounds (VOC) from sources not controlled by Ohio's CTG regulations in OAC Chapter 3745-21 or by categorical non-CTG RACT in OAC rules 3745-21-12, 3745-21-14, 3745-21-16, 3745-21-21 and 3745-21-25 to submit an updated RACT study within one year of the effective date of the rule. Upon review of the RACT study, Ohio EPA evaluated if the RACT proposed by the facility is appropriate to satisfy RACT requirements under the 2015 ozone standard.

Ohio is now submitting source-specific VOC RACT for Meggitt Aircraft Braking Systems Corp. (Facility ID 1677010999) for approval into Ohio's SIP. This facility is located in the Cleveland 2015 ozone maintenance area and has no prior existing source-specific RACT established in OAC rule 3745-21-09.

The updated VOC RACT Study was submitted per OAC rule 3745-21-11. Ohio has determined that the updated RACT study, along with supplemental information submitted subsequently, is sufficient to justify the continued use of the existing thermal oxidizer with an overall control efficiency of at least 99% pursuant to OAC rule 3745-31-05(D) proposed by the facility to act as RACT for the carbon furnaces under the 2015 ozone standard. The RACT study is provided in Appendix A, and the permit that incorporated RACT is provided as Appendix B. Within the permit, we have

highlighted the terms and conditions associated with RACT and request only those provisions are subject to this SIP revision request. Appendix C provides the permit strategy write-up for the permit.

Ohio held a public comment period on Ohio's RACT determination from September 10 to October 12, 2026. Appendix D contains the public notice. ***[Ohio's response to comments received during the public comment period is in Appendix E/No comments were received during the public comment period].***

This SIP does not include the relaxation of any existing requirements and therefore will not interfere with the attainment or maintenance of the NAAQS in accordance with section 110(l) of the CAA.

Ohio EPA is now requesting approval of the proposed RACT for Meggitt Aircraft Braking Systems Corp. into Ohio's SIP.

Ohio EPA is submitting this SIP via U.S. EPA's State Planning Electronic Collaboration System (SPECS). If you have questions, please contact Jennifer Van Vlerah in our Division of Air Pollution Control at (614) 644-3696.

Sincerely,

John Logue  
Director

Cc: Bob Hodanbosi, Chief, Division of Air Pollution Control, Ohio EPA

Enclosures

# **VOC RACT STUDY CARBON PROCESSING FURNACES**



**Meggitt Aircraft Braking Systems Corporation**

**Prepared By:**

**TRINITY CONSULTANTS**

400 Polaris Parkway  
Suite 275  
Westerville, Ohio 43082

|                     |            |
|---------------------|------------|
| Initial Submission: | March 2026 |
| Revision 1:         | May 2026   |
| Revision 2:         | July 2026  |

Project 253601.0166



## TABLE OF CONTENTS

---

|                                                                                            |            |
|--------------------------------------------------------------------------------------------|------------|
| <b>1. BACKGROUND</b>                                                                       | <b>1-1</b> |
| <b>2. FACILITY OVERVIEW</b>                                                                | <b>2-1</b> |
| 2.1 General Facility Information .....                                                     | 2-1        |
| 2.2 Permitted VOC Sources .....                                                            | 2-2        |
| <b>3. RACT DETERMINATION</b>                                                               | <b>A-1</b> |
| 3.1 Source Overview .....                                                                  | A-1        |
| 3.2 Control Overview .....                                                                 | A-1        |
| 3.3 Source Modification/Replacement .....                                                  | A-2        |
| 3.4 RACT Determination .....                                                               | A-3        |
| <b>APPENDIX A. POTENTIAL-TO-EMIT DOCUMENTATION</b>                                         | <b>A-4</b> |
| <b>APPENDIX B. SOURCE INFORMATION</b>                                                      | <b>B-1</b> |
| <b>APPENDIX C. THERMAL OXIDIZER STACK TEST RESULTS</b>                                     | <b>C-1</b> |
| <br><b>LIST OF FIGURES</b>                                                                 |            |
| Figure 2-1. Area Map for Meggitt                                                           | 2-1        |
| <br><b>LIST OF TABLES</b>                                                                  |            |
| Table 2-1. PTIO Permitted VOC Sources at the Akron Facility <sup>a</sup>                   | 2-3        |
| <br><b>APPENDIX: LIST OF FIGURES</b>                                                       |            |
| Appendix Figure B-1. Facility Plot Plan                                                    | B-4        |
| <br><b>APPENDIX: LIST OF TABLES</b>                                                        |            |
| Appendix Table B-1. General Source Information                                             | B-1        |
| Appendix Table B-2. Annual Production Rates for 2022-2024                                  | B-2        |
| Appendix Table B-3. Average and Maximum Daily and Annual Actual VOC Emissions <sup>a</sup> | B-3        |

## 1. BACKGROUND

---

On March 17, 2022, Ohio EPA promulgated revisions to the existing volatile organic compound (VOC) regulations under Chapter 3745-21 of the Ohio Administrative Code (OAC) due to the downgrade to moderate nonattainment status for the Cleveland area with respect to the 2015 8-hr Ozone National Ambient Air Quality Standard (NAAQS) as well as the change to marginal nonattainment status for the Cincinnati area.

Changes in the revised standards include but are not limited to:

- Extension of existing VOC Reasonably Available Control Technology (RACT) rules in OAC 3745-21 to the Cincinnati area; and
- Requirement for major VOC emitters (from non-control technique guidelines (CTG) sources) in the Cincinnati and Cleveland areas to conduct a detailed engineering study pursuant to OAC 3745-21-11.

Chapter 3745-21-11 requires facilities located in Butler, Clermont, Cuyahoga, Geauga, Hamilton, Lake, Lorain, Medina, Portage, Summit, or Warren County that have potential VOC emissions greater than 100 tons per year (tpy) from non-CTG sources to conduct a detailed engineering study to determine the technical and economic feasibility of reducing VOC emissions and define RACT for the affected sources. Additionally, it requires that any facility that has an existing site-specific definition of RACT in Chapter 3745-12-09 of the OAC submit an updated RACT study. In both cases the engineering study must be submitted to Ohio EPA within one (1) year of the effective date of the rule (i.e., by March 27, 2023).

On April 1, 2025, Ohio EPA promulgated revisions to the existing volatile organic compound (VOC) regulations under Chapter 3745-21 of the Ohio Administrative Code (OAC) following the classification of the Cleveland area to serious nonattainment status for the 2015 8-hr Ozone NAAQS in the Cleveland area.

Changes included in the revised standards include but are not limited to:

- ▶ Requirement for major VOC emitters (from non-CTG sources) in the Cleveland area to conduct a detailed engineering study pursuant to OAC 3745-21-11.

Chapter 3745-21-11 requires facilities located in Cuyahoga, Geauga, Lake, Lorain, Medina, Portage, or Summit County that have potential VOC emissions greater than 50 tpy from non-CTG sources to conduct a detailed engineering study to determine the technical and economic feasibility of reducing VOC emissions and define RACT for the affected sources. Additionally, it requires that any facility that has an existing site-specific definition of RACT in Chapter 3745-12-09 of the OAC submit an updated RACT study. In both cases the engineering study must be submitted to Ohio EPA within one (1) year of the effective date of the rule (i.e., by April 1, 2026).

Meggitt Aircraft and Braking Systems Corporation's manufacturing facility located in Akron, Ohio, is subject to a non-CTG RACT determination pursuant to OAC 3745-21-11. Accordingly, the facility is required to submit a VOC RACT study by April 1, 2026. The following sections comprise the required VOC RACT study for the Meggitt Aircraft Braking Systems Corporation Akron, Ohio Facility.

## 2. FACILITY OVERVIEW

### 2.1 General Facility Information

Meggitt Aircraft Braking Systems Corporation (Meggitt) owns and operates an aircraft parts and auxiliary equipment manufacturing facility Summit County. The facility is located at 1204 Massillon Road, Akron, Ohio 44306. The Akron Facility manufactures advanced aircraft braking systems. These include:

- ▶ Wheels
- ▶ Carbon brakes
- ▶ Brake control systems
- ▶ Landing gear components.

Figure 2-1 is an area map that shows the site location relative to predominant geographical features such as highways and railroads.

**Figure 2-1. Area Map for Meggitt**



Facility information required by sections (1) through (4) of OAC 3745-21-11(B) is provided as follows:

- a) The complete facility name, Ohio EPA air program facility identification number, and address:

*Meggitt Aircraft Braking System Corporation  
Facility ID 1677010999  
1204 Massillon Road  
Akron, OH 44306*

- b) The name, title, address and telephone number of the owner or operator's representative within the company who is the contact person for this facility regarding the engineering study and affected sources, and

*Gary Scotton*  
*EHS Manager*  
*1204 Massillon Road*  
*Akron, OH 44306*  
*(330) 796-5933*  
[Gary.Scotton@parker.com](mailto:Gary.Scotton@parker.com)

- c) The name, title, address, and telephone number of the official who is responsible for approval of the engineering study:

*Patrick Sines*  
*Senior Manager, Site Operations*  
*1204 Massillon Road*  
*Akron, OH 44306*  
*(330) 208-3634*  
[Patrick.Sines@parker.com](mailto:Patrick.Sines@parker.com)

- d) The standard industrial classification code and source classification code numbers which are applicable to the facility's operation:

*SIC Code: 3728*  
*SCC: 3-09-900-03*

## **2.2 Permitted VOC Sources**

Table 2-1 summarizes the PTIO permitted VOC sources at the Akron Facility. A detailed documentation of the approach for calculating potential to emit (PTE) is provided in Appendix A.

As shown in Table 2-1, Meggitt operates a touch up booth (i.e., K008), three portable parts washers (i.e., L007), a Grieve oven (i.e., P023), a foam packaging system (i.e., Z706), and a research and development furnace (TMP187138) that are de minimis sources of VOC emissions which are excluded from the RACT study.

The Akron Facility operates eight carbon processing electric induction coil furnaces (i.e., P036-P039, P041, P044, and P048-P049) that are subject to a non-CTG RACT determination at OAC 3745-21-11. The remainder of this study provides proposed VOC RACT determinations for these sources.

**Table 2-1. PTIO Permitted VOC Sources at the Akron Facility<sup>a</sup>**

| <b>Emission Unit ID</b>                                   | <b>Emission Unit Description</b> | <b>Current VOC Control</b> | <b>VOC PTE (tpy)</b> | <b>Current VOC Emission Limit(s)</b> | <b>VOC RACT Applicability</b> |
|-----------------------------------------------------------|----------------------------------|----------------------------|----------------------|--------------------------------------|-------------------------------|
| P036, P037, P038, P041, P044, P048, and P049 <sup>b</sup> | Carbon Processing Furnaces       | Thermal Oxidizer           | 11.3                 | 11.67                                | RACT Study                    |
| P039 <sup>b</sup>                                         | Accutherm Carbonization Furnace  |                            | 0.4                  |                                      |                               |

a. Excludes de-minimis and insignificant sources.

b. P036-P039, P041, P044, and P048-P049 are subject to a combined VOC emission limit of 11.67 tons per rolling, 12-month period.

## 3. RACT DETERMINATION

---

As discussed in Section 1 above, Meggitt is required to perform a RACT study for carbon processing furnaces (i.e, Ohio EPA Emission Unit IDs P036, P037, P038, P039, P041, P044, P048, and P049) pursuant to OAC 3745-21-11. Appendix B provides source specific information required by OAC 3745-21-11(B)(1) through (7). The following sections include a detailed description of the source followed by the top-down RACT analysis.

### 3.1 Source Overview

Meggitt operates carbon processing electric induction coil furnaces (i.e, Ohio EPA Emission Unit IDs P036, P037, P038, P039, P041, P044, P048, and P049), which are industrial thermal treatment units used to heat carbon-containing materials to high temperatures under controlled conditions. The furnaces perform processes such as carbonization, heat treatment, or stabilization to modify the physical and mechanical properties of the material, including strength, hardness, and thermal resistance.

Carbonization is a controlled thermal treatment process in which carbon-containing materials are heated in a high-temperature furnace operated under oxygen-limited or inert conditions. The purpose of the process is to thermally decompose organic constituents and remove volatile material while converting the processed material into a carbon-rich solid with improved structural and thermal properties.

The furnace is operated using controlled heating rates dependent on product requirements. The process environment prevents oxidation and open combustion; no direct flame contact occurs between the heating source and the material being processed.

VOC emissions associated with carbonization are generated as process emissions resulting from thermal decomposition of organic binders, resins, or other carbon-containing constituents within the material. As temperature increases, volatile organic compounds, moisture, and light hydrocarbons are driven off as off-gas.

The carbonization process itself is not a combustion process. Any fuel firing associated with the unit is limited to indirect heating of the furnace chamber and does not constitute a primary source of VOC emissions.

Off-gases from the carbonization furnace may contain, VOCs, Carbon Monoxide (CO), Methane and other hydrocarbons, and Carbon Dioxide (CO<sub>2</sub>). Emission composition and quantity depend on material type, throughput, and operating temperature.

The carbonization process at Meggitt's Akron facility does not include coating operations, or cleanup solvents. Therefore, the requirements of OAC 3745-21(B)(7)(e) and (f), which are for coating operations and solvent cleaning activities, do not apply to Meggitt.

### 3.2 Control Overview

The carbon furnaces are equipped with thermal oxidizers, which are an air pollution control device used to control VOC emissions generated as process off-gases from the carbonization process. There are two thermal oxidizers associated with P036-P038, P041, P044, and P048-P049, and an additional thermal

oxidizer associated with P039. Process exhaust gases from the carbonization furnaces are ducted directly to the thermal oxidizers, where VOCs and other combustibles are destroyed through high-temperature oxidation prior to atmospheric release.

The thermal oxidizers are regulated through Permit-to-Install and Operate (PTIO) P0129464, which contains enforceable operating parameters, including continuous monitoring and recordkeeping, to maintain minimum combustion temperatures. Additionally, the PTIO requires stack testing to demonstrate compliance with the allowable mass emission rates for VOC, organic hazardous air pollutants (HAPs), and organic material (OM). Appendix C provides a copy of the most recent stack test as required by OAC 3745-21-11(B)(7)(h).

A top-down RACT analysis was not performed for the carbon furnaces because the units are already equipped with thermal oxidizers that represent the highest level of reasonably available VOC control technology for this source category. Exhaust gases from the carbon furnaces are routed to thermal oxidizers designed and operated to achieve a VOC destruction efficiency of 99%.

Capture efficiency is estimated to exceed 99% because furnace exhaust is conveyed through a dedicated closed-duct system directly to a thermal oxidizer, and the furnaces are maintained under vacuum throughout the carbonization process. The integrity of the exhaust ductwork is critical because the introduction of oxygen into a furnace during carbonization could create a significant safety hazard, including the potential for fire or other upset conditions.

Thermal oxidation is widely recognized as the most effective and commonly implemented control technology for high-temperature, continuous industrial furnace exhaust streams containing VOCs. The installed thermal oxidizers provide near-complete oxidation of organic compounds and represents the upper bound of feasible VOC control performance for this type of process. Alternative control technology evaluated under a traditional top-down analysis (i.e., carbon adsorption, catalytic incinerator, condenser, scrubber, or alternative combustion-based controls) would not provide a materially higher level of control than the existing 99% destruction efficiency, nor would they be technically practicable for the furnace exhaust conditions.

Because the unit already achieves VOC emission reductions consistent with the most stringent level of control that is reasonably available, there are no technically feasible or economically reasonable control options that would result in a meaningful incremental reduction in VOC emissions beyond the existing configuration. Therefore, a top-down RACT analysis would not identify any additional RACT-level controls and would not materially inform the determination of RACT for this emission unit.

Accordingly, the existing carbon furnaces equipped with thermal oxidizers with a destruction efficiency of 99% are considered to meet RACT, and no further controls are evaluated.

### **3.3 Source Modification/Replacement**

In accordance with OAC 3745-21-11(B)(11), this RACT evaluation includes consideration of process modifications or operational changes that could reduce or eliminate VOC emissions at the source.

The carbonization furnaces are integral to Meggitt's operations. These emission units are used to thermally process materials under controlled conditions to achieve required product characteristics and performance specifications. Continuous and reliable operation of the carbonization furnaces is necessary to meet production demands and maintain product quality and consistency.

Potential pollution prevention measures, including reductions in furnace operating frequency or limitations on operating hours, or elimination of carbonization activities, were evaluated. However, implementation of such measures would directly interfere with the Meggitt facility's ability to meet its manufacturing, quality assurance, and customer requirements and would not be consistent with the intended function of the source. The furnaces are operated in accordance with established production and operating practices designed to optimize thermal efficiency and minimize unnecessary material throughput, thereby limiting VOC generation to the extent practicable.

Based on this evaluation, elimination or substantial modification of the carbonization furnace operations is not technically feasible.

### **3.4 RACT Determination**

The proposed RACT determination for VOC emissions from the carbon furnace is the continued operation of the existing thermal oxidizers in accordance with the operating requirements specified in PTIO P0129464. The thermal oxidizers are designed and operated to achieve a VOC capture and destruction efficiency of 99% and represent the most effective and commonly applied control technology for this type of emission source.

Continued operation of the thermal oxidizers ensures that VOC emissions from the carbon furnaces are controlled to a level consistent with the maximum degree of emission reduction that is reasonably available. No additional add-on controls or process modifications have been identified that would result in a meaningful incremental reduction in VOC emissions beyond the performance achieved by the existing control device. Therefore, continued operation and proper maintenance of the thermal oxidizer is proposed as RACT for the carbon furnace.

## **APPENDIX A. POTENTIAL-TO-EMIT DOCUMENTATION**

---

**REDACTED**

# REDACTED

MEGGITT AIRCRAFT BRAKING SYSTEMS CORPORATION  
AKRON, OHIO

EMISSION CALCULATIONS

**REDACTED**

**REDACTED**

**REDACTED**

## APPENDIX B. SOURCE INFORMATION

**Appendix Table B-1. General Source Information**

| <b>Emission Unit ID</b> | <b>Emission Unit Description</b> | <b>Installation Date (Month and Year)</b> | <b>Operating Schedule (hrs/day / days/week / weeks/yr)</b> | <b>Control Equipment</b> | <b>Control Device Installation Date</b> |
|-------------------------|----------------------------------|-------------------------------------------|------------------------------------------------------------|--------------------------|-----------------------------------------|
| P036                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P037                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P038                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P039                    | Accutherm Carbonization Furnace  | 6/1996                                    | 24/7/52                                                    | Thermal Oxidizer         | 3/1/1996                                |
| P041                    | Carbon Processing Furnace        | 12/1998                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P044                    | Carbon Processing Furnace        | 7/1999                                    | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P048                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |
| P049                    | Carbon Processing Furnace        | 11/1996                                   | 24/7/52                                                    | Thermal Oxidizer         | 8/1/1996                                |

**Appendix Table B-2. Annual Production Rates for 2022-2024**

| Emission Unit ID                       | Production Units | Average Daily Production Rates |      |      | Maximum Daily Production Rates |      |      | Annual Production Rates |      |      |
|----------------------------------------|------------------|--------------------------------|------|------|--------------------------------|------|------|-------------------------|------|------|
|                                        |                  | 2023                           | 2024 | 2025 | 2023                           | 2024 | 2025 | 2023                    | 2024 | 2025 |
| P036                                   | ■                | ■                              | ■    | ■    | ■                              | ■    | ■    | ■                       | ■    | ■    |
| P037, P038, P041, P044, P048, and P049 | ■                | ■                              | ■    | ■    | ■                              | ■    | ■    | ■                       | ■    | ■    |
| P039                                   | ■                | ■                              | ■    | ■    | ■                              | ■    | ■    | ■                       | ■    | ■    |


**Appendix Table B-3. Average and Maximum Daily and Annual Actual VOC Emissions<sup>a</sup>**

| <b>OEPA Emission Unit ID</b>              | <b>Emission Unit Description</b> | <b>Average<br/>Daily VOC<br/>Emissions<br/>(lb/day)</b> | <b>Maximum<br/>Daily VOC<br/>Emissions<br/>(lb/day)</b> | <b>Maximum<br/>Annual VOC<br/>Emissions<br/>(tpy)</b> |
|-------------------------------------------|----------------------------------|---------------------------------------------------------|---------------------------------------------------------|-------------------------------------------------------|
| P036                                      | Carbon Processing Furnaces       |                                                         | Did not operate                                         |                                                       |
| P037, P038, P041, P044,<br>P048, and P049 | Carbon Processing Furnaces       | 0.61                                                    | 0.78                                                    | 0.11                                                  |
| P039                                      | Accutherm Carbonization Furnace  | 0.68                                                    | 0.35                                                    | 0.05                                                  |

<sup>a</sup> As specified by OAC 3745-21-11(B)(7) the average daily, maximum daily, and maximum annual VOC emissions are based upon the highest production rates for each of the three full calendar years preceding submission of the RACT study (i.e., 2023-2025).

## **Appendix Figure B-1. Facility Plot Plan**





## **APPENDIX C. THERMAL OXIDIZER STACK TEST RESULTS**

---



Meggitt Aircraft Braking Systems Corporation  
1204 Massillon Road  
Akron, Ohio 44306

### Report

Performed Velocity, Moisture, Temperature, Volumetric Flow Rate  
and Volatile Organic Compounds Emissions Testing

Sampling performed on the North & South Afterburner Outlets

Akron, OH

Test Date: 12/7/20 & 12/8/20

**Meggitt Aircraft Braking Systems Corporation  
1204 Massillon Road  
Akron, Ohio 44306**

**Report**

**Performed Velocity, Moisture, Temperature, Volumetric Flow Rate  
and Volatile Organic Compounds Emissions Testing**

**Sampling performed on the North & South Afterburner Outlets**

**Akron, OH**

**Test Date: 12/7/20 & 12/8/20**

A handwritten signature in black ink, reading "Brian E. Lemasters". The signature is written in a cursive, flowing style. The first name "Brian" is written with a large, stylized 'B'. The middle initial "E" is smaller and positioned between the first and last names. The last name "Lemasters" is written in a similar cursive style, with a large 'L' and a trailing flourish.

**Brian E. Lemasters  
Custom Stack Analysis, LLC.**

## REPORT CERTIFICATION

Custom Stack Analysis, LLC. has used its professional experience and best professional efforts in performing this compliance test. I have reviewed the results of these tests and to the best of my knowledge and belief they are true and correct.

A handwritten signature in black ink that reads "Brian E. Lemasters". The signature is written in a cursive style with a large, stylized "B" and "L".

Brian E.Lemasters

## **TABLE OF CONTENTS**

|                                 |       |
|---------------------------------|-------|
| Executive Summary .....         | 1-2   |
| Test Results .....              | 3-4   |
| Methods Description .....       | 5-6   |
| Sampling Train Diagrams .....   | 7-8   |
| Sampling Point Description..... | 9-10  |
| Calculations .....              | 11-18 |

### **APPENDIX**

|                        |   |
|------------------------|---|
| Test Data .....        | 1 |
| Laboratory Data .....  | 2 |
| Calibration Data ..... | 3 |
| Monitoring Data .....  | 4 |

## **EXECUTIVE SUMMARY**

Custom Stack Analysis, LLC. conducted emissions sampling using USEPA Methods 1-4 and 25A at Facility ID# - 1677010999. Testing was conducted on the North & South Afterburner Outlets on December 7<sup>th</sup> & 8<sup>th</sup>, 2020 for compliance purposes - Permit # - P0121253 (see Table 1.2).

The Custom Stack Analysis, LLC. test crew consisted of Mr. James Gray, Mr. Brian Lemasters and Mr. Ethan Minor. The testing procedures were coordinated by Mr. Jim Davies and Mr. Jon Carver of Meggitt Aircraft Braking Systems Corporation (see Table 1.1).

**Table 1.1: Emissions Testing Program Contact Personnel**

| Name, Title                                                                                                         | Company Address                                                                | Phone, Fax, email                              |
|---------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|------------------------------------------------|
| Mr. Jim Davies<br>Mr. Jon Carver                                                                                    | Meggitt Aircraft Braking Corporation<br>1204 Massillon Road<br>Akron, OH 44306 | (330) 796-1743 (Phone)                         |
| Mr. James Gray<br>Owner<br><br>Mr. Brian Lemasters<br>Project Manager<br><br>Mr. Ethan Minor<br>Project Technicians | Custom Stack Analysis, LLC.<br>14614 Cenfield St. N.E.<br>Alliance, OH 44601   | (330) 525-5119 (Phone)<br>(330) 525-7908 (Fax) |

Test results are located on pages 3-4. A description of the testing protocol is included on pages 5-6. All testing calculations are located on pages 11-18. Appendix 1 includes field test data. Appendix 2 contains laboratory data from Custom Stack Analysis, LLC. Appendix 3 contains calibration data for the equipment used on test day. Appendix 4 contains monitoring data.

Table 1.2 demonstrates how Meggitt Aircraft Baking Systems Corporation in Akron, OH is operating in compliance with the applicable emission standards.

**Table 1.2: Emission Limits and Test Results Summary**

| Pollutant                  | Emission Limitations | Test Result Average                                                  | Compliance Demonstrated |
|----------------------------|----------------------|----------------------------------------------------------------------|-------------------------|
| Volatile Organic Compounds | See below            | <b><u>North Afterburner</u></b><br>0.00415 lbs/hr<br>0.0182 tons/yr  | Yes<br>Yes              |
|                            |                      | <b><u>South Afterburner</u></b><br>0.00166 lbs/hr<br>0.00726 tons/yr | Yes<br>Yes              |

Individual unit VOC limitations:

- from emissions units P036 and P048, combined, 2.5 lb/hr and 10.95 ton/yr
- from emissions units P037 and P049, combined, 2.5 lb/hr and 10.95 ton/yr
- from emissions unit P038, 2.5 lb/hr and 10.95 ton/yr
- from emissions unit P041, 2.5 lb/hr and 10.95 ton/yr
- from emissions unit P044, 2.47 lb/hr and 10.82 ton/yr

The overall combined VOC emissions from emissions units P036, P037, P038, P041, P044, P048 and P049 are limited to 11.31 ton/yr.

# Test Results

Meggitt Aircraft Braking Systems Corporation - North Afterburner Outlet  
12/7/2020

Methods 1-4 & 25A

|                              | <b><u>Run #1</u></b> | <b><u>Run #2</u></b> | <b><u>Run #3</u></b> | <b><u>Avg.</u></b> |
|------------------------------|----------------------|----------------------|----------------------|--------------------|
| Stack Gas Velocity (ft/sec)  | 37.31                | 38.22                | 38.31                | 37.95              |
| Standard Cubic Feet an Hour  | 227,390              | 230,154              | 232,946              | 230,163            |
| Actual Cubic Feet per Minute | 15,822               | 16,212               | 16,246               | 16,093             |
| Moisture %                   | 8.18%                | 8.70%                | 8.48%                | 8.45%              |
| Carbon Dioxide %             | 4.33%                | 4.17%                | 4.17%                | 4.22%              |
| Oxygen %                     | 12.17%               | 12.33%               | 12.17%               | 12.22%             |
| Nitrogen %                   | 83.50%               | 83.50%               | 83.66%               | 83.55%             |

## Method 25A

|                 |          |          |          |          |
|-----------------|----------|----------|----------|----------|
| VOC (ppm)       | 0.20     | 0.19     | 0.20     | 0.19     |
| (lbs/hr Carbon) | 4.17E-03 | 4.01E-03 | 4.29E-03 | 4.15E-03 |
| (tons/yr)       | 1.83E-02 | 1.76E-02 | 1.88E-02 | 1.82E-02 |

# Test Results

Meggitt Aircraft Braking Systems Corporation - South Afterburner Outet

12/8/2020

Methods 1-4 & 25A

|                              | <u>Run #1</u> | <u>Run #2</u> | <u>Run #3</u> | <u>Avg.</u> |
|------------------------------|---------------|---------------|---------------|-------------|
| Stack Gas Velocity (ft/sec)  | 30.58         | 30.95         | 30.53         | 30.69       |
| Standard Cubic Feet an Hour  | 197,116       | 195,080       | 190,059       | 194,085     |
| Actual Cubic Feet per Minute | 12,968        | 13,128        | 12,950        | 13,015      |
| Moisture %                   | 8.46%         | 8.80%         | 8.39%         | 8.55%       |
| Carbon Dioxide %             | 4.83%         | 4.83%         | 4.83%         | 4.83%       |
| Oxygen %                     | 11.67%        | 11.67%        | 11.50%        | 11.61%      |
| Nitrogen %                   | 83.50%        | 83.50%        | 83.67%        | 83.56%      |

## Method 25A

|                 |          |          |          |          |
|-----------------|----------|----------|----------|----------|
| VOC (ppm)       | 0.11     | 0.09     | 0.08     | 0.09     |
| (lbs/hr Carbon) | 2.01E-03 | 1.60E-03 | 1.36E-03 | 1.66E-03 |
| (tons/yr)       | 8.82E-03 | 7.01E-03 | 5.95E-03 | 7.26E-03 |

## **METHOD 1**

Sample and velocity traverses for stationary sources.

To aid in the representative measurement of pollutant emissions and/ or total volumetric flow rate from a stationary source, a measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas. A traverse point is then located within each of these equal areas.

## **METHOD 2**

Determination of stack gas velocity and volumetric flow rate.

The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Staustscheibe or reverse type) pitot tube.

## **METHOD 3**

Gas analysis for the determination of dry molecular weight.

This method is applicable for determining carbon dioxide and oxygen concentrations and dry molecular weight of a sample from a gas stream of a fossil-fuel combustion process.

## **METHOD 4**

Determination of moisture content in stack gases.

A gas sample is extracted at a constant rate from the source. It is determined either volumetrically or gravimetrically.

## METHOD 25A TESTING DESCRIPTION

This method will be used to measure the total VOC concentration expressed in terms of ppm propane. A gas sample is extracted from the source through a stainless steel probe, through a heated sample line (teflon), to a flame ionization analyzer. The main components of Method 25A are the same as Method 204B with the exception of a non heated sample probe.

The sampling system is heated up to the proper operating temperature. Within two hours of the start of the test the FIA is calibrated. The calibration range or span is selected to be from 1.5 to 2.5 times the expected concentration. Three calibration ranges are then selected as follows: Low level 25-35% of the span, Mid level 45-55% of the span, and a High level 80-90% of the span. A zero and a high level calibration gas is then injected at the valve assembly and the FIA is adjusted to these levels. Then all four gases are introduced into the analyzer and recorded. If the responses are within 5% of the expected values then the analyzer is responding correctly. The sample probe is located in the center of the stack and sealed in place and the test is started. The test lasts for 60 minutes. At the end of the test run a drift check is run. The zero gas and the mid level calibration gas is injected at the valve assembly. The analyzer responses are then recorded. The drift check is acceptable if the results are within 3% of the span value. These checks are performed before and after each test run.






FIGURE 3

# 25A Sampling System




## Location of Sampling Points



|                |                          |        |        |
|----------------|--------------------------|--------|--------|
| Location:      | North Afterburner Outlet |        |        |
| Upstream       | 3'                       |        |        |
| Downstream     | 15'                      |        |        |
| Stack Diameter | 36                       | Inches |        |
| Sample Point # | 1                        | 1.6    | Inches |
|                | 2                        | 5.3    |        |
|                | 3                        | 10.7   |        |
|                | 4                        | 25.3   |        |
|                | 5                        | 30.7   |        |
|                | 6                        | 34.4   |        |

## Location of Sampling Points



|                |                          |        |
|----------------|--------------------------|--------|
| Location:      | South Afterburner Outlet |        |
| Upstream       | 3'                       |        |
| Downstream     | 15'                      |        |
| Stack Diameter | 36                       | Inches |
| Sample Point # | 1                        | 1.6    |
|                | 2                        | 5.3    |
|                | 3                        | 10.7   |
|                | 4                        | 25.3   |
|                | 5                        | 30.7   |
|                | 6                        | 34.4   |

# CALCULATIONS

## North Afterburner Outlet

|    |                 | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|----|-----------------|---------------|---------------|---------------|---|
| 1. | <b>Vm (std)</b> | 42.74         | 42.04         | 42.21         | = |

$$VM * 17.64 * \frac{PBAR + 13.6}{Tm} * Y$$

|          |                                                                    | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|----------|--------------------------------------------------------------------|---------------|---------------|---------------|
| Vm (std) | = Volume of gas collected, corrected to standard conditions, cuft. | 42.74         | 42.04         | 42.21         |
| Vm       | = Volume of gas sampled at meter box, cuft.                        | 45.13         | 44.39         | 44.53         |
| 17.64    | = Standard temperature, 528 Rankine / std pressure, 29.92.         | 17.64         | 17.64         | 17.64         |
| Tm       | = Average dry gas meter temperature, + 460 Rankine.                | 538.58333     | 538.58333     | 538.16667     |
| Pbar     | = Barometric pressure, inches of mercury (Hg)                      | 28.76         | 28.76         | 28.76         |
| ^H       | = Average pressure differential across orifice.                    | 2             | 2             | 2             |
| 13.6     | = Specific gravity of mercury.                                     | 13.6          | 13.6          | 13.6          |
| Y        | = Calibration factor of meter box.                                 | 1.0004        | 1.0004        | 1.0004        |

|    |                 | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|----|-----------------|---------------|---------------|---------------|---|
| 2. | <b>Vw (std)</b> | 3.81          | 4.01          | 3.91          | = |

$$Vlc * \frac{P H20}{Mh20} * \frac{R Tstd}{Pstd} = K2 * Vlc$$

|       |                                                     | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-------|-----------------------------------------------------|---------------|---------------|---------------|
| Vlc   | = Volume of water and silica collected.             | 80.8          | 85            | 83            |
| P H20 | = Density of water, 0.002201 lb/ml.                 | 0.002201      | 0.002201      | 0.002201      |
| M H20 | = Molecular weight of water, 18.01 lb/lb-mole.      | 18.01         | 18.01         | 18.01         |
| R     | = Ideal gas constant, 21.85 in. hg - ft3/R-lb-mole. | 21.85         | 21.85         | 21.85         |
| Tstd  | = Standard absolute temperature, 528 R.             | 528           | 528           | 528           |
| Pstd  | = Standard absolute pressure, 29.92 in. Hg.         | 29.92         | 29.92         | 29.92         |
| K2    | = 0.0471 ft3 / ml.                                  | 0.0471        | 0.0471        | 0.0471        |

|    |            | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|----|------------|---------------|---------------|---------------|---|
| 3. | <b>Bws</b> | 0.08180       | 0.08698       | 0.08481       | = |

$$\frac{Vw(std)}{Vm(std) + Vw(std)}$$

|         |                                                 | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|---------|-------------------------------------------------|---------------|---------------|---------------|
| Bws     | = Water vapor in the gas stream, proportion.    | 0.08180       | 0.08698       | 0.08481       |
| Vw(std) | = Volume of water vapor in the gas sample, scf. | 3.81          | 4.01          | 3.91          |
| Vm(std) | = Volume of gas sampled at meter box, scf.      | 42.74         | 42.04         | 42.21         |

|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                  |               |               |  |
|----|----------------------------------------------------------|-----------------------------------------------------|---------------|---------------|---|----------------------------------------------------------------------------------|---------------|---------------|--|
| 4. | <b>Md</b>                                                | 29.1796                                             | 29.1604       | 29.154        | = | <div>0.44 (%CO2) + 0.32 (%O2) + 0.28 (%N2) + %CO</div>                           |               |               |  |
|    | Md                                                       | = Dry molecular weight, lb / lb-mole.               |               |               | = | <u>RUN #1</u>                                                                    | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 29.18                                                                            | 29.16         | 29.15         |  |
|    | 0.44                                                     | = Molecular weight of CO2 divided by 100.           |               |               | = | 0.44                                                                             | 0.44          | 0.44          |  |
|    | 0.32                                                     | = Molecular weight of O2 divided by 100.            |               |               | = | 0.32                                                                             | 0.32          | 0.32          |  |
|    | 0.28                                                     | = Molecular weight of N2 or CO divided by 100.      |               |               | = | 0.28                                                                             | 0.28          | 0.28          |  |
|    | Co2, O2, N2, and CO are in percent by volume, dry basis. |                                                     |               |               |   |                                                                                  |               |               |  |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                  |               |               |  |
| 5. | <b>Ms</b>                                                | 28.27                                               | 28.19         | 28.21         | = | <div>Md * (1-Bws) + M H2O * (Bws)</div>                                          |               |               |  |
|    | Ms                                                       | = Molecular weight of gas , wet basis, lb /lb-mole. |               |               | = | <u>RUN #1</u>                                                                    | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 28.27                                                                            | 28.19         | 28.21         |  |
|    | M H2O                                                    | = Molecular weight of water, 18 lb / lb-mole.       |               |               | = | 18                                                                               | 18            | 18            |  |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                  |               |               |  |
| 6. | <b>Vs</b>                                                | 37.31                                               | 38.22         | 38.31         | = | <div><div>85.49 * Cp √ ∆p √ <math>\frac{T_s + 460}{P_s * M_s}</math></div></div> |               |               |  |
|    | Vs                                                       | = Average stack gas velocity, ft / sec.             |               |               | = | <u>RUN #1</u>                                                                    | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 37.31                                                                            | 38.22         | 38.31         |  |
|    | 85.49                                                    | = Pitot tube constant, ft / sec.                    |               |               | = | 85.49                                                                            | 85.49         | 85.49         |  |
|    | Cp                                                       | = Pitot tube coefficient, dimensionless.            |               |               | = | 0.84                                                                             | 0.84          | 0.84          |  |
|    | ∆P                                                       | = Velocity head of stack gas, avg. sq rt.           |               |               | = | 0.33580                                                                          | 0.34248       | 0.34462       |  |
|    | Ts                                                       | = Temperature of stack gas, + 460 (Rankine).        |               |               | = | 1948.2083                                                                        | 1961          | 1946          |  |
|    | Ps                                                       | = Absolute stack gas pressure, barometric + static. |               |               | = | 28.80                                                                            | 28.80         | 28.80         |  |
|    | Ms                                                       | = Molecular weight of stack gas, wet basis.         |               |               | = | 28.27                                                                            | 28.19         | 28.21         |  |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                  |               |               |  |
| 7. | <b>ACFM</b>                                              | 15821.95                                            | 16211.57      | 16246.01      | = | <div>Stack Area * 60 * Vs</div>                                                  |               |               |  |
|    | Vs                                                       | = Average stack gas velocity, ft / sec.             |               |               | = | <u>RUN #1</u>                                                                    | <u>RUN #2</u> | <u>RUN #3</u> |  |
|    |                                                          |                                                     |               |               |   | 37.31                                                                            | 38.22         | 38.31         |  |

|   |      | <u>RUN #1</u> | <u>RUN #2</u>                                     | <u>RUN #3</u> |   |                                                                                                                                                         |
|---|------|---------------|---------------------------------------------------|---------------|---|---------------------------------------------------------------------------------------------------------------------------------------------------------|
| 8 | SCFH | 227390        | 230154                                            | 232946        | = | <div><div><div>Tstd</div><div>Ps</div></div><div><div>3600 * ( 1 - Bws ) * Vs * A</div><div><div>Ts</div><div>Pstd</div></div></div></div>              |
|   |      |               |                                                   |               |   | <div><div><div><u>RUN #1</u></div><div>3600</div></div><div><u>RUN #2</u></div><div>3600</div></div> <div><div><u>RUN #3</u></div><div>3600</div></div> |
|   | 3600 | =             | Seconds per hour.                                 |               | = |                                                                                                                                                         |
|   | Bws  | =             | Water vapor in the gas stream, proportion.        |               | = | 0.0817974 0.0869803 0.084805                                                                                                                            |
|   | A    | =             | Area of stack in sq ft.                           |               | = | 7.07 7.07 7.07                                                                                                                                          |
|   | Tstd | =             | Standard absolute temperature, 528 R.             |               | = | 528 528 528                                                                                                                                             |
|   | Pstd | =             | Standard absolute pressure, 29.92 in. Hg.         |               | = | 29.92 29.92 29.92                                                                                                                                       |
|   | Ts   | =             | Temperature of stack gas, + 460 (Rankine).        |               |   | 1948.2083 1961 1946                                                                                                                                     |
|   | Ps   | =             | Absolute stack gas pressure, barometric + static. |               |   | 28.76 28.76 28.76                                                                                                                                       |
|   | Vs   | =             | Average stack gas velocity, ft / sec.             |               |   | 37.31 38.22 38.31                                                                                                                                       |

## CALCULATIONS

| <u>VOC</u> |                       | <u>RUN #1</u> | <u>RUN #2</u>                                    | <u>RUN #3</u> |   |                                                                         |
|------------|-----------------------|---------------|--------------------------------------------------|---------------|---|-------------------------------------------------------------------------|
| 1.         | <b>Lbs/Hr Propane</b> | 0.00510       | 0.00490                                          | 0.00524       | = | 0.11443 * SCFH * PPM * 10 <sup>-6</sup>                                 |
|            | scfh                  | =             | Standard stack volumetric flow rate.             |               | = | <u>RUN #1</u><br>227390 <u>RUN #2</u><br>230154 <u>RUN #3</u><br>232946 |
|            | PPM                   | =             | PPM                                              |               | = | 0.1960352    0.1861953    0.1966794                                     |
| 2.         | <b>Lbs/Hr Carbon</b>  | 0.00417       | 0.00401                                          | 0.00429       | = | 0.031182 * SCFH * PPM * 3 * 10 <sup>-6</sup>                            |
|            | scfh                  | =             | Standard stack volumetric flow rate.             |               | = | <u>RUN #1</u><br>227390 <u>RUN #2</u><br>230154 <u>RUN #3</u><br>232946 |
|            | PPM                   | =             | PPM                                              |               | = | 0.1960352    0.1861953    0.1966794                                     |
|            | 3                     | =             | Carbon equivalent correction factor for propane. |               | = | 3                    3                    3                             |

# CALCULATIONS

## South Afterburner Outlet

|    |                                                                             | <u>RUN #1</u> | <u>RUN #2</u>            | <u>RUN #3</u>            |                          |                                                             |
|----|-----------------------------------------------------------------------------|---------------|--------------------------|--------------------------|--------------------------|-------------------------------------------------------------|
| 1. | <b>Vm (std)</b>                                                             | 43.20         | 42.42                    | 42.83                    | =                        | $VM * 17.64 * \frac{PBAR + 13.6}{Tm} * Y$                   |
|    | Vm (std) = Volume of gas collected, corrected to standard conditions, cuft. | =             | <u>RUN #1</u><br>43.20   | <u>RUN #2</u><br>42.42   | <u>RUN #3</u><br>42.83   |                                                             |
|    | Vm = Volume of gas sampled at meter box, cuft.                              | =             | 45.21                    | 44.38                    | 44.80                    |                                                             |
|    | 17.64 = Standard temperature, 528 Rankine / std pressure, 29.92.            | =             | 17.64                    | 17.64                    | 17.64                    |                                                             |
|    | Tm = Average dry gas meter temperature, + 460 Rankine.                      | =             | 535.58333                | 535.33333                | 535.20833                |                                                             |
|    | Pbar = Barometric pressure, inches of mercury (Hg)                          | =             | 28.85                    | 28.85                    | 28.85                    |                                                             |
|    | ^H = Average pressure differential across orifice.                          | =             | 2                        | 2                        | 2                        |                                                             |
|    | 13.6 = Specific gravity of mercury.                                         | =             | 13.6                     | 13.6                     | 13.6                     |                                                             |
|    | Y = Calibration factor of meter box.                                        | =             | 1.0004                   | 1.0004                   | 1.0004                   |                                                             |
|    |                                                                             | <u>RUN #1</u> | <u>RUN #2</u>            | <u>RUN #3</u>            |                          |                                                             |
| 2. | <b>Vw (std)</b>                                                             | 3.99          | 4.09                     | 3.92                     | =                        | $Vlc * \frac{P H20}{Mh20} * \frac{R Tstd}{Pstd} = K2 * Vlc$ |
|    | Vlc = Volume of water and silica collected.                                 | =             | <u>RUN #1</u><br>84.7    | <u>RUN #2</u><br>86.9    | <u>RUN #3</u><br>83.2    |                                                             |
|    | P H20 = Density of water, 0.002201 lb/ml.                                   | =             | 0.002201                 | 0.002201                 | 0.002201                 |                                                             |
|    | M H20 = Molecular weight of water, 18.01 lb/lb-mole.                        | =             | 18.01                    | 18.01                    | 18.01                    |                                                             |
|    | R = Ideal gas constant, 21.85 in. hg - ft3/R-lb-mole.                       | =             | 21.85                    | 21.85                    | 21.85                    |                                                             |
|    | Tstd = Standard absolute temperature, 528 R.                                | =             | 528                      | 528                      | 528                      |                                                             |
|    | Pstd = Standard absolute pressure, 29.92 in. Hg.                            | =             | 29.92                    | 29.92                    | 29.92                    |                                                             |
|    | K2 = 0.0471 ft3 / ml.                                                       | =             | 0.0471                   | 0.0471                   | 0.0471                   |                                                             |
|    |                                                                             | <u>RUN #1</u> | <u>RUN #2</u>            | <u>RUN #3</u>            |                          |                                                             |
| 3. | <b>Bws</b>                                                                  | 0.08458       | 0.08803                  | 0.08385                  | =                        | $\frac{Vw(std)}{Vm(std) + Vw(std)}$                         |
|    | Bws = Water vapor in the gas stream, proportion.                            | =             | <u>RUN #1</u><br>0.08458 | <u>RUN #2</u><br>0.08803 | <u>RUN #3</u><br>0.08385 |                                                             |
|    | Vw(std) = Volume of water vapor in the gas sample, scf.                     | =             | 3.99                     | 4.09                     | 3.92                     |                                                             |
|    | Vm(std) = Volume of gas sampled at meter box, scf.                          | =             | 43.20                    | 42.42                    | 42.83                    |                                                             |

|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                    |               |               |
|----|----------------------------------------------------------|-----------------------------------------------------|---------------|---------------|---|------------------------------------------------------------------------------------|---------------|---------------|
| 4. | <b>Md</b>                                                | 29.2396                                             | 29.2396       | 29.2328       | = | <u>0.44 (%CO2) + 0.32 (%O2) + 0.28 (%N2) + %CO)</u>                                |               |               |
|    | Md                                                       | = Dry molecular weight, lb / lb-mole.               |               |               | = | <u>RUN #1</u>                                                                      | <u>RUN #2</u> | <u>RUN #3</u> |
|    |                                                          |                                                     |               |               |   | 29.24                                                                              | 29.24         | 29.23         |
|    | 0.44                                                     | = Molecular weight of CO2 divided by 100.           |               |               | = | 0.44                                                                               | 0.44          | 0.44          |
|    | 0.32                                                     | = Molecular weight of O2 divided by 100.            |               |               | = | 0.32                                                                               | 0.32          | 0.32          |
|    | 0.28                                                     | = Molecular weight of N2 or CO divided by 100.      |               |               | = | 0.28                                                                               | 0.28          | 0.28          |
|    | Co2, O2, N2, and CO are in percent by volume, dry basis. |                                                     |               |               |   |                                                                                    |               |               |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                    |               |               |
| 5. | <b>Ms</b>                                                | 28.29                                               | 28.25         | 28.29         | = | <u>Md * (1-Bws) + M H2O * (Bws)</u>                                                |               |               |
|    | Ms                                                       | = Molecular weight of gas , wet basis, lb /lb-mole. |               |               | = | <u>RUN #1</u>                                                                      | <u>RUN #2</u> | <u>RUN #3</u> |
|    |                                                          |                                                     |               |               |   | 28.29                                                                              | 28.25         | 28.29         |
|    | M H2O                                                    | = Molecular weight of water, 18 lb / lb-mole.       |               |               | = | 18                                                                                 | 18            | 18            |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                    |               |               |
| 6. | <b>Vs</b>                                                | 30.58                                               | 30.95         | 30.53         | = | <u><math>85.49 * C_p \sqrt{\Delta p} \sqrt{\frac{T_s + 460}{P_s * M_s}}</math></u> |               |               |
|    | Vs                                                       | = Average stack gas velocity, ft / sec.             |               |               | = | <u>RUN #1</u>                                                                      | <u>RUN #2</u> | <u>RUN #3</u> |
|    |                                                          |                                                     |               |               |   | 30.58                                                                              | 30.95         | 30.53         |
|    | 85.49                                                    | = Pitot tube constant, ft / sec.                    |               |               | = | 85.49                                                                              | 85.49         | 85.49         |
|    | Cp                                                       | = Pitot tube coefficient, dimensionless.            |               |               | = | 0.84                                                                               | 0.84          | 0.84          |
|    | ΔP                                                       | = Velocity head of stack gas, avg. sq rt.           |               |               | = | 0.28360                                                                            | 0.28421       | 0.27818       |
|    | Ts                                                       | = Temperature of stack gas, + 460 (Rankine).        |               |               | = | 1842.2083                                                                          | 1877          | 1909          |
|    | Ps                                                       | = Absolute stack gas pressure, barometric + static. |               |               | = | 28.89                                                                              | 28.89         | 28.89         |
|    | Ms                                                       | = Molecular weight of stack gas, wet basis.         |               |               | = | 28.29                                                                              | 28.25         | 28.29         |
|    |                                                          | <u>RUN #1</u>                                       | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                    |               |               |
| 7. | <b>ACFM</b>                                              | 12967.65                                            | 13127.84      | 12949.88      | = | <u>Stack Area * 60 * Vs</u>                                                        |               |               |
|    | Vs                                                       | = Average stack gas velocity, ft / sec.             |               |               | = | <u>RUN #1</u>                                                                      | <u>RUN #2</u> | <u>RUN #3</u> |
|    |                                                          |                                                     |               |               |   | 30.58                                                                              | 30.95         | 30.53         |

|               |               | <u>RUN #1</u>                                     | <u>RUN #2</u> | <u>RUN #3</u> |           |                                                                                                                                            |               |               |               |      |      |      |
|---------------|---------------|---------------------------------------------------|---------------|---------------|-----------|--------------------------------------------------------------------------------------------------------------------------------------------|---------------|---------------|---------------|------|------|------|
| 8             | SCFH          | 197116                                            | 195080        | 190059        | =         | $3600 * ( 1 - Bws ) * Vs * A * \frac{Tstd}{Ts} * \frac{Ps}{Pstd}$                                                                          |               |               |               |      |      |      |
|               |               |                                                   |               |               |           |                                                                                                                                            |               |               |               |      |      |      |
|               |               |                                                   |               |               |           | <table><tr><th><u>RUN #1</u></th><th><u>RUN #2</u></th><th><u>RUN #3</u></th></tr><tr><td>3600</td><td>3600</td><td>3600</td></tr></table> | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> | 3600 | 3600 | 3600 |
| <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u>                                     |               |               |           |                                                                                                                                            |               |               |               |      |      |      |
| 3600          | 3600          | 3600                                              |               |               |           |                                                                                                                                            |               |               |               |      |      |      |
| 3600          | =             | Seconds per hour.                                 |               | =             |           |                                                                                                                                            |               |               |               |      |      |      |
| Bws           | =             | Water vapor in the gas stream, proportion.        |               | =             | 0.0845824 | 0.0880319 0.0838546                                                                                                                        |               |               |               |      |      |      |
| A             | =             | Area of stack in sq ft.                           |               | =             | 7.07      | 7.07 7.07                                                                                                                                  |               |               |               |      |      |      |
| Tstd          | =             | Standard absolute temperature, 528 R.             |               | =             | 528       | 528 528                                                                                                                                    |               |               |               |      |      |      |
| Pstd          | =             | Standard absolute pressure, 29.92 in. Hg.         |               | =             | 29.92     | 29.92 29.92                                                                                                                                |               |               |               |      |      |      |
| Ts            | =             | Temperature of stack gas, + 460 (Rankine).        |               |               | 1842.2083 | 1877 1909                                                                                                                                  |               |               |               |      |      |      |
| Ps            | =             | Absolute stack gas pressure, barometric + static. |               |               | 28.85     | 28.85 28.85                                                                                                                                |               |               |               |      |      |      |
| Vs            | =             | Average stack gas velocity, ft / sec.             |               |               | 30.58     | 30.95 30.53                                                                                                                                |               |               |               |      |      |      |

## CALCULATIONS

| <u>VOC</u> |                       | <u>RUN #1</u> | <u>RUN #2</u>                                    | <u>RUN #3</u> |   |                                                                         |
|------------|-----------------------|---------------|--------------------------------------------------|---------------|---|-------------------------------------------------------------------------|
| 1.         | <b>Lbs/Hr Propane</b> | 0.00246       | 0.00196                                          | 0.00166       | = | 0.11443 * SCFH * PPM * 10 <sup>-6</sup>                                 |
|            | scfh                  | =             | Standard stack volumetric flow rate.             |               | = | <u>RUN #1</u><br>197116 <u>RUN #2</u><br>195080 <u>RUN #3</u><br>190059 |
|            | PPM                   | =             | PPM                                              |               | = | 0.1092398    0.0877224    0.0764071                                     |
| 2.         | <b>Lbs/Hr Carbon</b>  | 0.00201       | 0.00160                                          | 0.00136       | = | 0.031182 * SCFH * PPM * 3 * 10 <sup>-6</sup>                            |
|            | scfh                  | =             | Standard stack volumetric flow rate.             |               | = | <u>RUN #1</u><br>197116 <u>RUN #2</u><br>195080 <u>RUN #3</u><br>190059 |
|            | PPM                   | =             | PPM                                              |               | = | 0.1092398    0.0877224    0.0764071                                     |
|            | 3                     | =             | Carbon equivalent correction factor for propane. |               | = | 3                    3                    3                             |

# **Appendix #1**

## **Test Data**

# Custom Stack Analysis, LLC.

## Pitot Traverse Data Sheet

Plant: ggitt Aircraft Braking Systems Corporat

Date 12/7/2020

Location North Afterburner

By Ethan M

| Run No. | Pre 1     |      | Post 1    |      | Post 2    |      | Post 3    |      |
|---------|-----------|------|-----------|------|-----------|------|-----------|------|
| Point # | Pitot Δ P | °F   | Pitot Δ P | °F   | Pitot Δ P | °F   | Pitot Δ P | °F   |
| A-1     | 0.16      | 1658 | 0.06      | 1547 | 0.08      | 1651 | 0.07      | 1733 |
| 2       | 0.18      | 1689 | 0.05      | 1599 | 0.10      | 1692 | 0.08      | 1762 |
| 3       | 0.26      | 1602 | 0.15      | 1671 | 0.11      | 1669 | 0.11      | 1593 |
| 4       | 0.22      | 1548 | 0.10      | 1292 | 0.09      | 1545 | 0.11      | 1448 |
| 5       | 0.18      | 1355 | 0.07      | 1074 | 0.07      | 1295 | 0.09      | 1233 |
| 6       | 0.10      | 1157 | 0.06      | 1048 | 0.06      | 1198 | 0.08      | 1054 |
| B-1     | 0.04      | 1680 | 0.15      | 1578 | 0.14      | 1660 | 0.11      | 1634 |
| 2       | 0.05      | 1720 | 0.17      | 1673 | 0.17      | 1697 | 0.22      | 1726 |
| 3       | 0.04      | 1612 | 0.22      | 1702 | 0.20      | 1633 | 0.22      | 1630 |
| 4       | 0.07      | 1413 | 0.19      | 1645 | 0.18      | 1524 | 0.16      | 1349 |
| 5       | 0.07      | 1235 | 0.16      | 1478 | 0.15      | 1475 | 0.14      | 1150 |
| 6       | 0.06      | 1118 | 0.11      | 1392 | 0.10      | 1289 | 0.11      | 1032 |

| Run #1  |       |         |       | Run #2 |         | Run #3 |       |         |
|---------|-------|---------|-------|--------|---------|--------|-------|---------|
|         | 0.34  | 1488.21 |       | 0.34   | 1501.13 |        | 0.34  | 1486.33 |
|         | 0.328 | 1502    | 0.343 | 1475   | 0.342   | 1527   | 0.347 | 1445    |
| Static: | 0.53  |         | 0.54  |        | 0.55    |        | 0.53  |         |

# TEST DATA

|              |                                                |
|--------------|------------------------------------------------|
| COMPANY NAME | Meggitt Aircraft Braking Systems Corporation - |
| ADDRESS      | 1204 Massillon Road                            |
| CITY         | Akron                                          |
| STATE        | OH                                             |
| ZIP          | 44306                                          |
| TEST METHODS | Methods 1-4 & 25A                              |
| CREW MEMBERS | Brian L. Ethan M                               |
| LOCATION     | Outlet                                         |
| SOURCE       | North Afterburner                              |
| CONTROL      |                                                |

|                     | RUN #1    | RUN #2    | RUN #3    |
|---------------------|-----------|-----------|-----------|
| DATE                | 12/7/2020 | 12/7/2020 | 12/7/2020 |
| RUN LENGTH (min)    | 60        | 60        | 60        |
| VOLUME (cubic feet) | 45.125    | 44.390    | 44.529    |
| Y FACTOR            | 1.0004    | 1.0004    | 1.0004    |
| BAROMETRIC          | 28.76     | 28.76     | 28.76     |
| METER TEMP. (R)     | 538.58    | 538.58    | 538.17    |
| STACK TEMP. (R)     | 1948.21   | 1961.13   | 1946.33   |
| AVERAGE ^P          | 0.34      | 0.34      | 0.34      |
| AVERAGE ^H          | 2.00      | 2.00      | 2.00      |
| IMPINGER VOLUME     | 80.80     | 85.00     | 83.00     |
|                     |           |           |           |
| PITOT COEF.         | 0.84      | 0.84      | 0.84      |
| STATIC PRESSURE     | 0.54      | 0.55      | 0.54      |
| STACK AREA          | 7.07      | 7.07      | 7.07      |
|                     |           |           |           |
| CARBON DIOXIDE      | 4.33      | 4.17      | 4.17      |
| OXYGEN              | 12.17     | 12.33     | 12.17     |
| NITROGEN            | 83.50     | 83.50     | 83.66     |

# TEST RESULTS

North Afterburner Outlet  
12/7/2020

|             | RUN #1    | RUN #2    | RUN #3    |
|-------------|-----------|-----------|-----------|
| VM (std)    | 42.741    | 42.044    | 42.209    |
| VW (std)    | 3.808     | 4.005     | 3.911     |
| BWS         | 0.082     | 0.087     | 0.085     |
| MD          | 29.180    | 29.160    | 29.154    |
| MS          | 28.265    | 28.190    | 28.208    |
| VS (ft/sec) | 37.306    | 38.224    | 38.306    |
|             |           |           |           |
| SCFH        | 227389.53 | 230153.95 | 232946.44 |
| ACFM        | 15821.95  | 16211.57  | 16246.01  |
| DCFM        | 3789.83   | 3835.90   | 3882.44   |

Vm (std) = Volume of gas sampled at standard conditions.

Vw (std) = Volume of water vapor collected at standard conditions.

Bws = Stack moisture content.

Md = Determination of dry molecular weight of stack gas.

Ms = Determination of stack gas molecular weight.

Vs = Average gas stack velocity. (ft/sec.)

ACFM = Actual cubic feet per minute of gas velocity.

DCFM = Dry standard cubic feet per minute of gas velocity.

# TEST RESULTS

North Afterburner Outlet

12/7/2020

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <u>CEM MONITORING</u> |        |        |        |
|                       |        |        |        |
| VOC (lbs/hr propane)  | 0.005  | 0.005  | 0.005  |
| VOC (lbs/hr carbon)   | 0.004  | 0.004  | 0.004  |

# TEST DATA

North Afterburner Outlet

12/7/2020

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <u>CEM MONITORING</u> |        |        |        |
|                       |        |        |        |
| VOC (ppm)             | 0.20   | 0.19   | 0.20   |

# Custom Stack Analysis, L.L.C.

## Method 4

Plant: eggitt Aircraft Braking Systems Corporati Date : 12/7/2020

North Afterburner Outlet

|                |       | Meter Box              |        |
|----------------|-------|------------------------|--------|
| Barometer (Pg) | 28.76 | ID:                    | 1      |
| Ambient Temp   |       | Y                      | 1.0004 |
|                |       | $\Delta H$             | 1.986  |
|                |       | $\Delta H$ Set Point : | 2.0    |
|                | Time  | Run Time               |        |
| Start:         | 12:14 | 60                     |        |
| Stop:          | 13:14 |                        |        |

### Run #1

| Cold Box #  |              |        |            |    |           |         |
|-------------|--------------|--------|------------|----|-----------|---------|
| 9           | Meter Volume |        | Meter Temp |    | Cond Temp | VAC "Hg |
| Time        |              |        |            |    |           |         |
| 0           | 478.000      |        | 77         | 75 | 41        | 3       |
| 5           | 481.764      |        | 78         | 76 | 41        | 3       |
| 10          | 485.534      |        | 79         | 76 | 40        | 3       |
| 15          | 489.282      |        | 80         | 76 | 40        | 3       |
| 20          | 493.042      |        | 82         | 77 | 41        | 3       |
| 25          | 496.631      |        | 81         | 77 | 42        | 3       |
| 30          | 500.430      |        | 81         | 77 | 43        | 3       |
| 35          | 504.175      |        | 81         | 78 | 43        | 3       |
| 40          | 508.275      |        | 81         | 79 | 45        | 3       |
| 45          | 511.755      |        | 81         | 77 | 44        | 3       |
| 50          | 515.450      |        | 81         | 77 | 44        | 3       |
| 55          | 519.230      |        | 81         | 78 | 45        | 3       |
| 60          | 523.125      |        |            |    |           |         |
| Vm          | 45.125       |        |            |    |           |         |
| Leak Rate @ | AVG:         |        | 79         |    | 42.4      | 3.0     |
|             | 5.5          | " Hg = | 0.000      |    |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 13:45 | 60       |
| Stop:  | 14:45 |          |

## Run #2

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>6</b>           | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 526.364      | 79         | 77    | 42        | 4       |
| <b>5</b>           | 530.111      | 79         | 77    | 40        | 4       |
| <b>10</b>          | 533.812      | 79         | 77    | 39        | 4       |
| <b>15</b>          | 537.549      | 79         | 77    | 40        | 4       |
| <b>20</b>          | 541.278      | 80         | 77    | 41        | 4       |
| <b>25</b>          | 544.972      | 80         | 77    | 42        | 4       |
| <b>30</b>          | 548.684      | 80         | 77    | 43        | 4       |
| <b>35</b>          | 552.372      | 80         | 77    | 43        | 4       |
| <b>40</b>          | 556.058      | 80         | 78    | 45        | 4       |
| <b>45</b>          | 559.751      | 80         | 78    | 44        | 4       |
| <b>50</b>          | 563.435      | 80         | 78    | 44        | 4       |
| <b>55</b>          | 566.535      | 81         | 79    | 46        | 4       |
| <b>60</b>          | 570.754      |            |       |           |         |
| <b>Vm</b>          | 44.390       |            |       |           |         |
|                    | AVG:         | 79         |       | 42.4      | 4.0     |
| <b>Leak Rate @</b> | 8.0          | " Hg =     | 0.000 |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 15:13 | 60       |
| Stop:  | 16:13 |          |

### Run #3

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>11</b>          | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 571.148      | 78         | 77    | 39        | 4       |
| <b>5</b>           | 574.893      | 78         | 77    | 1         | 4       |
| <b>10</b>          | 578.625      | 79         | 77    | 41        | 4       |
| <b>15</b>          | 582.387      | 79         | 77    | 43        | 4       |
| <b>20</b>          | 586.065      | 79         | 78    | 44        | 4       |
| <b>25</b>          | 589.731      | 80         | 77    | 44        | 4       |
| <b>30</b>          | 593.435      | 80         | 78    | 45        | 4       |
| <b>35</b>          | 597.210      | 80         | 78    | 45        | 5       |
| <b>40</b>          | 600.935      | 79         | 77    | 47        | 5       |
| <b>45</b>          | 604.645      | 79         | 77    | 45        | 5       |
| <b>50</b>          | 608.345      | 80         | 77    | 46        | 5       |
| <b>55</b>          | 612.153      | 79         | 76    | 46        | 5       |
| <b>60</b>          | 615.677      |            |       |           |         |
| <b>Vm</b>          | 44.529       |            |       |           |         |
|                    | AVG:         | 78         |       | 40.5      | 5.0     |
| <b>Leak Rate @</b> | 8.5          | " Hg =     | 0.000 |           |         |

# Custom Stack Analysis, LLC.

## Pitot Traverse Data Sheet

Plant ggitt Aircraft Braking Systems Corpor

Date 12/8/2020

Location South Afterburner

By Ethan M

| Run No. | Pre 1     |      | Post 1    |      | Post 2    |      | Post 3    |      |
|---------|-----------|------|-----------|------|-----------|------|-----------|------|
| Point # | Pitot Δ P | °F   | Pitot Δ P | °F   | Pitot Δ P | °F   | Pitot Δ P | °F   |
| A-1     | 0.06      | 1743 | 0.08      | 1231 | 0.07      | 1356 | 0.07      | 1595 |
| 2       | 0.10      | 1703 | 0.11      | 1449 | 0.09      | 1523 | 0.10      | 1633 |
| 3       | 0.08      | 1538 | 0.11      | 1435 | 0.07      | 1701 | 0.08      | 1523 |
| 4       | 0.07      | 1144 | 0.10      | 1395 | 0.11      | 1658 | 0.07      | 1176 |
| 5       | 0.10      | 1236 | 0.09      | 1121 | 0.08      | 1432 | 0.06      | 1062 |
| 6       | 0.08      | 1087 | 0.07      | 1046 | 0.06      | 1134 | 0.07      | 1087 |
| B-1     | 0.06      | 1153 | 0.06      | 1467 | 0.05      | 1473 | 0.06      | 1543 |
| 2       | 0.07      | 1326 | 0.08      | 1692 | 0.08      | 1657 | 0.11      | 1687 |
| 3       | 0.06      | 1648 | 0.10      | 1581 | 0.07      | 1682 | 0.11      | 1654 |
| 4       | 0.08      | 1305 | 0.07      | 1411 | 0.10      | 1519 | 0.09      | 1521 |
| 5       | 0.10      | 1212 | 0.09      | 1275 | 0.09      | 1389 | 0.06      | 1362 |
| 6       | 0.06      | 1189 | 0.07      | 1168 | 0.06      | 1222 | 0.07      | 1198 |

|         |        |         |        |         |        |         |
|---------|--------|---------|--------|---------|--------|---------|
|         | Run #1 |         | Run #2 |         | Run #3 |         |
|         | 0.28   | 1382.21 | 0.28   | 1417.38 | 0.28   | 1449.46 |
|         | 0.276  | 1409    | 0.292  | 1356    | 0.277  | 1479    |
| Static: | 0.53   |         | 0.57   |         | 0.55   |         |
|         |        |         |        |         |        | 0.53    |

# TEST DATA

|              |                                                |
|--------------|------------------------------------------------|
| COMPANY NAME | Meggitt Aircraft Braking Systems Corporation - |
| ADDRESS      | 1204 Massillon Road                            |
| CITY         | Akron                                          |
| STATE        | OH                                             |
| ZIP          | 44306                                          |
| TEST METHODS | Methods 1-4 & 25A                              |
| CREW MEMBERS | Brian L. Ethan M                               |
| LOCATION     | Outlet                                         |
| SOURCE       | South Afterburner                              |
| CONTROL      |                                                |

|                     | RUN #1    | RUN #2    | RUN #3    |
|---------------------|-----------|-----------|-----------|
| DATE                | 12/8/2020 | 12/8/2020 | 12/8/2020 |
| RUN LENGTH (min)    | 60        | 60        | 60        |
| VOLUME (cubic feet) | 45.212    | 44.380    | 44.801    |
| Y FACTOR            | 1.0004    | 1.0004    | 1.0004    |
| BAROMETRIC          | 28.85     | 28.85     | 28.85     |
| METER TEMP. (R)     | 535.58    | 535.33    | 535.21    |
| STACK TEMP. (R)     | 1842.21   | 1877.38   | 1909.46   |
| AVERAGE ^P          | 0.28      | 0.28      | 0.28      |
| AVERAGE ^H          | 2.00      | 2.00      | 2.00      |
| IMPINGER VOLUME     | 84.70     | 86.90     | 83.20     |
|                     |           |           |           |
| PITOT COEF.         | 0.84      | 0.84      | 0.84      |
| STATIC PRESSURE     | 0.55      | 0.56      | 0.54      |
| STACK AREA          | 7.07      | 7.07      | 7.07      |
|                     |           |           |           |
| CARBON DIOXIDE      | 4.83      | 4.83      | 4.83      |
| OXYGEN              | 11.67     | 11.67     | 11.50     |
| NITROGEN            | 83.50     | 83.50     | 83.67     |

# TEST RESULTS

South Afterburner Outlet  
12/8/2020

|             | RUN #1    | RUN #2    | RUN #3    |
|-------------|-----------|-----------|-----------|
| VM (std)    | 43.197    | 42.422    | 42.834    |
| VW (std)    | 3.991     | 4.095     | 3.921     |
| BWS         | 0.085     | 0.088     | 0.084     |
| MD          | 29.240    | 29.240    | 29.233    |
| MS          | 28.289    | 28.250    | 28.291    |
| VS (ft/sec) | 30.576    | 30.954    | 30.534    |
|             |           |           |           |
| SCFH        | 197115.57 | 195079.74 | 190058.77 |
| ACFM        | 12967.65  | 13127.84  | 12949.88  |
| DCFM        | 3285.26   | 3251.33   | 3167.65   |

Vm (std) = Volume of gas sampled at standard conditions.

Vw (std) = Volume of water vapor collected at standard conditions.

Bws = Stack moisture content.

Md = Determination of dry molecular weight of stack gas.

Ms = Determination of stack gas molecular weight.

Vs = Average gas stack velocity. (ft/sec.)

ACFM = Actual cubic feet per minute of gas velocity.

DCFM = Dry standard cubic feet per minute of gas velocity.

# TEST RESULTS

South Afterburner Outet

12/8/2020

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <u>CEM MONITORING</u> |        |        |        |
|                       |        |        |        |
| VOC (lbs/hr propane)  | 0.002  | 0.002  | 0.002  |
| VOC (lbs/hr carbon)   | 0.002  | 0.002  | 0.001  |

# TEST DATA

South Afterburner Outet

12/8/2020

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <u>CEM MONITORING</u> |        |        |        |
|                       |        |        |        |
| VOC (ppm)             | 0.11   | 0.09   | 0.08   |

# Custom Stack Analysis, L.L.C.

## Method 4

Plant: eggitt Aircraft Braking Systems Corporati

Date : 12/8/2020

South Afterburner Outlet

|                |       | Meter Box              |        |
|----------------|-------|------------------------|--------|
| Barometer (Pg) | 28.85 | ID:                    | 1      |
| Ambient Temp   | 30    | Y                      | 1.0004 |
|                |       | $\Delta H$             | 1.986  |
|                |       | $\Delta H$ Set Point : | 2.0    |
|                | Time  | Run Time               |        |
| Start:         | 8:40  | 60                     |        |
| Stop:          | 9:40  |                        |        |

Run #1

| Cold Box #  |              |        |            |    |           |         |
|-------------|--------------|--------|------------|----|-----------|---------|
| 12          | Meter Volume |        | Meter Temp |    | Cond Temp | VAC "Hg |
| Time        |              |        |            |    |           |         |
| 0           | 669.947      |        | 77         | 75 | 37        | 4       |
| 5           | 673.645      |        | 75         | 75 | 38        | 4       |
| 10          | 677.430      |        | 77         | 77 | 36        | 4       |
| 15          | 681.450      |        | 77         | 77 | 39        | 4       |
| 20          | 685.020      |        | 75         | 75 | 39        | 4       |
| 25          | 688.905      |        | 75         | 76 | 40        | 4       |
| 30          | 692.605      |        | 76         | 74 | 40        | 4       |
| 35          | 696.250      |        | 77         | 75 | 43        | 4       |
| 40          | 700.100      |        | 76         | 74 | 41        | 4       |
| 45          | 703.955      |        | 77         | 74 | 43        | 4       |
| 50          | 707.740      |        | 76         | 74 | 42        | 4       |
| 55          | 711.462      |        | 76         | 74 | 43        | 4       |
| 60          | 715.159      |        |            |    |           |         |
| Vm          | 45.212       |        |            |    |           |         |
| Leak Rate @ | AVG:         |        | 76         |    | 40.1      | 4.0     |
|             | 7.5          | " Hg = | 0.000      |    |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 10:40 | 60       |
| Stop:  | 11:40 |          |

## Run #2

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>11</b>          | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 716.015      | 76         | 74    | 39        | 5       |
| <b>5</b>           | 719.788      | 76         | 74    | 41        | 5       |
| <b>10</b>          | 723.551      | 76         | 74    | 43        | 5       |
| <b>15</b>          | 727.279      | 77         | 75    | 42        | 5       |
| <b>20</b>          | 731.004      | 76         | 74    | 42        | 5       |
| <b>25</b>          | 734.717      | 76         | 75    | 44        | 5       |
| <b>30</b>          | 738.405      | 76         | 75    | 45        | 5       |
| <b>35</b>          | 742.091      | 77         | 74    | 46        | 5       |
| <b>40</b>          | 745.754      | 77         | 74    | 46        | 5       |
| <b>45</b>          | 749.512      | 76         | 75    | 47        | 5       |
| <b>50</b>          | 753.100      | 77         | 74    | 47        | 5       |
| <b>55</b>          | 756.862      | 76         | 74    | 48        | 5       |
| <b>60</b>          | 760.395      |            |       |           |         |
| <b>Vm</b>          | 44.380       |            |       |           |         |
|                    | AVG:         | 75         |       | 44.2      | 5.0     |
| <b>Leak Rate @</b> | 10.0         | " Hg =     | 0.000 |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 12:15 | 60       |
| Stop:  | 13:15 |          |

### Run #3

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>9</b>           | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 761.450      | 75         | 74    | 42        | 5       |
| <b>5</b>           | 765.015      | 76         | 74    | 43        | 5       |
| <b>10</b>          | 768.815      | 77         | 74    | 43        | 5       |
| <b>15</b>          | 772.445      | 76         | 74    | 44        | 5       |
| <b>20</b>          | 776.295      | 77         | 74    | 46        | 5       |
| <b>25</b>          | 780.225      | 76         | 75    | 46        | 5       |
| <b>30</b>          | 783.825      | 77         | 74    | 47        | 5       |
| <b>35</b>          | 787.550      | 76         | 74    | 47        | 5       |
| <b>40</b>          | 791.281      | 77         | 74    | 46        | 5       |
| <b>45</b>          | 795.039      | 76         | 75    | 46        | 5       |
| <b>50</b>          | 798.793      | 76         | 74    | 48        | 5       |
| <b>55</b>          | 802.514      | 76         | 74    | 46        | 5       |
| <b>60</b>          | 806.251      |            |       |           |         |
| <b>Vm</b>          | 44.801       |            |       |           |         |
|                    | AVG:         | 75         |       | 45.3      | 5.0     |
| <b>Leak Rate @</b> | 9.5          | " Hg =     | 0.000 |           |         |

# Fyrite

Date: 12-7-20

Technician: Ethan

| Run #1 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | <u>Avg</u>      |       |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|-------|
|        | Time            | 12:15 | Time            | 12:45 | Time            | 13:07 |                 |       |
|        | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.33  |
|        | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.5  | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.17 |

| Run #2 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | <u>Avg</u>      |       |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|-------|
|        | Time            | 13:50 | Time            | 14:17 | Time            | 14:42 |                 |       |
|        | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.17  |
|        | O <sup>2</sup>  | 12.5  | O <sup>2</sup>  | 12.5  | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.33 |

| Run #3 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | <u>Avg</u>      |       |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|-------|
|        | Time            | 15:16 | Time            | 15:38 | Time            | 16:00 |                 |       |
|        | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.0   | CO <sup>2</sup> | 4.17  |
|        | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 12.5  | O <sup>2</sup>  | 12.17 |

# Fyrite

Date:

12-8-20

Technician:

F. Thompson

| Run #1 | <u>1</u>        |      | <u>2</u>        |      | <u>3</u>        |      | Avg             |       |
|--------|-----------------|------|-----------------|------|-----------------|------|-----------------|-------|
|        | Time            | 8:41 | Time            | 9:16 | Time            | 9:40 |                 |       |
|        | CO <sup>2</sup> | 4.5  | CO <sup>2</sup> | 5.0  | CO <sup>2</sup> | 4.5  | CO <sup>2</sup> | 4.83  |
|        | O <sup>2</sup>  | 12.0 | O <sup>2</sup>  | 11.5 | O <sup>2</sup>  | 11.5 | O <sup>2</sup>  | 11.67 |

| Run #2 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | Avg             |       |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|-------|
|        | Time            | 10:44 | Time            | 11:09 | Time            | 11:35 |                 |       |
|        | CO <sup>2</sup> | 5.0   | CO <sup>2</sup> | 5.0   | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 4.83  |
|        | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 12.0  | O <sup>2</sup>  | 11.67 |

| Run #3 | <u>1</u>        |       | <u>2</u>        |       | <u>3</u>        |       | Avg             |      |
|--------|-----------------|-------|-----------------|-------|-----------------|-------|-----------------|------|
|        | Time            | 12:17 | Time            | 12:46 | Time            | 13:13 |                 |      |
|        | CO <sup>2</sup> | 5.0   | CO <sup>2</sup> | 4.5   | CO <sup>2</sup> | 5.0   | CO <sup>2</sup> | 4.83 |
|        | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 11.5  | O <sup>2</sup>  | 11.5 |

# **Appendix #2**

## **Laboratory Data**

Lab Data Sheet For: Meggitt Aircraft Braking Systems Corporation - North Afterburner OutletBy: Ethan MMoisture Weights

## Moisture

| RUN # 1 |         |            |            |            |            |            |            |                   |
|---------|---------|------------|------------|------------|------------|------------|------------|-------------------|
|         | Box ID  | grams<br>1 | grams<br>2 | grams<br>3 | grams<br>4 | grams<br>5 | grams<br>6 | grams<br>Drierite |
|         | Gross   | 9          | 821.3      | 652.2      | 537.2      |            |            | 981.5             |
|         | Tare    |            | 749.7      | 651.1      | 536.5      |            |            | 974.1             |
|         | Net     |            | 71.6       | 1.1        | 0.7        | 0.0        | 0.0        | 7.4               |
|         | Reagent |            | H2O        | H2O        |            |            |            |                   |
|         |         | mLs        | 100.0      | 100.0      |            |            |            |                   |

|                  |       | grams            |      | grams   |      |
|------------------|-------|------------------|------|---------|------|
| Initial Imp mL = | 200.0 | Impinger Total = | 73.4 | Total = | 80.8 |

| RUN # 2 |         |            |            |            |            |            |            |                   |
|---------|---------|------------|------------|------------|------------|------------|------------|-------------------|
|         | Box ID  | grams<br>1 | grams<br>2 | grams<br>3 | grams<br>4 | grams<br>5 | grams<br>6 | grams<br>Drierite |
|         | Gross   | 6          | 688.3      | 755.3      | 508.4      |            |            | 956.0             |
|         | Tare    |            | 612.6      | 754.1      | 507.8      |            |            | 948.5             |
|         | Net     |            | 75.7       | 1.2        | 0.6        | 0.0        | 0.0        | 7.5               |
|         | Reagent |            | H2O        | H2O        |            |            |            |                   |
|         |         | mLs        | 100.0      | 100.0      |            |            |            |                   |

|                  |       | grams            |      | grams   |    |
|------------------|-------|------------------|------|---------|----|
| Initial Imp mL = | 200.0 | Impinger Total = | 77.5 | Total = | 85 |

| RUN # 3 |         |            |            |            |            |            |            |                   |
|---------|---------|------------|------------|------------|------------|------------|------------|-------------------|
|         | Box ID  | grams<br>1 | grams<br>2 | grams<br>3 | grams<br>4 | grams<br>5 | grams<br>6 | grams<br>Drierite |
|         | Gross   | 11         | 802.2      | 723.5      | 535.8      |            |            | 997.8             |
|         | Tare    |            | 729.0      | 722.6      | 535.0      |            |            | 989.7             |
|         | Net     |            | 73.2       | 0.9        | 0.8        | 0.0        | 0.0        | 8.1               |
|         | Reagent |            | H2O        | H2O        |            |            |            |                   |
|         |         | mLs        | 100.0      | 100.0      |            |            |            |                   |

|                  |       | grams            |      | grams   |    |
|------------------|-------|------------------|------|---------|----|
| Initial Imp mL = | 200.0 | Impinger Total = | 74.9 | Total = | 83 |

Lab Data Sheet For: Meggitt Aircraft Braking Systems Corporation - South Afterburner Outet

By: Ethan M

Moisture Weights

Moisture

| RUN # 1 |         | Box ID | grams    | grams | grams | grams | grams | grams |
|---------|---------|--------|----------|-------|-------|-------|-------|-------|
|         |         |        | 1        | 2     | 3     | 4     | 5     | 6     |
|         |         |        | Drierite |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         | Gross   | 12     | 697.9    | 546.8 | 625.2 |       |       | 993.1 |
|         | Tare    |        | 622.0    | 546.1 | 624.8 |       |       | 985.4 |
|         | Net     |        | 75.9     | 0.7   | 0.4   | 0.0   | 0.0   | 7.7   |
|         | Reagent |        | H2O      | H2O   |       |       |       |       |
|         | mLs     |        | 100.0    | 100.0 |       |       |       |       |

|                  |       |                  |             |         |               |
|------------------|-------|------------------|-------------|---------|---------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>77 | Total = | grams<br>84.7 |
|------------------|-------|------------------|-------------|---------|---------------|

| RUN # 2 |         | Box ID | grams    | grams | grams | grams | grams | grams |
|---------|---------|--------|----------|-------|-------|-------|-------|-------|
|         |         |        | 1        | 2     | 3     | 4     | 5     | 6     |
|         |         |        | Drierite |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         | Gross   | 11     | 806.6    | 723.2 | 535.6 |       |       | 970.4 |
|         | Tare    |        | 729.2    | 722.3 | 535.1 |       |       | 962.3 |
|         | Net     |        | 77.4     | 0.9   | 0.5   | 0.0   | 0.0   | 8.1   |
|         | Reagent |        | H2O      | H2O   |       |       |       |       |
|         | mLs     |        | 100.0    | 100.0 |       |       |       |       |

|                  |       |                  |               |         |               |
|------------------|-------|------------------|---------------|---------|---------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>78.8 | Total = | grams<br>86.9 |
|------------------|-------|------------------|---------------|---------|---------------|

| RUN # 3 |         | Box ID | grams    | grams | grams | grams | grams | grams |
|---------|---------|--------|----------|-------|-------|-------|-------|-------|
|         |         |        | 1        | 2     | 3     | 4     | 5     | 6     |
|         |         |        | Drierite |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         |         |        |          |       |       |       |       |       |
|         | Gross   | 9      | 824.8    | 652.0 | 536.9 |       |       | 979.0 |
|         | Tare    |        | 750.0    | 651.4 | 536.6 |       |       | 971.5 |
|         | Net     |        | 74.8     | 0.6   | 0.3   | 0.0   | 0.0   | 7.5   |
|         | Reagent |        | H2O      | H2O   |       |       |       |       |
|         | mLs     |        | 100.0    | 100.0 |       |       |       |       |

|                  |       |                  |               |         |               |
|------------------|-------|------------------|---------------|---------|---------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>75.7 | Total = | grams<br>83.2 |
|------------------|-------|------------------|---------------|---------|---------------|

# **Appendix #3**

## **Calibration Data**



B21856!

Scott-Gross Co., Inc.  
664 Magnolia Ave.  
Lexington, KY 40505  
(859)231-0225 (888)431-5882

## Certificate of Analysis


Certification Date: 12 January 2017  
Certificate Number: 0097B-02T5-C01  
Mixture Grade: EPA Protocol Standard Gas Mixture  
Lot Number: 0097B-02T5  
Expiration Date: 12 January 2025  
Cylinder Number: EB0049442  
Part Number: T5L EPA2RATAP-14

| Mixture Components | Requested Composition | Certified Composition | U (Expanded Uncertainty, k=2) |
|--------------------|-----------------------|-----------------------|-------------------------------|
| Propane            | 43 ppm                | 47.05 PPM             | +/- 0.12 PPM (absolute)       |
| Air                | Balance               | Balance               |                               |

Cylinder Pressure: 1900 psi – Do not use below 100 psi (0.7 megapascals)  
Production Lab: Tier 5 Labs, LLC, Indianapolis, IN, PGVP Vendor ID R12017  
Procedure Used: EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012  
Analytical Method: C3H8: FTIR  
Multipoint Calibration Date: Propane: 12/29/2016

| Reference Standards |         |            |      |           |         |               |                 |                |
|---------------------|---------|------------|------|-----------|---------|---------------|-----------------|----------------|
| Serial Number       | Lot     | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
| CAL017809           | 83-J-12 | 8/17/2017  | SRM  | C3H8      | Air     | 48.83 PPM     | 0.225           | 1667b          |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025-2005.

  
Jeff Lynn



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 3415-11278230

Traceable® Certificate of Calibration for Digital Calipers

Customer: Custom Slack Analysis, LLC, 14614 Cenfield Street NE, Alliance, OH-44601, U.S.A.

Instrument Identification:

Model: 3415,

S/N: 101856179

Manufacturer: Control Company

Standards/Equipment:

| Description | Serial Number | Due Date    | NIST Traceable Reference |
|-------------|---------------|-------------|--------------------------|
| Gage Set    | 99146223      | 17 Dec 2020 | 1000449283               |

Certificate Information:

Technician: 57

Procedure: CAL-05

Cal Date: 12 May 2020

Cal Due Date: 12 May 2021

Test Conditions: 55.18%RH 22.45°C 1018mBar

Calibration Data:

| Unit(s)   | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U      | TUR    |
|-----------|---------|----------|--------|---------|---------|--------|-------|-------|---------|--------|
| in        | N.A.    | N.A.     |        | 0.1000  | 0.1005  | Y      | 0.099 | 0.101 | 0.0003  | 3.33:1 |
| in        | N.A.    | N.A.     |        | 2.0000  | 2.0005  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in        | N.A.    | N.A.     |        | 4.0000  | 4.0005  | Y      | 3.996 | 4.004 | 0.0004  | >4:1   |
| in        | N.A.    | N.A.     |        | 6.0000  | 6.0005  | Y      | 5.994 | 6.006 | 0.0005  | >4:1   |
| In depth  | N.A.    | N.A.     |        | 2.0000  | 2.000   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| In inside | N.A.    | N.A.     |        | 1.0000  | 1.0005  | Y      | 0.999 | 1.001 | 0.00031 | 3.23:1 |
| In step   | N.A.    | N.A.     |        | 2.0000  | 1.9985  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor  $k=2$  to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy= $\pm(\text{Max}-\text{Min})/2$ ; Min=As Left Nominal(Rounded) - Tolerance; Max=As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*

Nicol Rodriguez, Quality Manager

*Marisa Elms*

Marisa Elms, Technical Manager

Note:

Maintaining Accuracy:

In our opinion once calibrated your Digital Calipers should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Calipers change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

Issue Date: 12 May 2020

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.traceable.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2015 Quality Certified by DNV GL, Certificate No. CERT-01805-2006-AQ-HOU-ANAB.  
International Laboratory Accreditation Cooperation - Multilateral Recognition Arrangement (ILAC-MRA).

B21925B



Scott-Gross Co., Inc.  
664 Blagden Ave.  
Lexington, KY 40505  
(859)231-0225 (888)431-5882

|                     |                                   |                       |                  |
|---------------------|-----------------------------------|-----------------------|------------------|
| Cylinder Number:    | CC444989                          | Certification Date:   | 28 April 2017    |
| Mixture Grade:      | EPA Protocol Standard Gas Mixture | Expiration Date:      | 29 April 2025    |
| Certificate Number: | 1147B-02T5-C01                    | Lot Number:           | 1147B-02T5       |
| Cylinder Pressure:  | 2015 PSIG                         | Customer Part Number: | T5L EPA2RATAP-19 |

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

### Certified Concentrations

| Component | Concentration | Uncertainty            | Assay Dates |
|-----------|---------------|------------------------|-------------|
| Propane   | 24.7 PPM      | +/- 0.2 PPM (absolute) | 4/28/2017   |
| Air       | Balance       |                        |             |

### Analytical Instrumentation

| Component | Analytical Principle | Make   | Model       | Serial     | MPC Date  |
|-----------|----------------------|--------|-------------|------------|-----------|
| Propane   | FTIR                 | Thermo | Antaris IGS | AWZ1200117 | 4/17/2017 |


### Reference Standards

| Serial Number | Lot        | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|------------|------------|------|-----------|---------|---------------|-----------------|----------------|
| CC459851      | 2186A-01T5 | 11/10/2024 | GMIS | C3H8      | N2      | 247.7 PPM     | 0.411           | 2644a          |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of  $k=2$  to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid.

This calibration meets the requirements of ISO/IEC 17025-2005

  
Analyst: Allison Hanover

  
Reviewer: Jeff Lynn

Production Laboratory:

Tier 5 Labs, LLC

5353 W. Southern Ave.

Indianapolis, IN 46241

PGVP Vendor ID R12017

B21925B



Scott-Gross Co., Inc.  
664 Magnolia Ave.  
Lexington, KY 40505  
(859)231-6225 (888)431-5882

|                     |                                   |                       |                  |
|---------------------|-----------------------------------|-----------------------|------------------|
| Cylinder Number:    | CC444989                          | Certification Date:   | 28 April 2017    |
| Mixture Grade:      | EPA Protocol Standard Gas Mixture | Expiration Date:      | 29 April 2025    |
| Certificate Number: | 1147B-02T5-C01                    | Lot Number:           | 1147B-02T5       |
| Cylinder Pressure:  | 2015 PSIG                         | Customer Part Number: | T5L EPA2RATAP-19 |

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

### Certified Concentrations

| Component | Concentration | Uncertainty            | Assay Dates |
|-----------|---------------|------------------------|-------------|
| Propane   | 24.7 PPM      | +/- 0.2 PPM (absolute) | 4/28/2017   |
| Air       | Balance       |                        |             |


### Analytical Instrumentation

| Component | Analytical Principle | Make   | Model       | Serial     | MPC Date  |
|-----------|----------------------|--------|-------------|------------|-----------|
| Propane   | FTIR                 | Thermo | Antaris IGS | AWZ1200117 | 4/17/2017 |

### Reference Standards


| Serial Number | Lot        | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|------------|------------|------|-----------|---------|---------------|-----------------|----------------|
| CC459851      | 2186A-01T5 | 11/10/2024 | GMIS | C3H8      | N2      | 247.7 PPM     | 0.411           | 2644a          |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of  $k=2$  to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025-2005.

  
Analyst: Allison Hanover

  
Reviewer: Jeff Lynn

Production Laboratory:  
Tier 5 Labs, LLC  
5353 W. Southern Ave.  
Indianapolis, IN 46241  
PGVP Vendor ID R12017



**LIQUID TECHNOLOGY CORPORATION**  
"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis  
**- EPA PROTOCOL GAS -**

Customer IE Monitoring Instruments (Worthington, OH)  
Date October 06, 2014  
Delivery Receipt DR-53322  
Gas Standard 13.8 ppm Propane/Air - EPA PROTOCOL  
Final Analysis Date October 06, 2014  
Expiration Date October 07, 2022

B21477B

Component Propane  
Balance Gas Air

Analytical Data:  
EPA Protocol, Section No. 2.2, Procedure G-1.

**DO NOT USE BELOW 100 psig**

Reported Concentrations  
**Propane: 13.7 ppm +/- 0.1 ppm**  
**Air: Balance**

Reference Standards:

SRM/GMIS: GMIS  
Cylinder Number: CC-165367  
Concentration: 20.21 ppm Propane (+/- 0.09 ppm)  
Expiration Date: 12/02/18  
NIST Sample Number: NA

GMIS Traceability

SRM-1667b  
XF-003853 B  
49.54 ppm Propane (+/- 0.26 ppm)  
07/12/15  
83-I-14

Certification Instrumentation

Component: Propane  
Make/Model: Agilent 7890A  
Serial Number: CN10736166  
Principal of Measurement: GC-FID  
Last Calibration: September 28, 2014

Cylinder Data

Cylinder Serial Number: EB-0051537  
Cylinder Volume: 138 Cubic Feet

Cylinder Outlet: CGA 590  
Cylinder Pressure: 1950 psig, 70°F

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-12/531.

Certified by:

*Cole Dylewski*

Cole Dylewski

PGVP Vendor ID: E12014

**"UNMATCHED EXCELLENCE"**



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 1870-11290275

**Traceable® Certificate of Calibration for Digital Barometer Module**

Customer: Custom Stack Analysis, LLC, 14614 Cenfield Street NE, Alliance, OH-44601, U.S.A.

**Instrument Identification:**

Model: 1870,

S/N: 90724105

Manufacturer: Control Company

**Standards/Equipment:**

| Description               | Serial Number  | Due Date    | NIST Traceable Reference |
|---------------------------|----------------|-------------|--------------------------|
| Digital Thermometer       | 221197993      | 10 Oct 2020 | 4000-10785768            |
| Chilled Mirror Hygrometer | 31874/1H2048MR | 22 Jan 2021 | 18004                    |
| Digital Barometer         | D4540001       | 01 Nov 2020 | 1000447551               |

**Certificate Information:**

Technician: 57

Procedure: CAL-31

Cal Date: 17 May 2020

Cal Due Date: 17 May 2021

Test Conditions: 57.18%RH 22.6°C 1012mBar

**Calibration Data:**

| Unit(s) | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U   | TUR  |
|---------|---------|----------|--------|---------|---------|--------|-------|-------|------|------|
| %RH     | N.A.    | N.A.     |        | 48.33   | 32      | N      | 43    | 53    | 0.74 | >4:1 |
| °C      | N.A.    | N.A.     |        | 24.29   | 24      | Y      | 23.29 | 25.29 | 0.05 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 806.00  | 812     | Y      | 795   | 817   | 0.62 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 909.98  | 914     | Y      | 899   | 921   | 0.62 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 1018.72 | 1022    | Y      | 1008  | 1030  | 0.62 | >4:1 |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement": (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*  
Nicol Rodriguez, Quality Manager

*Marisa Elms*  
Marisa Elms, Technical Manager

Note :

**Maintaining Accuracy:**

In our opinion once calibrated your Digital Barometer Module should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Barometer Module change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

**Recalibration:**

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

Issue Date : 17 May 2020

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.traceable.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2015 Quality Certified by DNV GL, Certificate No. CERT-D1805-2006-AQ-HOU-ANAB.  
International Laboratory Accreditation Cooperation - Multilateral Recognition Arrangement (ILAC-MRA).



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 3415-10347847

**Traceable® Certificate of Calibration for Digital Calipers**

Manufactured for and distributed by: Control Company 12554 Galveston Rd B230, Webster, TX 77598

**Instrument Identification:**

Model: 3415,

S/N: 192125551

Manufacturer: Control Company

**Standards/Equipment:**

| Description    | Serial Number | Due Date    | NIST Traceable Reference |
|----------------|---------------|-------------|--------------------------|
| Gage Block Set | 99146223      | 06 Dec 2019 | 1000434942               |

**Certificate Information:**

Technician: 57

Procedure: CAL-05

Cal Date: 23 Apr 2019

Cal Due Date: 23 Apr 2021

Test Conditions: 57.01%RH 23.96°C 1018mBar

**Calibration Data: (New Instrument)**

| Unit(s)   | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U      | TUR    |
|-----------|---------|----------|--------|---------|---------|--------|-------|-------|---------|--------|
| in        | N.A.    | N.A.     |        | 0.1000  | 0.0995  | Y      | 0.099 | 0.101 | 0.0003  | 3.33:1 |
| in        | N.A.    | N.A.     |        | 2.0000  | 1.9985  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in        | N.A.    | N.A.     |        | 4.0000  | 3.998   | Y      | 3.996 | 4.004 | 0.0004  | >4:1   |
| in        | N.A.    | N.A.     |        | 6.0000  | 5.997   | Y      | 5.994 | 6.006 | 0.0005  | >4:1   |
| in depth  | N.A.    | N.A.     |        | 2.0000  | 1.998   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in inside | N.A.    | N.A.     |        | 1.0000  | 0.9995  | Y      | 0.999 | 1.001 | 0.00031 | 3.23:1 |
| in step   | N.A.    | N.A.     |        | 2.0000  | 2.000   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement": (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*

Nicol Rodriguez, Quality Manager

*Asur Justice*

Asur Justice, Technical Manager

Note:

**Maintaining Accuracy:**

In our opinion once calibrated your Digital Calipers should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Calipers change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

**Recalibration:**

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.control3.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2008 Quality Certified by DNV GL, Certificate No. CERT-01805-2008-AQ-HOU-RvA.  
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).

**MATHESON**

ask...The Gas Professionals™

**Certificate of Batch Analysis**

| <b>Manufacturing Location</b><br>Matheson<br>1055 Garden Street<br>Greensburg, PA 15601<br><br><b>CYLINDER NUMBER(S)</b><br><br>748203Y<br>30-872<br>W-450273<br>TWC-563435<br>279432Y<br>3041791Y<br><br>24698<br>BA-1423<br>NK00455<br><br>7899<br>Q8572<br><br>784192<br>3597456Y<br>SG904256<br><br>935283<br>46-1392<br><br><b>Lot No:</b> 118K41520<br><br><b>Fill Date:</b> 4/28/2015                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     | <b>To:</b> Matheson                                  |                         | <b>Sales Order No:</b><br><b>Purchase Order:</b>  |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------|-------------------------|---------------------------------------------------|-------------------------|-------|-------------------|--------|---------|------|---|---|-----|------|------|-----|---|-------|----|-----|-----|---|----------------|----|----|-----|---|-----------------|----|----|-----|---|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | <b>Product:</b> Air                                  |                         | <b>Cylinder Size:</b> 1L<br><b>Valve:</b> CGA 590 |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | <b>Grade:</b> Ultra Zero<br><b>Part No:</b> G2001312 |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                      |                         | <b>Pressure:</b> 2400 PSIG                        |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| <table border="1"><thead><tr><th>Component</th><th>Specification</th><th>Certified Concentration</th><th>Units</th><th>Analytical Method</th></tr></thead><tbody><tr><td>Oxygen</td><td>20 - 22</td><td>20.8</td><td>%</td><td>J</td></tr><tr><td>THC</td><td>&lt;0.1</td><td>0.01</td><td>ppm</td><td>E</td></tr><tr><td>Water</td><td>&lt;2</td><td>1.6</td><td>ppm</td><td>F</td></tr><tr><td>Carbon Dioxide</td><td>&lt;1</td><td>ND</td><td>ppm</td><td>H</td></tr><tr><td>Carbon Monoxide</td><td>&lt;1</td><td>ND</td><td>ppm</td><td>H</td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr></tbody></table> |                                                      | Component               | Specification                                     | Certified Concentration | Units | Analytical Method | Oxygen | 20 - 22 | 20.8 | % | J | THC | <0.1 | 0.01 | ppm | E | Water | <2 | 1.6 | ppm | F | Carbon Dioxide | <1 | ND | ppm | H | Carbon Monoxide | <1 | ND | ppm | H |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Component                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | Specification                                        | Certified Concentration | Units                                             | Analytical Method       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Oxygen                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | 20 - 22                                              | 20.8                    | %                                                 | J                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| THC                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | <0.1                                                 | 0.01                    | ppm                                               | E                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Water                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | <2                                                   | 1.6                     | ppm                                               | F                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Carbon Dioxide                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | <1                                                   | ND                      | ppm                                               | H                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| Carbon Monoxide                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | <1                                                   | ND                      | ppm                                               | H                       |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| <b>COMMENTS</b><br>Product Composition verified by instrumentation calibrated with at least one of the following: NIST traceable weights, gas mixtures traceable to NIST weights, NIST gas standards such as NTRM's or SRM's, manufacturer NIST calibrations                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| <b>Analytical Method Key</b><br>A Trace oxygen analyzer<br>B Gas chromatograph with thermal conductivity detector<br>C Gas chromatograph with flame ionization detector<br>D Trace nitric oxide analyzer<br>E Total hydrocarbon analyzer<br>F Specific moisture analyzer<br>G Gas chromatograph with thermal conductivity detector<br>H Gas chromatograph with discharge ionization detector<br>I Specific carbon monoxide analyzer<br>J Percent oxygen analyzer<br>K Specific carbon dioxide analyzer<br>L Binary gas mixture analyzer                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |                                                      |                         |                                                   |                         |       |                   |        |         |      |   |   |     |      |      |     |   |       |    |     |     |   |                |    |    |     |   |                 |    |    |     |   |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |

**IMPORTANT**

The information contained herein has been prepared at your request by qualified experts within Matheson. While we believe that the information is accurate within the limits of the analytical methods employed and is complex to the extent of the specified analysis performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Matheson arising out of the use of the information contained herein exceed the fee established for providing such information.

The undersigned certifies that the product(s) listed above reflect gas phase by volume (unless otherwise indicated) and meet or exceed the minimum purity specification(s).

Analyst

12/20/16

Date



## Page 1 of 1

APEX INSTRUMENTS

EPA Method 5

560 Series Meter Box Calibration

Pre-Test Orifice Method

Metric Meter Box Volume Units, English K Factor

Filename: C:\Customer Project Files\APPENDIX\Cal Sheets\Meter Boxes\Meter Box 1 5-7-20.xlsja  
Revised: 7/25/95 Version: 2.2

Model #: 1  
Serial #:

Date: 5/7/2020  
Barometric Pressure: 28.44 (in Hg)  
Theoretical Critical Vacuum: 13.42 (in Hg)

CONVERSION FACTORS

1 mm Hg = 0.1330 kPa  
1 inch = 0.39370 cm  
1 inch = 0.03937 mm  
1 cu ft = 28.32 liters

\*\*\*\*\*

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

IMPORTANT The Critical Orifice Coefficient, K, must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in Hg)<sup>0.5</sup>(min))

\*\*\*\*\*

----- DRY GAS METER READINGS -----

| dH<br>in H <sub>2</sub> O | Time<br>(min) | Volume                        |                             | Volume            |                  | Initial Temps.    |                  | Final Temps.      |                           | Orifice K<br>Serial#<br>(number) | Coefficient<br>(see above) | Actual - Ambient Temperature -- |                    | Average Temperatures --  |                           |                            |
|---------------------------|---------------|-------------------------------|-----------------------------|-------------------|------------------|-------------------|------------------|-------------------|---------------------------|----------------------------------|----------------------------|---------------------------------|--------------------|--------------------------|---------------------------|----------------------------|
|                           |               | Initial<br>(ft <sup>3</sup> ) | Final<br>(ft <sup>3</sup> ) | Total<br>(liters) | Inlet<br>(deg F) | Outlet<br>(deg F) | Inlet<br>(deg F) | Outlet<br>(deg F) | Vacuum Initial<br>(in Hg) |                                  |                            | Final<br>(deg F)                | Average<br>(deg F) | DGM<br>Outlet<br>(deg R) | DGM<br>Overall<br>(deg R) | Ambient<br>Temp<br>(deg R) |
| 0.5                       | 10            | 311.555                       | 315.488                     | 111.38256         | 62               | 61                | 55               | 62                | 12                        | 0.30390681                       | 15                         | 64                              | 64                 | 521.5                    | 522.5                     | 524                        |
| 0.93                      | 10            | 315.468                       | 320.81                      | 150.71708         | 67               | 63                | 68               | 63                | 16                        | 0.41080925                       | 15                         | 64                              | 65                 | 523                      | 524.75                    | 524.5                      |
| 1.4                       | 10            | 320.81                        | 327.085                     | 177.77804         | 66               | 64                | 68               | 65                | 19                        | 0.48449779                       | 15                         | 65                              | 65                 | 524.5                    | 525.75                    | 525                        |
| 2.1                       | 5             | 327.085                       | 331.027                     | 111.63744         | 68               | 65                | 69               | 66                | 23                        | 0.60910402                       | 15                         | 66                              | 66                 | 525.5                    | 527                       | 526                        |
| 3.8                       | 5             | 331.027                       | 336.224                     | 147.17904         | 68               | 66                | 70               | 67                | 31                        | 0.80595932                       | 15                         | 66                              | 66                 | 526.5                    | 527.75                    | 526                        |

----- DRY GAS METER READINGS -----

| ----- CRITICAL ORIFICE READINGS ----- |  |  |  |  |  |  |  |  |  |  |  |  |
|---------------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|
| ----- CRITICAL ORIFICE READINGS ----- |  |  |  |  |  |  |  |  |  |  |  |  |

\*\*\*\*\* RESULTS \*\*\*\*\*

--- DRY GAS METER --- ORIFICE --- ORIFICE ---

| VOLUME CORRECTED |         | VOLUME CORRECTED |           | VOLUME CORRECTED |           | VOLUME CORRECTED |          | VOLUME CORRECTED |         | VOLUME CORRECTED |         | VOLUME CORRECTED |         |
|------------------|---------|------------------|-----------|------------------|-----------|------------------|----------|------------------|---------|------------------|---------|------------------|---------|
| Vm(std)          | Vm(std) | Vm(std)          | Vm(std)   | Vm(std)          | Vm(std)   | Vm(std)          | Vm(std)  | Vm(std)          | Vm(std) | Vm(std)          | Vm(std) | Vm(std)          | Vm(std) |
| 3.7811759        | 107.08  | 3.77576          | 106.92952 | 3.94373          | 111.36256 | 4.1014902        | 114.4742 | 4.2691958        | 117.708 | 4.436998         | 120.81  | 4.6048088        | 123.92  |
| 5.1002748        | 144.44  | 5.094088         | 144.44    | 5.087902         | 144.44    | 5.081716         | 144.44   | 5.07553          | 144.44  | 5.069348         | 144.44  | 5.063165         | 144.44  |
| 6.0094088        | 170.19  | 6.003222         | 170.19    | 6.000029         | 170.19    | 5.996844         | 170.19   | 5.990659         | 170.19  | 5.984474         | 170.19  | 5.978289         | 170.19  |
| 3.7729909        | 106.85  | 3.766756         | 106.85    | 3.760522         | 106.85    | 3.754287         | 106.85   | 3.748052         | 106.85  | 3.741817         | 106.85  | 3.735582         | 106.85  |
| 4.988287         | 141.28  | 4.982052         | 141.28    | 4.975817         | 141.28    | 4.969582         | 141.28   | 4.963347         | 141.28  | 4.957112         | 141.28  | 4.950877         | 141.28  |
| Average Y        |         | Average Y        |           | Average Y        |           | Average Y        |          | Average Y        |         | Average Y        |         | Average Y        |         |
| 1.00043          |         | 1.00043          |           | 1.00043          |           | 1.00043          |          | 1.00043          |         | 1.00043          |         | 1.00043          |         |

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dh@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

SIGNED: Brian Lemasters

Date: 5/7/2020

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

595572

FOR Custom Scale 593P

14614 Centerville St Alliance Ohio

☐ 14941 Liberty Hill Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5525 Galileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7180  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45089  
 513-777-5800  
☐ 2351 Jaclyn Court  
 SOUTH BEND, IN 46614  
☐ 100 McClunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

2019-01-01

TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO.

STATE OF Ohio

WEIGHT  
SIN'S

Class 1000

SCALE  
TECHNICIAN: MR.

SIGNATURE

ACCEPTED BY: John Doe  
SIGNATURE

PARTS USED

| TAG NO. | MFG   | MOD NO.   | S/N        | LOC. | CAP.   | GRAD. SIZE | NORM RING        | CAL FRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|---------|-------|-----------|------------|------|--------|------------|------------------|----------|------------|-----------|----------|
| 1       | Chaus | Navigator | 1119252904 | Lab  | 2,100g | 0.1g       | HI 2000<br>LO 10 | 6 months | YES        | NO        | 11/2020  |
| 2       | 500   | 500.0     |            |      | 500.0  |            |                  |          |            |           |          |
| 3       | 1000  | 1000.0    |            |      | 1000.0 |            |                  |          |            |           |          |
| 4       |       |           |            |      |        |            |                  |          |            |           |          |
| 5       |       |           |            |      |        |            |                  |          |            |           |          |
| 6       |       |           |            |      |        |            |                  |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

# BRECHBUHLER Scales, Inc.

## SCALE INSPECTION REPORT

584495

FOR CUSTOM STACK 393P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/10/20

- ☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3086  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3305 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-495-8489  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2680  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-298-7980  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 528 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46614  
☐ 8930 Crescent Park Drive  
 WEST CHESTER, OH 43086  
 513-777-5800  
☐ 100 McLunkin Road  
 NITRO, WV 25143  
 304-755-0886

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

2019. 0/87

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO.

Gram 1113

WEIGHT  
S/N'S

SCALE  
TECHNICIAN: M.P.

SIGNATURE

ACCEPTED BY: J. J. J.

SIGNATURE

PARTS USED

| TAG NO.  | MFG    | MOD NO.    | S/N        | LOC.     | CAP.    | GRAD. SIZE | NORM RING        | CAL FRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|----------|--------|------------|------------|----------|---------|------------|------------------|----------|------------|-----------|----------|
|          | OHALIS | ADVENTURER | 1203240794 | LAB      | 4100 g  | .1 g       | HW - g<br>LO - g | 6 Months | YES        | NO        | 11/2020  |
| COMMENTS |        |            |            |          |         |            |                  |          |            |           |          |
| 1        | 10g    | 10.0       | 10.0       | YES / NO | AS LEFT | 10.0       |                  |          |            |           |          |
| 2        | 20g    | 20.0       | 20.0       | YES / NO | 20.0    |            |                  |          |            |           |          |
| 3        | 50g    | 50.0       | 50.0       | YES / NO | 50.0    |            |                  |          |            |           |          |
| 4        | 100g   | 100.0      | 100.0      | YES / NO | 100.0   |            |                  |          |            |           |          |
| 5        | 1kg    | 999.7      | 999.7      | YES / NO | 1000.0  |            |                  |          |            |           |          |
| 6        | 2kg    | 1999.4     | 1999.4     | YES / NO | 2000.0  |            |                  |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584497

FOR CUSTOM STACK 593P - COD(11111)  
14614 CENFIELD ST ALLIANCE, OH 44601

☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Caveller Dr.  
 FORT WAYNE, IN 46808  
 260-486-8469  
☐ 5205 Galileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7980  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-525-3006  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46614  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5800  
☐ 100 McLunkin Road  
 NITRO, WV 25143  
 304-755-0886

P.O. COD(11111) DATE 5/12/20

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT  
S/N'S

Calam kit #3

SCALE  
TECHNICIAN: M.P.

SIGNATURE

ACCEPTED BY: [Signature]

PARTS USED

| TAG NO.  | MFG      | MOD NO.   | S/N        | LOC.     | CAP.    | GRAD. SIZE | NORM RNG               | CAL FRQ  | CLEAR TEST | CAL STICK | NEXT CAL |
|----------|----------|-----------|------------|----------|---------|------------|------------------------|----------|------------|-----------|----------|
|          | OHAUS    | SCOUT PRO | 7124111434 | LAB      | 2000 -  | .1 --      | H 2000 --<br>LO 500 -- | 6 Months | YES        | YES       | 11/2020  |
| WGT USED | AS FOUND | DEV.      | TOL. +/-   | ADJUSTED | AS LEFT | COMMENTS   |                        |          |            |           |          |
| 1 500    | 500.0    | 0         | +/- 2%     | YES / NO | 500.0   |            |                        |          |            |           |          |
| 2 1000   | 1000.0   | 0         | +/- 2%     | YES / NO | 1000.0  |            |                        |          |            |           |          |
| 3 1500   | 1500.0   | 0         | +/- 2%     | YES / NO | 1500.0  |            |                        |          |            |           |          |
| 4 2000   | 2000.0   | 0         | +/- 2%     | YES / NO | 2000.0  |            |                        |          |            |           |          |
| 5        |          |           |            | YES / NO |         |            |                        |          |            |           |          |
| 6        |          |           |            | YES / NO |         |            |                        |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechtbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584496

CUSTOM STACK 593P - COD(III)

FOR

14614 CENFIELD ST ALLIANCE, OH 44601

COD(III)

PO

DATE 5/12/20

J 14941 Liberty H. Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
 J 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
 J 41424 Scale St. S.W.  
 CANTON, OH 44708-3096  
 330-453-2424  
 J 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
 J 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
 J 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-486-8468  
 J 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
 J 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-239-7960  
 J 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7160  
 J 1001 Findlay Rd.  
 LIMA, OH 45801  
 419-226-5021  
 J 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
 J 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
 J 2351 Jaclyn Court  
 SOUTH BEND, IN 46614  
 J 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5800  
 J 100 McJunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

2019-0182

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO.

WEIGHT  
SN'S

Calibration #3

SCALE  
TECHNICIAN: M.P.

SIGNATURE

ACCEPTED BY: [Signature]

SIGNATURE

PARTS USED

| TAG NO. | MFG       | MOD NO.  | S/N      | LOC.     | CAP.     | GRAD. SIZE | NORM RNG         | CAL FRQ  | CLEAN TEST | CAL STICK | NEXT CAL  |
|---------|-----------|----------|----------|----------|----------|------------|------------------|----------|------------|-----------|-----------|
|         | SARTORIUS | A2005    | 38080133 | LAB      | 100 GM g | 0.1 g      | HI - g<br>LO - g | 6 Months | YES        | NO        | 11/2/2020 |
| 1       | 10g       | 10000.9  | +0.9     | YES / NO | AS LEFT  | 10000.0    | CAL-BROTES       |          |            |           |           |
| 2       | 20g       | 20001.3  | +1.3     | YES / NO | 20000.0  |            |                  |          |            |           |           |
| 3       | 50g       | 50004.5  | +4.5     | YES / NO | 50000.0  |            |                  |          |            |           |           |
| 4       | 100g      | 100010.8 | +10.8    | YES / NO | 100000.0 |            |                  |          |            |           |           |
| 5       | g         |          |          | YES / NO |          |            |                  |          |            |           |           |
| 6       | g         |          |          | YES / NO |          |            |                  |          |            |           |           |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER Scales, Inc.

## SCALE INSPECTION REPORT

584489

FOR CUSTOM STACK 593P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!! DATE 5/12/20

☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 1001 Findlay Rd.  
 LIMA, OH 45801  
 419-228-5021  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46614  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5800  
☐ 100 McJunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0186

WEIGHT

S/N'S colam hit #3

SCALE

TECHNICIAN: M.R.

ACCEPTED BY: Scal

SIGNATURE

SIGNATURE

PARTS USED

| TAG NO. | MFG  | MOD NO   | SN       | LOC.     | CAP.     | GRAD. SIZE | NORM RNG            | CAL FRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|---------|------|----------|----------|----------|----------|------------|---------------------|----------|------------|-----------|----------|
|         | A&D  | HR-200   | 12323498 | LAB      | 210 g    | 0.0001 g   | HI 200 g<br>LO 10 g | 6 Months | YES        | NO        | 11/2020  |
| 1       | 10g  | 9.9995   | -0.0005  | ADJUSTED | AS LEFT  | 10.0000    | COMMENTS            |          |            |           |          |
| 2       | 20g  | 19.9996  | -0.0004  | YES / NO | 20.0000  | 20.0000    | CAL. BORTED         |          |            |           |          |
| 3       | 50g  | 49.9997  | -0.0003  | YES / NO | 50.0000  | 50.0000    |                     |          |            |           |          |
| 4       | 100g | 99.9980  | -0.0020  | YES / NO | 100.0000 | 100.0000   |                     |          |            |           |          |
| 5       | 200g | 199.9970 | -0.0030  | YES / NO | 200.0000 | 200.0000   |                     |          |            |           |          |
| 6       | g    |          |          | YES / NO |          |            |                     |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.



# SCALE INSPECTION REPORT

584490

FOR CUSTOM STACK 583P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/12/20

- ☐ 14941 Liberty Hi Rd.  
BOWLING GREEN, OH 43402  
419-354-2030
- ☐ 1424 Scale St. S.W.  
CANTON, OH 44706-3096  
330-453-2424
- ☐ 4005 South Ave.  
YOUNGSTOWN, OH 44512  
330-259-0414
- ☐ 7550 Jacks Lane  
CLAYTON, OH 45315  
937-832-2040
- ☐ 3306 Cavalier Dr.  
FORT WAYNE, IN 46808  
260-496-8469
- ☐ 520 Brookpark Rd.  
CLEVELAND, OH 44109-5898  
216-661-2660
- ☐ 5525 Galasso Court  
INDIANAPOLIS, IN 46241  
317-548-7821
- ☐ 1080 National Parkway  
MANSFIELD, OH 44906  
419-529-3006
- ☐ 526 31st St.  
PARKERSBURG, WV 26101  
304-428-1792
- ☐ 100 McClunkin Road  
NITRO, WV 25143  
304-765-0886
- ☐ 2351 Jaclyn Court  
SOUTH BEND, IN 46614
- ☐ 9930 Crescent Park Drive  
WEST CHESTER, OH 45069  
513-777-5800

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT  
S/N'S

GLAM BRIT #3

SCALE  
TECHNICIAN: MT.

ACCEPTED BY: *[Signature]*

PARTS USED

| TAG NO. | MFG      | MOD NO. | S/N  | LOC.      | CAP.    | GRAD. SIZE | NORM RING           | CAL FRQ  | CLEAN TEST | CAL STICK | NEXT CAL |
|---------|----------|---------|------|-----------|---------|------------|---------------------|----------|------------|-----------|----------|
|         | US SOLID | NONE    | NONE | TRAVELLER | 500 g   | 0.001 g    | HI 200 g<br>LO 10 g | 6 Months | YES        | YES       | 11/2020  |
| 1       | 10g      | 10.000  |      | YES / NO  | AS LEFT | 10.000     |                     |          |            |           |          |
| 2       | 20g      | 20.000  |      | YES / NO  | 20.000  |            |                     |          |            |           |          |
| 3       | 50g      | 50.000  |      | YES / NO  | 50.000  |            |                     |          |            |           |          |
| 4       | 100g     | 100.000 |      | YES / NO  | 100.000 |            |                     |          |            |           |          |
| 5       | 200g     | 200.000 |      | YES / NO  | 200.000 |            |                     |          |            |           |          |
| 6       | g        |         |      | YES / NO  |         |            |                     |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechtbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

# BRECHBUHLER Scales, Inc.

## SCALE INSPECTION REPORT

584488

FOR CUSTOM STACK 533P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/12/20

☐ 14941 Liberty Hi Rd.  
BOWLING GREEN, OH 43402  
419-354-2030

☐ 1424 Scale St. S.W.  
CANTON, OH 44706-3096  
330-453-2424

☐ 4005 South Ave.  
YOUNGSTOWN, OH 44512  
330-259-0414

☐ 520 Brookpark Rd.  
CLEVELAND, OH 44109-5898  
216-661-2680

☐ 5525 Gallean Court  
INDIANAPOLIS, IN 46241  
317-548-7821

☐ 5200 Grand Avenue  
PITTSBURGH, PA 15225  
412-299-7960

☐ 477 North Pike Rd.  
SARVER, PA 16055  
724-224-7180

☐ 1080 National Parkway  
MANSFIELD, OH 44906  
419-529-3006

☐ 526 31st St.  
PARKERSBURG, WV 26101  
304-428-1792

☐ 2351 Jacyln Court  
SOUTH BEND, IN 46614

☐ 9930 Crescent Park Drive  
WEST CHESTER, OH 45069  
513-777-5800

☐ 100 McLunkin Road  
NITRO, WV 25143  
304-755-0686

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT S/N'S Cream bit #3

SCALE TECHNICIAN: M.T.

ACCEPTED BY: *[Signature]*  
SIGNATURE

PARTS USED

| TAG NO. | MFG   | MOD NO. | S/N      | LOC. | CAP.   | GRAD. SIZE | NORM RING             | CAL FRQ  | CLEAN TEST | CAL STICK | NEXT CAL |
|---------|-------|---------|----------|------|--------|------------|-----------------------|----------|------------|-----------|----------|
| 1       | 200g  | GF1200  | 14632225 | LAB  | 1210 g | 0.01 g     | HI 1000 g<br>LO 200 g | 6 Months | YES        | ✓         | 11/2020  |
| 2       | 500g  |         |          |      |        |            |                       |          |            |           |          |
| 3       | 1000g |         |          |      |        |            |                       |          |            |           |          |
| 4       | g     |         |          |      |        |            |                       |          |            |           |          |
| 5       | g     |         |          |      |        |            |                       |          |            |           |          |
| 6       | g     |         |          |      |        |            |                       |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechtbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.



7410 Worthington-Galena Road  
Worthington, Ohio 43085  
Phone: (614) 436-4933  
Fax: (614) 436-9144

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.ierevents.com](http://www.ierevents.com)

### Temperature Calibration Certificate

Instrument: H-B Thermometer  
Serial #: 4A6108

Date: 4/6/2020  
Technician: Sam Shults

| <u>Lab Standard</u> | <u>Thermometer Mark</u> |
|---------------------|-------------------------|
| 169.9               | 170.0                   |
| 190.0               | 190.0                   |
| 204.8               | 205.0                   |
| 214.6               | 215.0                   |

Accuracy = 1 F

#### Reference Standards

PIE 525B sn. 116765 Cal Due: 9/6/2020  
Hart 9103 Temp Dry Well

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**



7410 Worthington-Galena Road  
Worthington, Ohio 43085  
Phone: (614) 436-4933  
Fax: (614) 436-9144

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.iemnts.com](http://www.iemnts.com)

### Temperature Calibration Certificate

Instrument: H-B Thermometer  
Serial #: 4B5200

Date: 4/6/2020  
Technician: Sam Shults

| <u>Lab Standard</u> | <u>Thermometer Mark</u> |
|---------------------|-------------------------|
| 30.1                | 30.0                    |
| 50.1                | 50.0                    |
| 70.0                | 70.0                    |
| 88.0                | 88.0                    |

Accuracy = 1 F

#### Reference Standards

PIE 525B sn. 116765 Cal Due: 9/6/2020  
Hart 9103 Temp Dry Well

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**

# THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/23/19 BY ANDREW CANNON Pb 28.76

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| ICE WATER           |           | BOILING WATER |           |     |
|---------------------|-----------|---------------|-----------|-----|
| TC                  | PRECISION | TC            | PRECISION | TC  |
| OVEN THERMOCOUPLES  |           |               |           |     |
| O-1                 | 32        | 32            | 212       | 212 |
| O-2                 | 32        | 32            | 212       | 212 |
| O-3                 | 32        | 31            | 212       | 211 |
| O-4                 | 32        | 31            | 212       | 211 |
| O-5                 | 32        | 32            | 212       | 212 |
| O-6                 | 32        | 31            | 212       | 211 |
| O-7                 | 32        | 31            | 212       | 211 |
| O-8                 | 32        | 32            | 212       | 212 |
| O-9                 | 32        | 32            | 212       | 212 |
| O-10                | 32        | 32            | 212       | 212 |
| O-11                | 32        | 31            | 212       | 211 |
| O-12                | 32        | 31            | 212       | 211 |
| STACK THERMOCOUPLES |           |               |           |     |
| 2S-1                | 32        | 31            | 212       | 211 |
| 2S-2                | 32        | 31            | 212       | 211 |
| 2S-3                | 32        | 32            | 212       | 212 |
| 3S-1                | 32        | 32            | 212       | 212 |
| 3S-2                | 32        | 31            | 212       | 211 |
| 3S-3                | 32        | 31            | 212       | 211 |
| 3S-4                | 32        | 31            | 212       | 211 |
| 3S-5                | 32        | 31            | 212       | 211 |
| 4S-1                | 32        | 32            | 212       | 212 |
| 4S-2                | 32        | 31            | 212       | 211 |
| 4S-3                | 32        | 31            | 212       | 211 |
| 4S-4                | 32        | 33            | 212       | 213 |
| 4S-5                | 32        | 31            | 212       | 211 |
| 4S-6                | 32        | 32            | 212       | 212 |
| 5S-1                | 32        | 32            | 212       | 212 |
| 5S-2                | 32        | 32            | 212       | 212 |
| 5S-3                | 32        | 33            | 212       | 213 |
| 6S-1                | 32        | 31            | 212       | 211 |
| 6S-2                | 32        | 31            | 212       | 211 |
| 6S-3                | 32        | 31            | 212       | 211 |
| 6S-4                | 32        | 32            | 212       | 212 |
| 8S-1                | 32        | 32            | 212       | 212 |
| 8S-2                | 32        | 32            | 212       | 212 |
| 10S-1               | 32        | 32            | 212       | 212 |
| 10S-2               | 32        | 31            | 212       | 211 |
| 12S-1               | 32        | 31            | 212       | 211 |

# THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/23/19 BY ANDREW CANNON Pb 28.76

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| <u>ICE WATER</u>               |                  | <u>BOILING WATER</u> |                  |           |
|--------------------------------|------------------|----------------------|------------------|-----------|
| <u>TC</u>                      | <u>PRECISION</u> | <u>TC</u>            | <u>PRECISION</u> | <u>TC</u> |
| <u>CONDENSOR THERMOCOUPLES</u> |                  |                      |                  |           |
| <u>C-1</u>                     | 32               | 31                   | 212              | 211       |
| <u>C-2</u>                     | 32               | 31                   | 212              | 211       |
| <u>C-3</u>                     | 32               | 31                   | 212              | 211       |
| <u>C-4</u>                     | 32               | 31                   | 212              | 211       |
| <u>C-5</u>                     | 32               | 31                   | 212              | 211       |
| <u>C-6</u>                     | 32               | 32                   | 212              | 212       |
| <u>C-7</u>                     | 32               | 31                   | 212              | 211       |
| <u>C-8</u>                     | 32               | 31                   | 212              | 211       |
| <u>C-9</u>                     | 32               | 31                   | 212              | 211       |
| <u>PROBE THERMOCOUPLES</u>     |                  |                      |                  |           |
| <u>2P-1</u>                    | 32               | 31                   | 212              | 211       |
| <u>2P-2</u>                    | 32               | 31                   | 212              | 211       |
| <u>2P-3</u>                    | 32               | 31                   | 212              | 211       |
| <u>3P-1</u>                    | 32               | 32                   | 212              | 212       |
| <u>3P-2</u>                    | 32               | 31                   | 212              | 211       |
| <u>3P-3</u>                    | 32               | 31                   | 212              | 211       |
| <u>3P-4</u>                    | 32               | 32                   | 212              | 212       |
| <u>3P-5</u>                    | 32               | 33                   | 212              | 213       |
| <u>4P-1</u>                    | 32               | 32                   | 212              | 212       |
| <u>4P-2</u>                    | 32               | 32                   | 212              | 212       |
| <u>4P-3</u>                    | 32               | 32                   | 212              | 212       |
| <u>4P-4</u>                    | 32               | 32                   | 212              | 212       |
| <u>4P-5</u>                    | 32               | 32                   | 212              | 212       |
| <u>4P-6</u>                    | 32               | 32                   | 212              | 212       |
| <u>5P-1</u>                    | 32               | 32                   | 212              | 212       |
| <u>5P-2</u>                    | 32               | 31                   | 212              | 211       |
| <u>5P-3</u>                    | 32               | 31                   | 212              | 211       |
| <u>6P-1</u>                    | 32               | 31                   | 212              | 211       |
| <u>6P-2</u>                    | 32               | 31                   | 212              | 211       |
| <u>6P-3</u>                    | 32               | 31                   | 212              | 211       |
| <u>6P-4</u>                    | 32               | 31                   | 212              | 211       |
| <u>8P-1</u>                    | 32               | 32                   | 212              | 212       |
| <u>8P-2</u>                    | 32               | 32                   | 212              | 212       |
| <u>10P-1</u>                   | 32               | 33                   | 212              | 213       |
| <u>10P-2</u>                   | 32               | 32                   | 212              | 212       |
| <u>12P-1</u>                   | 32               | 32                   | 212              | 212       |

Client: heggitt

## Pitot Tube Inspection


Date: 12-6-20

|                         |      |                            |      |
|-------------------------|------|----------------------------|------|
| Probe/Pitot Number      | 3p-2 | A (Pa + Pb)                | .957 |
| Level and Perpendicular | yes  | Zs = A tan Y (< 0.125")    | 0    |
| Obstruction?            | no   | Ws = A tan 0 (< 0.03125")  | 0    |
| Damaged?                | no   | Dt (0.1875" < Dt < 0.375") | .375 |
| a1 (-10° < a1 < +10°)   | 0    | Pa (1.05 Dt < Pa < 1.5 Dt) | .471 |
| a2 (-10° < a2 < +10°)   | 0    | Pb (1.05 Dt < Pb < 1.5 Dt) | .486 |
| b1 (-5° < b1 < +5°)     | 0    | Pa = Pb ± 0.063"           | .015 |
| b2 (-5° < b2 < +5°)     | 0    |                            |      |

## Probe Minimum Interferences

|              |  |                |  |
|--------------|--|----------------|--|
| Y (>= 3.0")  |  | Dn             |  |
| X (> .75")   |  | X/Dn (>= 1.5") |  |
| Zp (>= .75") |  |                |  |

- Pa Distance between where pitots adjoin to tip of pitot (Must be between 1.05 & 1.50 times O.D. of tubing)  
 Pb Distance between where pitots adjoin to tip of pitot (Must be between 1.05 & 1.50 times O.D. of tubing)  
 Dt Diameter of pitot tube (0.375 inches on all pitots)  
 Zs Distance between the tip of the impact and static line along the length of the pitot (Must be < 1/8 inch (0.1250))  
 Ws Spacing between Pitot tubes where welded together (Must be < 1/32 inch (0.0313))  
 a1 Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 10 Deg)  
 a2 Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 10 Deg)  
 b1 Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 5 Deg)  
 b2 Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 5 Deg)  
 X Distance between side of nozzle and side of pitot tube (Must be > 3/4 inch)  
 Zp Distance from center of pitot opening back to tip of thermal couple (Must be >= 3/4 inch (0.75))  
 Y Distance from center of pitot opening back to probe (Must be >= 3 inches)



# THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/23/19 BY ANDREW CANNON Pb 28.76

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| ICE WATER           |           | BOILING WATER |           |     |
|---------------------|-----------|---------------|-----------|-----|
| TC                  | PRECISION | TC            | PRECISION | TC  |
| METER THERMOCOUPLES |           |               |           |     |
| 1M-1                | 32        | 31            | 212       | 211 |
| 1M-2                | 32        | 31            | 212       | 211 |
| 2M-1                | 32        | 32            | 212       | 212 |
| 2M-2                | 32        | 32            | 212       | 212 |
| 3M-1                | 32        | 32            | 212       | 212 |
| 3M-2                | 32        | 32            | 212       | 212 |
| 4M-1                | 32        | 33            | 212       | 213 |
| 4M-2                | 32        | 33            | 212       | 213 |
| 5M-1                | 32        | 32            | 212       | 212 |
| 5M-2                | 32        | 32            | 212       | 212 |
| 6M-1                | 32        | 32            | 212       | 212 |
| 6M-2                | 32        | 31            | 212       | 211 |
| 7M-1                | 32        | 31            | 212       | 211 |
| 7M-2                | 32        | 31            | 212       | 211 |
| 8M-1                | 32        | 31            | 212       | 211 |
| 8M-2                | 32        | 31            | 212       | 211 |
| 9M-1                | 32        | 31            | 212       | 211 |
| 9M-2                | 32        | 31            | 212       | 211 |
| 10M-1               | 32        | 32            | 212       | 212 |
| 10M-2               | 32        | 32            | 212       | 212 |
| 15M-1               | 32        | 32            | 212       | 212 |
| 15M-2               | 32        | 32            | 212       | 212 |
| 17M-1               | 32        | 32            | 212       | 212 |
| 17M-2               | 32        | 33            | 212       | 213 |
| 18M-1               | 32        | 32            | 212       | 212 |
| 18M-2               | 32        | 22            | 212       | 212 |

THERMOCOUPLE TEMPERATURES ARE READ ON THE DTI DURING TEST.  
DTI CALIBRATED BY ALTEK 22 TC SOURCE S# 148946 OR S# 243783 PRIOR TO TC CAL.

# **Appendix #4**

## **Monitoring Data**

Meggitt Aircraft Braking Systems Crporation  
North Afterburner Outlet

|      |       |
|------|-------|
| VOC  | Conc. |
| High | 47.05 |
| Mid  | 24.7  |
| Low  | 13.7  |

| VOC   | Time Stamp            |             |
|-------|-----------------------|-------------|
| 47.21 | 12/7/2020 11:46:59 AM | High        |
| 47.27 | 12/7/2020 11:48:00 AM |             |
| 46.81 | 12/7/2020 11:49:00 AM |             |
| 47.04 | 12/7/2020 11:50:01 AM |             |
| 46.75 | 12/7/2020 11:51:02 AM |             |
| 1.44  | 12/7/2020 11:52:02 AM |             |
| 0.15  | 12/7/2020 11:53:03 AM | Zero        |
| 0.15  | 12/7/2020 11:54:03 AM |             |
| 0.15  | 12/7/2020 11:55:04 AM |             |
| 0.15  | 12/7/2020 11:56:05 AM |             |
| 0.15  | 12/7/2020 11:57:05 AM |             |
| 8.87  | 12/7/2020 11:58:06 AM |             |
| 13.38 | 12/7/2020 11:59:06 AM |             |
| 13.43 | 12/7/2020 12:00:07 PM | Low         |
| 13.55 | 12/7/2020 12:01:08 PM |             |
| 13.44 | 12/7/2020 12:02:08 PM |             |
| 13.62 | 12/7/2020 12:03:09 PM |             |
| 13.49 | 12/7/2020 12:04:09 PM |             |
| 19.58 | 12/7/2020 12:05:10 PM |             |
| 24.60 | 12/7/2020 12:06:11 PM |             |
| 24.76 | 12/7/2020 12:07:11 PM | Bias        |
| 24.77 | 12/7/2020 12:08:12 PM |             |
| 24.20 | 12/7/2020 12:09:12 PM |             |
| 23.85 | 12/7/2020 12:10:13 PM |             |
| 23.63 | 12/7/2020 12:11:14 PM |             |
| 1.57  | 12/7/2020 12:12:14 PM |             |
| 0.16  | 12/7/2020 12:13:15 PM |             |
| 0.15  | 12/7/2020 12:14:15 PM | Start Run 1 |
| 0.15  | 12/7/2020 12:15:16 PM |             |
| 0.18  | 12/7/2020 12:16:11PM  |             |
| 0.15  | 12/7/2020 12:17:12 PM |             |
| 0.15  | 12/7/2020 12:18:12 PM |             |
| 0.15  | 12/7/2020 12:19:13 PM |             |
| 0.23  | 12/7/2020 12:20:13 PM |             |
| 0.19  | 12/7/2020 12:21:14 PM |             |
| 0.15  | 12/7/2020 12:22:14 PM |             |
| 0.15  | 12/7/2020 12:23:15 PM |             |
| 0.15  | 12/7/2020 12:24:16 PM |             |
| 0.40  | 12/7/2020 12:25:16 PM |             |
| 0.25  | 12/7/2020 12:26:17 PM |             |
| 0.17  | 12/7/2020 12:27:18 PM |             |
| 0.15  | 12/7/2020 12:28:18 PM |             |
| 0.15  | 12/7/2020 12:29:19 PM |             |
| 0.15  | 12/7/2020 12:30:19 PM |             |
| 0.15  | 12/7/2020 12:31:20 PM |             |
| 0.15  | 12/7/2020 12:32:20 PM |             |
| 0.15  | 12/7/2020 12:33:21 PM |             |
| 0.21  | 12/7/2020 12:34:22 PM |             |
| 0.15  | 12/7/2020 12:35:22 PM |             |
| 0.15  | 12/7/2020 12:36:23 PM |             |
| 0.15  | 12/7/2020 12:37:24 PM |             |
| 0.15  | 12/7/2020 12:38:24 PM |             |

|       |                                 |
|-------|---------------------------------|
| 0.24  | 12/7/2020 12:39:25 PM           |
| 0.38  | 12/7/2020 12:40:25 PM           |
| 0.16  | 12/7/2020 12:41:26 PM           |
| 0.26  | 12/7/2020 12:42:26 PM           |
| 0.15  | 12/7/2020 12:43:27 PM           |
| 0.15  | 12/7/2020 12:44:28 PM           |
| 0.18  | 12/7/2020 12:45:28 PM           |
| 0.16  | 12/7/2020 12:46:29 PM           |
| 0.15  | 12/7/2020 12:47:29 PM           |
| 0.15  | 12/7/2020 12:48:30 PM           |
| 0.15  | 12/7/2020 12:49:31 PM           |
| 0.15  | 12/7/2020 12:50:31 PM           |
| 0.24  | 12/7/2020 12:51:32 PM           |
| 0.17  | 12/7/2020 12:52:32 PM           |
| 0.35  | 12/7/2020 12:53:33 PM           |
| 0.57  | 12/7/2020 12:54:34 PM           |
| 0.15  | 12/7/2020 12:55:34 PM           |
| 0.15  | 12/7/2020 12:56:35 PM           |
| 0.15  | 12/7/2020 12:57:36 PM           |
| 0.15  | 12/7/2020 12:58:36 PM           |
| 0.15  | 12/7/2020 12:59:37 PM           |
| 0.15  | 12/7/2020 1:00:37 PM            |
| 0.15  | 12/7/2020 1:01:38 PM            |
| 0.15  | 12/7/2020 1:02:38 PM            |
| 0.15  | 12/7/2020 1:03:39 PM            |
| 0.22  | 12/7/2020 1:04:40 PM            |
| 0.15  | 12/7/2020 1:05:40 PM            |
| 0.15  | 12/7/2020 1:06:41 PM            |
| 0.16  | 12/7/2020 1:07:42 PM            |
| 0.15  | 12/7/2020 1:08:42 PM            |
| 0.15  | 12/7/2020 1:09:43 PM            |
| 0.15  | 12/7/2020 1:10:43 PM            |
| 0.15  | 12/7/2020 1:11:44 PM            |
| 0.20  | 12/7/2020 1:12:45 PM            |
| 0.15  | 12/7/2020 1:13:45 PM            |
| 0.15  | 12/7/2020 1:14:46 PM Stop Run 1 |
| 0.18  | Avg                             |
| 0.15  | 12/7/2020 1:15:46 PM            |
| 0.15  | 12/7/2020 1:16:47 PM            |
| 0.15  | 12/7/2020 1:17:48 PM            |
| 0.15  | 12/7/2020 1:18:48 PM            |
| 3.82  | 12/7/2020 1:19:49 PM            |
| 25.08 | 12/7/2020 1:20:49 PM            |
| 25.07 | 12/7/2020 1:21:50 PM Bias       |
| 24.90 | 12/7/2020 1:22:51 PM            |
| 25.10 | 12/7/2020 1:23:51 PM            |
| 25.06 | 12/7/2020 1:24:52 PM            |
| 25.05 | 12/7/2020 1:25:52 PM            |
| 25.12 | 12/7/2020 1:26:53 PM            |
| 22.29 | 12/7/2020 1:27:54 PM            |
| 0.16  | 12/7/2020 1:28:54 PM            |
| 0.15  | 12/7/2020 1:29:55 PM Zero       |
| 0.15  | 12/7/2020 1:30:55 PM            |
| 0.15  | 12/7/2020 1:31:56 PM            |
| 0.15  | 12/7/2020 1:32:57 PM            |
| 0.15  | 12/7/2020 1:33:57 PM            |
| 0.19  | 12/7/2020 1:34:58 PM            |
| 0.15  | 12/7/2020 1:35:58 PM            |
| 0.15  | 12/7/2020 1:36:59 PM            |
| 0.17  | 12/7/2020 1:38:00 PM            |
| 0.15  | 12/7/2020 1:39:00 PM            |
| 0.28  | 12/7/2020 1:40:01 PM            |

|      |                                  |
|------|----------------------------------|
| 0.28 | 12/7/2020 1:40:01 PM             |
| 0.20 | 12/7/2020 1:41:02 PM             |
| 0.15 | 12/7/2020 1:42:02 PM             |
| 0.15 | 12/7/2020 1:43:03 PM             |
| 0.15 | 12/7/2020 1:44:03 PM             |
| 0.18 | 12/7/2020 1:45:04 PM Start Run 2 |
| 0.23 | 12/7/2020 1:46:04 PM             |
| 0.16 | 12/7/2020 1:47:05 PM             |
| 0.15 | 12/7/2020 1:48:06 PM             |
| 0.15 | 12/7/2020 1:49:06 PM             |
| 0.15 | 12/7/2020 1:50:07 PM             |
| 0.15 | 12/7/2020 1:51:08 PM             |
| 0.15 | 12/7/2020 1:52:08 PM             |
| 0.25 | 12/7/2020 1:53:09 PM             |
| 0.18 | 12/7/2020 1:54:09 PM             |
| 0.15 | 12/7/2020 1:55:10 PM             |
| 0.15 | 12/7/2020 1:56:11 PM             |
| 0.15 | 12/7/2020 1:57:11 PM             |
| 0.15 | 12/7/2020 1:58:12 PM             |
| 0.15 | 12/7/2020 1:59:12 PM             |
| 0.15 | 12/7/2020 2:00:13 PM             |
| 0.15 | 12/7/2020 2:01:14 PM             |
| 0.15 | 12/7/2020 2:02:14 PM             |
| 0.15 | 12/7/2020 2:03:15 PM             |
| 0.15 | 12/7/2020 2:04:15 PM             |
| 0.15 | 12/7/2020 2:05:16 PM             |
| 0.17 | 12/7/2020 2:06:17 PM             |
| 0.31 | 12/7/2020 2:07:17 PM             |
| 0.18 | 12/7/2020 2:08:18 PM             |
| 0.15 | 12/7/2020 2:09:18 PM             |
| 0.15 | 12/7/2020 2:10:19 PM             |
| 0.15 | 12/7/2020 2:11:20 PM             |
| 0.15 | 12/7/2020 2:12:20 PM             |
| 0.15 | 12/7/2020 2:13:21 PM             |
| 0.15 | 12/7/2020 2:14:21 PM             |
| 0.15 | 12/7/2020 2:15:22 PM             |
| 0.15 | 12/7/2020 2:16:23 PM             |
| 0.21 | 12/7/2020 2:17:23 PM             |
| 0.17 | 12/7/2020 2:18:24 PM             |
| 0.15 | 12/7/2020 2:19:25 PM             |
| 0.15 | 12/7/2020 2:20:25 PM             |
| 0.15 | 12/7/2020 2:21:26 PM             |
| 0.15 | 12/7/2020 2:22:27 PM             |
| 0.15 | 12/7/2020 2:23:27 PM             |
| 0.15 | 12/7/2020 2:24:28 PM             |
| 0.15 | 12/7/2020 2:25:29 PM             |
| 0.27 | 12/7/2020 2:26:30 PM             |
| 0.34 | 12/7/2020 2:27:31 PM             |
| 0.16 | 12/7/2020 2:28:32 PM             |
| 0.15 | 12/7/2020 2:29:36 PM             |
| 0.15 | 12/7/2020 2:30:37 PM             |
| 0.15 | 12/7/2020 2:31:38 PM             |
| 0.15 | 12/7/2020 2:32:42 PM             |
| 0.15 | 12/7/2020 2:33:43 PM             |
| 0.18 | 12/7/2020 2:34:46 PM             |
| 0.15 | 12/7/2020 2:35:47 PM             |
| 0.15 | 12/7/2020 2:36:50 PM             |
| 0.15 | 12/7/2020 2:37:51 PM             |
| 0.15 | 12/7/2020 2:38:52 PM             |
| 0.15 | 12/7/2020 2:39:53 PM             |
| 0.24 | 12/7/2020 2:40:55 PM             |
| 0.18 | 12/7/2020 2:41:56 PM             |

|       |                                  |
|-------|----------------------------------|
| 0.15  | 12/7/2020 2:42:58 PM             |
| 0.15  | 12/7/2020 2:43:59 PM             |
| 0.15  | 12/7/2020 2:44:01 PM             |
| 0.15  | 12/7/2020 2:45:02 PM Stop Run 2  |
| 0.17  | Avg                              |
| 0.15  | 12/7/2020 2:46:03 PM             |
| 0.15  | 12/7/2020 2:47:04 PM             |
| 0.26  | 12/7/2020 2:48:05 PM             |
| 0.23  | 12/7/2020 2:49:06 PM             |
| 0.19  | 12/7/2020 2:50:07 PM             |
| 0.15  | 12/7/2020 2:51:08 PM             |
| 0.15  | 12/7/2020 2:52:08 PM             |
| 0.15  | 12/7/2020 2:53:09 PM             |
| 0.15  | 12/7/2020 2:54:10 PM             |
| 0.40  | 12/7/2020 2:55:10 PM             |
| 16.34 | 12/7/2020 2:56:11 PM             |
| 23.90 | 12/7/2020 2:57:12 PM             |
| 24.47 | 12/7/2020 2:58:12 PM Bias        |
| 24.70 | 12/7/2020 2:59:13 PM             |
| 24.62 | 12/7/2020 3:00:13 PM             |
| 24.46 | 12/7/2020 3:01:14 PM             |
| 24.44 | 12/7/2020 3:02:15 PM             |
| 24.69 | 12/7/2020 3:03:15 PM             |
| 21.88 | 12/7/2020 3:04:16 PM             |
| 0.15  | 12/7/2020 3:05:16 PM             |
| 0.15  | 12/7/2020 3:06:17 PM Zero        |
| 0.15  | 12/7/2020 3:07:18 PM             |
| 0.15  | 12/7/2020 3:08:18 PM             |
| 0.15  | 12/7/2020 3:09:19 PM             |
| 0.15  | 12/7/2020 3:10:19 PM             |
| 0.22  | 12/7/2020 3:11:20 PM             |
| 0.15  | 12/7/2020 3:12:21 PM             |
| 0.15  | 12/7/2020 3:13:21 PM Start Run 3 |
| 0.15  | 12/7/2020 3:14:22 PM             |
| 0.25  | 12/7/2020 3:15:22 PM             |
| 0.36  | 12/7/2020 3:16:23 PM             |
| 0.24  | 12/7/2020 3:17:24 PM             |
| 0.15  | 12/7/2020 3:18:24 PM             |
| 0.15  | 12/7/2020 3:19:25 PM             |
| 0.15  | 12/7/2020 3:20:26 PM             |
| 0.15  | 12/7/2020 3:21:26 PM             |
| 0.15  | 12/7/2020 3:22:27 PM             |
| 0.15  | 12/7/2020 3:23:27 PM             |
| 0.15  | 12/7/2020 3:24:28 PM             |
| 0.15  | 12/7/2020 3:25:29 PM             |
| 0.15  | 12/7/2020 3:26:29 PM             |
| 0.15  | 12/7/2020 3:27:30 PM             |
| 0.15  | 12/7/2020 3:28:30 PM             |
| 0.15  | 12/7/2020 3:29:31 PM             |
| 0.15  | 12/7/2020 3:30:31 PM             |
| 0.15  | 12/7/2020 3:31:32 PM             |
| 0.15  | 12/7/2020 3:32:33 PM             |
| 0.20  | 12/7/2020 3:33:33 PM             |
| 0.37  | 12/7/2020 3:34:34 PM             |
| 0.21  | 12/7/2020 3:35:35 PM             |
| 0.15  | 12/7/2020 3:36:35 PM             |
| 0.15  | 12/7/2020 3:37:36 PM             |
| 0.15  | 12/7/2020 3:38:36 PM             |
| 0.15  | 12/7/2020 3:39:37 PM             |
| 0.15  | 12/7/2020 3:40:38 PM             |
| 0.15  | 12/7/2020 3:41:38 PM             |

|       |                      |            |
|-------|----------------------|------------|
| 0.15  | 12/7/2020 3:41:38 PM |            |
| 0.15  | 12/7/2020 3:42:39 PM |            |
| 0.15  | 12/7/2020 3:43:39 PM |            |
| 0.15  | 12/7/2020 3:44:40 PM |            |
| 0.15  | 12/7/2020 3:45:41 PM |            |
| 0.15  | 12/7/2020 3:46:41 PM |            |
| 0.24  | 12/7/2020 3:47:42 PM |            |
| 0.46  | 12/7/2020 3:48:42 PM |            |
| 0.31  | 12/7/2020 3:49:43 PM |            |
| 0.18  | 12/7/2020 3:50:44 PM |            |
| 0.15  | 12/7/2020 3:51:44 PM |            |
| 0.15  | 12/7/2020 3:52:45 PM |            |
| 0.15  | 12/7/2020 3:53:45 PM |            |
| 0.15  | 12/7/2020 3:54:46 PM |            |
| 0.17  | 12/7/2020 3:55:47 PM |            |
| 0.15  | 12/7/2020 3:56:47 PM |            |
| 0.15  | 12/7/2020 3:57:48 PM |            |
| 0.15  | 12/7/2020 3:58:48 PM |            |
| 0.15  | 12/7/2020 3:59:49 PM |            |
| 0.15  | 12/7/2020 4:00:50 PM |            |
| 0.15  | 12/7/2020 4:01:50 PM |            |
| 0.15  | 12/7/2020 4:02:51 PM |            |
| 0.23  | 12/7/2020 4:03:51 PM |            |
| 0.29  | 12/7/2020 4:04:52 PM |            |
| 0.20  | 12/7/2020 4:05:53 PM |            |
| 0.15  | 12/7/2020 4:06:53 PM |            |
| 0.15  | 12/7/2020 4:07:54 PM |            |
| 0.15  | 12/7/2020 4:08:54 PM |            |
| 0.15  | 12/7/2020 4:09:55 PM |            |
| 0.16  | 12/7/2020 4:10:56 PM |            |
| 0.15  | 12/7/2020 4:11:56 PM |            |
| 0.15  | 12/7/2020 4:12:57 PM |            |
| 0.17  | 12/7/2020 4:13:57 PM | Stop Run 3 |
| 0.18  |                      | Avg        |
| 0.15  | 12/7/2020 4:14:58 PM |            |
| 0.15  | 12/7/2020 4:15:59 PM |            |
| 0.15  | 12/7/2020 4:16:59 PM |            |
| 0.27  | 12/7/2020 4:17:01 PM |            |
| 0.19  | 12/7/2020 4:18:02 PM |            |
| 0.15  | 12/7/2020 4:19:02 PM |            |
| 0.15  | 12/7/2020 4:20:03 PM |            |
| 0.15  | 12/7/2020 4:21:03 PM |            |
| 0.15  | 12/7/2020 4:22:04 PM |            |
| 1.05  | 12/7/2020 4:23:04 PM |            |
| 22.63 | 12/7/2020 4:24:05 PM |            |
| 24.79 | 12/7/2020 4:25:06 PM |            |
| 25.52 | 12/7/2020 4:26:06 PM | Bias       |
| 25.51 | 12/7/2020 4:27:07 PM |            |
| 25.05 | 12/7/2020 4:28:07 PM |            |
| 25.50 | 12/7/2020 4:29:08 PM |            |
| 25.64 | 12/7/2020 4:30:08 PM |            |
| 25.67 | 12/7/2020 4:31:09 PM |            |
| 10.69 | 12/7/2020 4:32:10 PM |            |
| 0.15  | 12/7/2020 4:33:10 PM | Zero       |
| 0.15  | 12/7/2020 4:34:11 PM |            |
| 0.15  | 12/7/2020 4:35:12 PM |            |

Meggitt Aircraft Braking Systems Corporation  
South Afterburner Outlet

|      |       |
|------|-------|
| VOC  | Conc. |
| High | 47.05 |
| Mid  | 24.7  |
| Low  | 13.7  |

| VOC   | Time Stamp                       |
|-------|----------------------------------|
| 46.92 | 12/8/2020 7:59:44 AM             |
| 47.22 | 12/8/2020 8:00:45 AM High        |
| 47.23 | 12/8/2020 8:01:45 AM             |
| 47.22 | 12/8/2020 8:02:46 AM             |
| 47.41 | 12/8/2020 8:03:46 AM             |
| 47.67 | 12/8/2020 8:04:47 AM             |
| 47.86 | 12/8/2020 8:05:48 AM             |
| 12.15 | 12/8/2020 8:06:48 AM             |
| 0.02  | 12/8/2020 8:07:49 AM             |
| 0.02  | 12/8/2020 8:08:50 AM Zero        |
| 0.02  | 12/8/2020 8:09:50 AM             |
| 0.02  | 12/8/2020 8:10:51 AM             |
| 0.79  | 12/8/2020 8:11:51 AM             |
| 0.02  | 12/8/2020 8:12:52 AM             |
| 0.02  | 12/8/2020 8:13:52 AM             |
| 1.08  | 12/8/2020 8:14:53 AM             |
| 12.10 | 12/8/2020 8:15:54 AM             |
| 13.10 | 12/8/2020 8:16:54 AM             |
| 13.40 | 12/8/2020 8:17:55 AM Low         |
| 13.43 | 12/8/2020 8:18:56 AM             |
| 13.36 | 12/8/2020 8:19:56 AM             |
| 12.95 | 12/8/2020 8:20:57 AM             |
| 12.75 | 12/8/2020 8:21:57 AM             |
| 12.80 | 12/8/2020 8:22:58 AM             |
| 12.03 | 12/8/2020 8:23:59 AM             |
| 19.00 | 12/8/2020 8:24:59 AM             |
| 23.96 | 12/8/2020 8:26:00 AM             |
| 24.87 | 12/8/2020 8:27:00 AM Bias        |
| 24.84 | 12/8/2020 8:28:01 AM             |
| 24.94 | 12/8/2020 8:29:02 AM             |
| 24.50 | 12/8/2020 8:30:02 AM             |
| 24.36 | 12/8/2020 8:31:03 AM             |
| 24.37 | 12/8/2020 8:32:03 AM             |
| 20.03 | 12/8/2020 8:33:04 AM             |
| 0.03  | 12/8/2020 8:34:05 AM             |
| 0.02  | 12/8/2020 8:35:05 AM             |
| 0.02  | 12/8/2020 8:36:06 AM             |
| 0.49  | 12/8/2020 8:37:06 AM             |
| 0.21  | 12/8/2020 8:38:07 AM             |
| 0.02  | 12/8/2020 8:39:08 AM             |
| 0.02  | 12/8/2020 8:40:08 AM Start Run 1 |
| 0.02  | 12/8/2020 8:41:09 AM             |
| 0.02  | 12/8/2020 8:42:10 AM             |
| 0.48  | 12/8/2020 8:43:10 AM             |
| 0.15  | 12/8/2020 8:44:11 AM             |
| 0.02  | 12/8/2020 8:45:11 AM             |
| 0.02  | 12/8/2020 8:46:12 AM             |
| 0.02  | 12/8/2020 8:47:12 AM             |
| 0.02  | 12/8/2020 8:48:13 AM             |
| 0.02  | 12/8/2020 8:49:14 AM             |
| 0.34  | 12/8/2020 8:50:14 AM             |

|       |                                 |
|-------|---------------------------------|
| 0.15  | 12/8/2020 8:51:15 AM            |
| 0.02  | 12/8/2020 8:52:15 AM            |
| 0.02  | 12/8/2020 8:53:16 AM            |
| 0.02  | 12/8/2020 8:54:17 AM            |
| 0.02  | 12/8/2020 8:55:17 AM            |
| 0.02  | 12/8/2020 8:56:18 AM            |
| 0.07  | 12/8/2020 8:57:18 AM            |
| 0.02  | 12/8/2020 8:58:19 AM            |
| 0.02  | 12/8/2020 8:59:20 AM            |
| 0.02  | 12/8/2020 9:00:20 AM            |
| 0.02  | 12/8/2020 9:01:21 AM            |
| 0.47  | 12/8/2020 9:02:22 AM            |
| 0.02  | 12/8/2020 9:03:22 AM            |
| 0.02  | 12/8/2020 9:04:23 AM            |
| 0.02  | 12/8/2020 9:05:23 AM            |
| 0.25  | 12/8/2020 9:06:24 AM            |
| 0.02  | 12/8/2020 9:07:25 AM            |
| 0.02  | 12/8/2020 9:08:25 AM            |
| 0.06  | 12/8/2020 9:09:26 AM            |
| 0.02  | 12/8/2020 9:10:26 AM            |
| 0.02  | 12/8/2020 9:11:27 AM            |
| 0.18  | 12/8/2020 9:12:27 AM            |
| 0.02  | 12/8/2020 9:13:28 AM            |
| 0.02  | 12/8/2020 9:14:29 AM            |
| 0.02  | 12/8/2020 9:15:29 AM            |
| 0.61  | 12/8/2020 9:16:30 AM            |
| 0.02  | 12/8/2020 9:17:31 AM            |
| 0.02  | 12/8/2020 9:18:31 AM            |
| 0.02  | 12/8/2020 9:19:32 AM            |
| 0.26  | 12/8/2020 9:20:32 AM            |
| 0.11  | 12/8/2020 9:21:33 AM            |
| 0.02  | 12/8/2020 9:22:34 AM            |
| 0.02  | 12/8/2020 9:23:34 AM            |
| 0.02  | 12/8/2020 9:24:35 AM            |
| 0.51  | 12/8/2020 9:25:35 AM            |
| 0.02  | 12/8/2020 9:26:36 AM            |
| 0.02  | 12/8/2020 9:27:37 AM            |
| 0.07  | 12/8/2020 9:28:37 AM            |
| 0.02  | 12/8/2020 9:29:38 AM            |
| 0.09  | 12/8/2020 9:30:39 AM            |
| 0.02  | 12/8/2020 9:31:39 AM            |
| 0.02  | 12/8/2020 9:32:40 AM            |
| 0.67  | 12/8/2020 9:33:40 AM            |
| 0.41  | 12/8/2020 9:34:41 AM            |
| 0.07  | 12/8/2020 9:35:42 AM            |
| 0.02  | 12/8/2020 9:36:42 AM            |
| 0.02  | 12/8/2020 9:37:43 AM            |
| 0.02  | 12/8/2020 9:38:43 AM            |
| 0.02  | 12/8/2020 9:39:44 AM            |
| 0.13  | 12/8/2020 9:40:44 AM Stop Run 1 |
| 0.10  | Avg                             |
| 0.02  | 12/8/2020 9:41:45 AM            |
| 0.02  | 12/8/2020 9:42:46 AM            |
| 0.37  | 12/8/2020 9:43:46 AM            |
| 0.16  | 12/8/2020 9:44:47 AM            |
| 0.02  | 12/8/2020 9:45:48 AM            |
| 0.61  | 12/8/2020 9:46:48 AM            |
| 22.83 | 12/8/2020 9:47:49 AM            |
| 19.05 | 12/8/2020 9:48:49 AM            |
| 24.41 | 12/8/2020 9:49:50 AM            |
| 24.37 | 12/8/2020 9:50:51 AM            |
| 24.55 | 12/8/2020 9:51:51 AM Bias       |

|       |                                   |
|-------|-----------------------------------|
| 24.44 | 12/8/2020 9:52:52 AM              |
| 24.95 | 12/8/2020 9:53:52 AM              |
| 25.10 | 12/8/2020 9:54:53 AM              |
| 24.86 | 12/8/2020 9:55:54 AM              |
| 19.80 | 12/8/2020 9:56:54 AM              |
| 0.02  | 12/8/2020 9:57:55 AM              |
| 0.02  | 12/8/2020 9:58:55 AM              |
| 0.02  | 12/8/2020 9:59:56 AM              |
| 0.02  | 12/8/2020 10:00:57 AM             |
| 0.02  | 12/8/2020 10:01:57 AM Zero        |
| 0.02  | 12/8/2020 10:02:58 AM             |
| 0.02  | 12/8/2020 10:03:58 AM             |
| 0.08  | 12/8/2020 10:04:59 AM             |
| 0.02  | 12/8/2020 10:06:00 AM             |
| 0.02  | 12/8/2020 10:07:00 AM             |
| 0.02  | 12/8/2020 10:08:01 AM             |
| 0.12  | 12/8/2020 10:09:02 AM             |
| 0.02  | 12/8/2020 10:10:02 AM             |
| 0.02  | 12/8/2020 10:11:03 AM             |
| 0.05  | 12/8/2020 10:12:03 AM             |
| 0.02  | 12/8/2020 10:13:04 AM             |
| 0.02  | 12/8/2020 10:14:04 AM             |
| 0.02  | 12/8/2020 10:15:05 AM             |
| 0.02  | 12/8/2020 10:16:06 AM             |
| 0.33  | 12/8/2020 10:17:06 AM             |
| 0.02  | 12/8/2020 10:18:07 AM             |
| 0.02  | 12/8/2020 10:19:07 AM             |
| 0.15  | 12/8/2020 10:20:08 AM             |
| 0.02  | 12/8/2020 10:21:09 AM             |
| 0.06  | 12/8/2020 10:22:09 AM             |
| 0.02  | 12/8/2020 10:23:10 AM             |
| 0.02  | 12/8/2020 10:24:11 AM             |
| 0.02  | 12/8/2020 10:25:11 AM             |
| 0.02  | 12/8/2020 10:26:12 AM             |
| 0.02  | 12/8/2020 10:27:12 AM             |
| 0.09  | 12/8/2020 10:28:13 AM             |
| 0.02  | 12/8/2020 10:29:14 AM             |
| 0.02  | 12/8/2020 10:30:14 AM             |
| 0.02  | 12/8/2020 10:31:15 AM             |
| 0.02  | 12/8/2020 10:32:15 AM             |
| 0.02  | 12/8/2020 10:33:16 AM             |
| 0.02  | 12/8/2020 10:34:17 AM             |
| 0.11  | 12/8/2020 10:35:17 AM             |
| 0.02  | 12/8/2020 10:36:18 AM             |
| 0.02  | 12/8/2020 10:37:18 AM             |
| 0.02  | 12/8/2020 10:38:19 AM             |
| 0.02  | 12/8/2020 10:39:19 AM             |
| 0.05  | 12/8/2020 10:40:20 AM Start Run 2 |
| 0.02  | 12/8/2020 10:41:21 AM             |
| 0.02  | 12/8/2020 10:42:21 AM             |
| 0.02  | 12/8/2020 10:43:22 AM             |
| 0.25  | 12/8/2020 10:44:23 AM             |
| 0.02  | 12/8/2020 10:45:23 AM             |
| 0.02  | 12/8/2020 10:46:24 AM             |
| 0.51  | 12/8/2020 10:47:24 AM             |
| 0.02  | 12/8/2020 10:48:25 AM             |
| 0.02  | 12/8/2020 10:49:26 AM             |
| 0.02  | 12/8/2020 10:50:26 AM             |
| 0.24  | 12/8/2020 10:51:27 AM             |
| 0.16  | 12/8/2020 10:52:27 AM             |
| 0.02  | 12/8/2020 10:53:28 AM             |
| 0.05  | 12/8/2020 10:54:29 AM             |

|       |                       |            |
|-------|-----------------------|------------|
| 0.02  | 12/8/2020 10:55:29 AM |            |
| 0.02  | 12/8/2020 10:56:30 AM |            |
| 0.02  | 12/8/2020 10:57:30 AM |            |
| 0.02  | 12/8/2020 10:58:31 AM |            |
| 0.27  | 12/8/2020 10:59:32 AM |            |
| 0.02  | 12/8/2020 11:00:32 AM |            |
| 0.02  | 12/8/2020 11:01:33 AM |            |
| 0.12  | 12/8/2020 11:02:33 AM |            |
| 0.02  | 12/8/2020 11:03:34 AM |            |
| 0.02  | 12/8/2020 11:04:35 AM |            |
| 0.08  | 12/8/2020 11:05:35 AM |            |
| 0.02  | 12/8/2020 11:06:36 AM |            |
| 0.02  | 12/8/2020 11:07:37 AM |            |
| 0.02  | 12/8/2020 11:08:37 AM |            |
| 0.02  | 12/8/2020 11:09:38 AM |            |
| 0.49  | 12/8/2020 11:10:38 AM |            |
| 0.24  | 12/8/2020 11:11:39 AM |            |
| 0.02  | 12/8/2020 11:12:40 AM |            |
| 0.02  | 12/8/2020 11:13:40 AM |            |
| 0.02  | 12/8/2020 11:14:41 AM |            |
| 0.02  | 12/8/2020 11:15:41 AM |            |
| 0.14  | 12/8/2020 11:16:42 AM |            |
| 0.42  | 12/8/2020 11:17:42 AM |            |
| 0.02  | 12/8/2020 11:18:43 AM |            |
| 0.02  | 12/8/2020 11:19:44 AM |            |
| 0.02  | 12/8/2020 11:20:44 AM |            |
| 0.02  | 12/8/2020 11:21:45 AM |            |
| 0.38  | 12/8/2020 11:22:45 AM |            |
| 0.02  | 12/8/2020 11:23:46 AM |            |
| 0.02  | 12/8/2020 11:24:47 AM |            |
| 0.02  | 12/8/2020 11:25:47 AM |            |
| 0.14  | 12/8/2020 11:26:48 AM |            |
| 0.02  | 12/8/2020 11:27:48 AM |            |
| 0.02  | 12/8/2020 11:28:49 AM |            |
| 0.02  | 12/8/2020 11:29:50 AM |            |
| 0.02  | 12/8/2020 11:30:50 AM |            |
| 0.02  | 12/8/2020 11:31:51 AM |            |
| 0.02  | 12/8/2020 11:32:52 AM |            |
| 0.23  | 12/8/2020 11:33:52 AM |            |
| 0.02  | 12/8/2020 11:34:53 AM |            |
| 0.02  | 12/8/2020 11:35:53 AM |            |
| 0.02  | 12/8/2020 11:36:54 AM |            |
| 0.07  | 12/8/2020 11:37:55 AM |            |
| 0.02  | 12/8/2020 11:38:55 AM |            |
| 0.02  | 12/8/2020 11:39:56 AM |            |
| 0.02  | 12/8/2020 11:40:57 AM | Stop Run 2 |
| 0.08  |                       | Avg        |
| 0.02  | 12/8/2020 11:41:57 AM |            |
| 0.06  | 12/8/2020 11:42:58 AM |            |
| 0.02  | 12/8/2020 11:43:58 AM |            |
| 0.02  | 12/8/2020 11:44:59 AM |            |
| 0.02  | 12/8/2020 11:46:00 AM |            |
| 0.09  | 12/8/2020 11:47:00 AM |            |
| 0.02  | 12/8/2020 11:48:01 AM |            |
| 0.05  | 12/8/2020 11:49:01 AM |            |
| 5.11  | 12/8/2020 11:50:02 AM |            |
| 24.40 | 12/8/2020 11:51:02 AM |            |
| 24.71 | 12/8/2020 11:52:03 AM |            |
| 25.01 | 12/8/2020 11:53:04 AM | Bias       |
| 24.95 | 12/8/2020 11:54:04 AM |            |
| 25.02 | 12/8/2020 11:55:05 AM |            |
| 25.03 | 12/8/2020 11:56:05 AM |            |

|       |                                   |
|-------|-----------------------------------|
| 25.04 | 12/8/2020 11:57:06 AM             |
| 25.05 | 12/8/2020 11:58:07 AM             |
| 7.72  | 12/8/2020 11:59:07 AM             |
| 0.02  | 12/8/2020 12:00:08 PM             |
| 0.02  | 12/8/2020 12:01:08 PM             |
| 0.02  | 12/8/2020 12:02:09 PM             |
| 0.02  | 12/8/2020 12:03:10 PM Zero        |
| 0.02  | 12/8/2020 12:04:10 PM             |
| 0.02  | 12/8/2020 12:05:11 PM             |
| 0.02  | 12/8/2020 12:06:11 PM             |
| 0.11  | 12/8/2020 12:07:12 PM             |
| 0.02  | 12/8/2020 12:08:13 PM             |
| 0.02  | 12/8/2020 12:09:13 PM             |
| 0.02  | 12/8/2020 12:10:14 PM             |
| 0.02  | 12/8/2020 12:11:14 PM             |
| 0.02  | 12/8/2020 12:12:15 PM             |
| 0.08  | 12/8/2020 12:13:16 PM             |
| 0.02  | 12/8/2020 12:14:16 PM             |
| 0.02  | 12/8/2020 12:15:17 PM Start Run 3 |
| 0.07  | 12/8/2020 12:16:18 PM             |
| 0.02  | 12/8/2020 12:17:18 PM             |
| 0.02  | 12/8/2020 12:18:19 PM             |
| 0.37  | 12/8/2020 12:19:19 PM             |
| 0.02  | 12/8/2020 12:20:20 PM             |
| 0.02  | 12/8/2020 12:21:21 PM             |
| 0.08  | 12/8/2020 12:22:21 PM             |
| 0.02  | 12/8/2020 12:23:22 PM             |
| 0.05  | 12/8/2020 12:24:22 PM             |
| 0.02  | 12/8/2020 12:25:23 PM             |
| 0.02  | 12/8/2020 12:26:24 PM             |
| 0.02  | 12/8/2020 12:27:24 PM             |
| 0.02  | 12/8/2020 12:28:25 PM             |
| 0.06  | 12/8/2020 12:29:25 PM             |
| 0.02  | 12/8/2020 12:30:26 PM             |
| 0.29  | 12/8/2020 12:31:27 PM             |
| 0.02  | 12/8/2020 12:32:27 PM             |
| 0.02  | 12/8/2020 12:33:28 PM             |
| 0.02  | 12/8/2020 12:34:28 PM             |
| 0.15  | 12/8/2020 12:35:29 PM             |
| 0.02  | 12/8/2020 12:36:30 PM             |
| 0.02  | 12/8/2020 12:37:30 PM             |
| 0.35  | 12/8/2020 12:38:31 PM             |
| 0.02  | 12/8/2020 12:39:31 PM             |
| 0.02  | 12/8/2020 12:40:32 PM             |
| 0.02  | 12/8/2020 12:41:33 PM             |
| 0.02  | 12/8/2020 12:42:33 PM             |
| 0.26  | 12/8/2020 12:43:34 PM             |
| 0.02  | 12/8/2020 12:44:35 PM             |
| 0.02  | 12/8/2020 12:45:35 PM             |
| 0.02  | 12/8/2020 12:46:36 PM             |
| 0.25  | 12/8/2020 12:47:36 PM             |
| 0.02  | 12/8/2020 12:48:37 PM             |
| 0.02  | 12/8/2020 12:49:38 PM             |
| 0.19  | 12/8/2020 12:50:38 PM             |
| 0.02  | 12/8/2020 12:51:39 PM             |
| 0.02  | 12/8/2020 12:52:39 PM             |
| 0.02  | 12/8/2020 12:53:40 PM             |
| 0.05  | 12/8/2020 12:54:40 PM             |
| 0.02  | 12/8/2020 12:55:41 PM             |
| 0.02  | 12/8/2020 12:56:42 PM             |
| 0.06  | 12/8/2020 12:57:42 PM             |
| 0.02  | 12/8/2020 12:58:43 PM             |

|       |                       |            |
|-------|-----------------------|------------|
| 0.02  | 12/8/2020 12:59:44 PM |            |
| 0.02  | 12/8/2020 1:00:44 PM  |            |
| 0.02  | 12/8/2020 1:01:45 PM  |            |
| 0.31  | 12/8/2020 1:02:45 PM  |            |
| 0.02  | 12/8/2020 1:03:46 PM  |            |
| 0.02  | 12/8/2020 1:04:47 PM  |            |
| 0.02  | 12/8/2020 1:05:47 PM  |            |
| 0.27  | 12/8/2020 1:06:48 PM  |            |
| 0.02  | 12/8/2020 1:07:48 PM  |            |
| 0.02  | 12/8/2020 1:08:49 PM  |            |
| 0.02  | 12/8/2020 1:09:50 PM  |            |
| 0.02  | 12/8/2020 1:10:50 PM  |            |
| 0.53  | 12/8/2020 1:11:51 PM  |            |
| 0.15  | 12/8/2020 1:12:51 PM  |            |
| 0.02  | 12/8/2020 1:13:52 PM  |            |
| 0.02  | 12/8/2020 1:14:53 PM  |            |
| 0.03  | 12/8/2020 1:15:53 PM  | Stop Run 3 |
| 0.07  |                       | Avg        |
| 0.02  | 12/8/2020 1:16:54 PM  |            |
| 0.02  | 12/8/2020 1:17:55 PM  |            |
| 0.10  | 12/8/2020 1:18:55 PM  |            |
| 0.02  | 12/8/2020 1:19:56 PM  |            |
| 0.02  | 12/8/2020 1:20:56 PM  |            |
| 0.02  | 12/8/2020 1:21:57 PM  |            |
| 0.13  | 12/8/2020 1:22:57 PM  |            |
| 0.02  | 12/8/2020 1:23:58 PM  |            |
| 18.19 | 12/8/2020 1:24:59 PM  |            |
| 23.99 | 12/8/2020 1:25:59 PM  |            |
| 24.91 | 12/8/2020 1:27:00 PM  |            |
| 25.63 | 12/8/2020 1:28:00 PM  |            |
| 25.77 | 12/8/2020 1:29:01 PM  |            |
| 25.89 | 12/8/2020 1:30:02 PM  | Bias       |
| 26.00 | 12/8/2020 1:31:02 PM  |            |
| 26.02 | 12/8/2020 1:32:03 PM  |            |
| 26.02 | 12/8/2020 1:33:04 PM  |            |
| 26.02 | 12/8/2020 1:34:04 PM  |            |
| 25.82 | 12/8/2020 1:35:05 PM  |            |
| 1.67  | 12/8/2020 1:36:05 PM  |            |
| 0.15  | 12/8/2020 1:37:06 PM  |            |
| 0.02  | 12/8/2020 1:38:07 PM  |            |
| 0.02  | 12/8/2020 1:39:07 PM  | Zero       |
| 0.03  | 12/8/2020 1:40:08 PM  |            |



Meggitt Aircraft Braking Systems Corporation  
1204 Massillon Road  
Akron, Ohio 44306

### Report

Performed Velocity, Moisture, Temperature, Volumetric Flow Rate,  
Oxygen, Carbon Dioxide, Nitrogen Oxide, Carbon Monoxide and  
Volatile Organic Compounds Emissions Testing

Sampling performed on the P039 Accutherm Thermal Oxidizer Outlet

Akron, OH

Test Date: 4/15/2021

**Meggitt Aircraft Braking Systems Corporation  
1204 Massillon Road  
Akron, Ohio 44306**

**Report**

**Performed Velocity, Moisture, Temperature, Volumetric Flow Rate,  
Oxygen, Carbon Dioxide, Nitrogen Oxide, Carbon Monoxide and  
Volatile Organic Compounds Emissions Testing**

**Sampling performed on the P039 Accutherm Thermal Oxidizer Outlet**

**Akron, OH**

**Test Date: 4/15/2021**

A handwritten signature in black ink, reading "Brian E. Lemasters". The signature is written in a cursive, flowing style. The first name "Brian" is written with a large, stylized 'B'. The middle initial "E" is smaller and positioned between the first and last names. The last name "Lemasters" is written with a long, sweeping 'L' and a trailing flourish.

**Brian E. Lemasters  
Custom Stack Analysis, LLC.**

## REPORT CERTIFICATION

Custom Stack Analysis, LLC. has used its professional experience and best professional efforts in performing this compliance test. I have reviewed the results of these tests, and to the best of my knowledge and belief, they are true and correct.

A handwritten signature in black ink that reads "Brian E. Lemasters". The signature is written in a cursive style with a large initial "B" and "L".

Brian E. Lemasters

## **TABLE OF CONTENTS**

|                                 |       |
|---------------------------------|-------|
| Executive Summary .....         | 1-2   |
| Test Results .....              | 3     |
| Methods Description .....       | 4-8   |
| Sampling Train Diagrams .....   | 9-13  |
| Sampling Point Description..... | 14    |
| Calculations .....              | 15-22 |

## **APPENDIX**

|                        |   |
|------------------------|---|
| Test Data .....        | 1 |
| Laboratory Data .....  | 2 |
| Calibration Data ..... | 3 |
| Monitoring Data .....  | 4 |
| Process Data .....     | 5 |

## **EXECUTIVE SUMMARY**

Custom Stack Analysis, LLC. conducted emissions sampling using USEPA Methods 1-4, 3A, 7E, 10 and 25A. Testing was conducted on the P039 Accutherm Outlet on April 15<sup>th</sup>, 2021. The testing was conducted at Meggitt Aircraft Braking Systems Corporation (Facility ID – 16-77-01-0999) on P039 Accutherm Outlet to determine compliance status with Permit No. – P0121253 (see Table 1.2).

The Custom Stack Analysis, LLC. test crew consisted of Mr. James Gray, Mr. Dylan Gray and Mr. Brian Lemasters. The testing procedures were coordinated by Mr. Jim Davies of Meggitt Aircraft Braking Systems Corporation. All testing procedures were witnessed by Mr. Connor Moroney of the Akron Regional Air Quality Management District (see Table 1.1).

**Table 1.1: Emissions Testing Program Contact Personnel**

| Name, Title                                                                                                       | Company Address                                                                            | Phone, Fax, email                              |
|-------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|------------------------------------------------|
| Mr. Jim Davies                                                                                                    | Meggitt Aircraft Braking Systems Corporation<br>1204 Massillon Road<br>Akron, OH 44306     | (330) 796-1743 (Phone)                         |
| Mr. Connor Moroney                                                                                                | Akron Regional Air Quality<br>Management District<br>1867 W. Market St,<br>Akron, OH 44313 | (330) 812-3904 (Phone)                         |
| Mr. James Gray<br>Owner<br><br>Mr. Brian Lemasters<br>Project Manager<br><br>Mr. Dylan Gray<br>Project Technician | Custom Stack Analysis, LLC.<br>14614 Cenfield St. N.E.<br>Alliance, OH 44601               | (330) 525-5119 (Phone)<br>(330) 525-7908 (Fax) |

Test results are located on page 3. A description of the testing protocol is included on pages 4-8. All testing calculations are located on pages 15-22. Appendix 1 includes field test data. Appendix 2 contains laboratory data from Custom Stack Analysis, LLC. Appendix 3 contains calibration data for the equipment used on test day. Appendix 4 contains monitoring data. Appendix 5 contains process data.

Table 1.2 demonstrates how Meggitt Aircraft Braking Systems Corporation in Akron, OH is operating in compliance with the applicable emission standards.

**Table 1.2: Emission Limits and Test Results Summary**

| Pollutant                  | Emission Limitations | Test Result Average | Compliance Demonstrated |
|----------------------------|----------------------|---------------------|-------------------------|
| Nitrogen Oxide             |                      | 0.637 tons/yr       |                         |
| Volatile Organic Compounds | 0.36 tons/yr         | 0.0199 tons/yr      | Yes                     |
| Carbon Monoxide            |                      | 0.0023 tons/yr      |                         |

# Test Results

Meggitt Aircraft Braking Systems Corporation - P039 Accutherm Outlet  
4/15/2021

Methods 1-4, 3A, 7E, 10 and 25A

|                              | <u>Run #1</u> | <u>Run #2</u> | <u>Run #3</u> | <u>Avg.</u> |
|------------------------------|---------------|---------------|---------------|-------------|
| Stack Gas Velocity (ft/sec)  | 12.70         | 13.02         | 13.18         | 12.97       |
| Standard Cubic Feet an Hour  | 50,567        | 50,007        | 49,802        | 50,125      |
| Actual Cubic Feet per Minute | 2,394         | 2,454         | 2,484         | 2,444       |
| Moisture %                   | 5.33%         | 6.49%         | 6.14%         | 5.99%       |
| Carbon Dioxide %             | 3.24%         | 2.92%         | 3.32%         | 3.16%       |
| Oxygen %                     | 14.21%        | 14.76%        | 14.27%        | 14.41%      |
| Nitrogen %                   | 82.55%        | 82.33%        | 82.41%        | 82.43%      |
| CO (ppm)                     | 0.07          | 0.17          | 0.20          | 0.14        |
| CO (lbs/hr)                  | 0.0002        | 0.0006        | 0.0007        | 0.0005      |
| CO (tons/yr)                 | 0.0011        | 0.0026        | 0.0032        | 0.0023      |
| Nox (ppm)                    | 24.77         | 24.02         | 24.11         | 24.30       |
| Nox (lbs/hr)                 | 0.1496        | 0.1434        | 0.1433        | 0.1454      |
| Nox (tons/yr)                | 0.6551        | 0.6282        | 0.6278        | 0.6370      |
| VOC (ppm)                    | 0.86          | 1.28          | 0.77          | 0.97        |
| VOC (lbs/hr Carbon)          | 0.0040        | 0.0060        | 0.0036        | 0.0045      |
| VOC (tons/yr)                | 0.0177        | 0.0263        | 0.0157        | 0.0199      |

## **METHOD 1**

Sample and velocity traverses for stationary sources.

To aid in the representative measurement of pollutant emissions and/ or total volumetric flow rate from a stationary source, a measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas. A traverse point is then located within each of these equal areas.

## **METHOD 2**

Determination of stack gas velocity and volumetric flow rate.

The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Staustscheibe or reverse type) pitot tube.

## **METHOD 3**

Gas analysis for the determination of dry molecular weight.

This method is applicable for determining carbon dioxide and oxygen concentrations and dry molecular weight of a sample from a gas stream of a fossil-fuel combustion process.

## **METHOD 4**

Determination of moisture content in stack gases.

A gas sample is extracted at a constant rate from the source. It is determined either volumetrically or gravimetrically.

## METHOD 3A TESTING DESCRIPTION

A gas sample is continuously extracted from the stack, and a portion of the sample is conveyed to an instrumental analyzer for determination of O<sub>2</sub> gas concentration. The gases pass through a heated sampling probe and filter to prevent condensation. The gases then pass through a calibration valve to a heated sampling line. After the heated sampling line is a Universal Analyzers Model 530 air cooled single sample thermoelectric water condenser with a perostolic pump for moisture removal. The sample is then passed through to a California Analytical Instruments Model 100F for O<sub>2</sub> concentrations. Before the testing procedures commence the analyzer is left to warm up for a 90 minute period. It is then calibrated according to Method 7E specifications. To the extent practicable, the measured emissions should be between 20 to 100 percent of the selected calibration span. Three calibration gases are selected. The High-Level gas concentrations shall be equivalent to 20 to 100 percent of the calibration span. Mid-Level concentrations shall be equivalent to 40 to 60 percent of the calibration span. The Low-Level Gas concentrations of less than 20 percent of the span. Before the first run an analyzer calibration error check is conducted. If the low-level, mid, or high cal gases expected concentrations differ by more than  $\pm 2\%$  of the span then the procedure needs to be repeated until an acceptable 3 point calibration is obtained. After the analyzer calibration check the upscale and low level calibration gases are introduced to the sampling calibration valve and recorded. System bias calibration must be within 5.0% of the analyzer calibration span for low-scale and upscale calibration gases. At the conclusion of each of the test runs the low-level gas and an upscale gas closest to the concentrations are introduced to the calibration valve assembly. If either the low-level or upscale value exceeds  $\pm 3\%$  of the span, then the run is considered invalid.

## METHOD 7E TESTING DESCRIPTION

A gas sample is continuously extracted from the stack, and a portion of the sample is conveyed to an instrumental analyzer for determination of NO<sub>x</sub> gas concentration using a chemiluminescence analyzer. The gases pass through a heated sampling probe and filter to prevent condensation. The gases then pass through a calibration valve to a heated sampling line. After the heated sampling line is a condenser for moisture removal. The sample is then passed through to a Thermo Environmental Instruments Model 42 chemiluminescence analyzer where the gases are analyzed for NO<sub>x</sub> concentrations. Before the testing procedures commence the analyzer is left to warm up for a 90 minute period. It is then calibrated according to Method 7E specifications. To the extent practicable, the measured emissions should be between 20 to 100 percent of the selected calibration span. Three calibration gases are selected. The High-Level gas concentrations shall be equivalent to 20 to 100 percent of the calibration span. Mid-Level concentrations shall be equivalent to 40 to 60 percent of the calibration span. The Low-Level Gas concentrations of less than 20 percent of the span. Before the first run an analyzer calibration error check is conducted. If the low-level, mid, or high cal gases expected concentrations differ by more than  $\pm 2\%$  of the span then the procedure needs to be repeated until an acceptable 3 point calibration is obtained. After the analyzer calibration check the upscale and low level calibration gases are introduced to the sampling calibration valve and recorded. System bias calibration must be within 5.0% of the analyzer calibration span for low-scale and upscale calibration gases. At the conclusion of each of the test runs the low-level gas and an upscale gas closest to the concentrations are introduced to the calibration valve assembly. If either the low-level or upscale value exceeds  $\pm 3\%$  of the span, then the run is considered invalid.


## METHOD 10 TESTING DESCRIPTION

A gas sample is continuously extracted from the stack, and a portion of the sample is conveyed to an instrumental analyzer for determination of CO gas concentration using a Luft-type nondispersive infrared analyzer. The gases pass through a heated sampling probe and filter to prevent condensation. The gases then pass through a calibration valve to a heated sampling line. After the heated sampling line is a Universal Analyzers Model 530 air cooled single sample thermoelectric water condenser with a perostolic pump for moisture removal. The sample is then passed through an ascarite tube to a Thermo Environmental Instruments Model 48 Luft-type analyzer where the gases are analyzed for CO concentrations. Before the testing procedures commence the analyzer is left to warm up for a 90 minute period. It is then calibrated according to Method 7E specifications. To the extent practicable, the measured emissions should be between 20 to 100 percent of the selected calibration span. Three calibration gases are selected. The High-Level gas concentrations shall be equivalent to 20 to 100 percent of the calibration span. Mid-Level concentrations shall be equivalent to 40 to 60 percent of the calibration span. The Low-Level Gas concentrations of less than 20 percent of the span. Before the first run an analyzer calibration error check is conducted. If the low-level, mid, or high cal gases expected concentrations differ by more than  $\pm 2\%$  of the span then the procedure needs to be repeated until an acceptable 3 point calibration is obtained. After the analyzer calibration check the upscale and low level calibration gases are introduced to the sampling calibration valve and recorded. System bias calibration must be within 5.0% of the analyzer calibration span for low-scale and upscale calibration gases. At the conclusion of each of the test runs the low-level gas and an upscale gas closest to the concentrations are introduced to the calibration valve assembly. If either the low-level or upscale value exceeds  $\pm 3\%$  of the span, then the run is considered invalid.


## METHOD 25A TESTING DESCRIPTION

This method will be used to measure the total VOC concentration expressed in terms of ppm propane. A gas sample is extracted from the source through a stainless steel probe, through a heated sample line (teflon), to a flame ionization analyzer. The main components of Method 25A are the same as Method 204B with the exception of a non heated sample probe.


The sampling system is heated up to the proper operating temperature. Within two hours of the start of the test the FIA is calibrated. The calibration range or span is selected to be from 1.5 to 2.5 times the expected concentration. Three calibration ranges are then selected as follows: Low level 25-35% of the span, Mid level 45-55% of the span, and a High level 80-90% of the span. A zero and a high level calibration gas is then injected at the valve assembly and the FIA is adjusted to these levels. Then all four gases are introduced into the analyzer and recorded. If the responses are within 5% of the expected values then the analyzer is responding correctly. The sample probe is located in the center of the stack and sealed in place and the test is started. The test lasts for 60 minutes. At the end of the test run a drift check is ran. The zero gas and the mid level calibration gas is injected at the valve assembly. The analyzer responses are then recorded. The drift check is acceptable if the results are within 3% of the span value. These checks are performed before and after each test run.




# 3A Sampling System




# 7E Sampling System




# 10 Sampling System



# 25A Sampling System



## Location of Sampling Points



| Location       | Accutherm Outlet |
|----------------|------------------|
| Upstream       | 180.0 Inches     |
| Downstream     | 240 Inches       |
| Stack Diameter | 24 Inches        |
| Sample Point # |                  |
| 1              | 0.8 Inches       |
| 2              | 2.5              |
| 3              | 4.7              |
| 4              | 7.8              |
| 5              | 16.2             |
| 6              | 19.3             |
| 7              | 21.5             |
| 8              | 23.2             |

# CALCULATIONS

## Outlet

|             | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|-------------|---------------|---------------|---------------|---|
| 1. Vm (std) | 43.07         | 42.45         | 42.75         | = |

$$\frac{VM * 17.64 * \frac{PBAR + 13.6}{Tm} * Y}{Tm}$$

|                                                                             |   | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-----------------------------------------------------------------------------|---|---------------|---------------|---------------|
| Vm (std) = Volume of gas collected, corrected to standard conditions, cuft. | = | 43.07         | 42.45         | 42.75         |
| Vm = Volume of gas sampled at meter box, cuft.                              | = | 45.02         | 44.61         | 45.09         |
| 17.64 = Standard temperature, 528 Rankine / std pressure, 29.92.            | = | 17.64         | 17.64         | 17.64         |
| Tm = Average dry gas meter temperature, + 460 Rankine.                      | = | 531.04167     | 533.75        | 535.79167     |
| Pbar = Barometric pressure, inches of mercury (Hg)                          | = | 28.64         | 28.64         | 28.64         |
| ^H = Average pressure differential across orifice.                          | = | 2             | 2             | 2             |
| 13.6 = Specific gravity of mercury.                                         | = | 13.6          | 13.6          | 13.6          |
| Y = Calibration factor of meter box.                                        | = | 1.0004        | 1.0004        | 1.0004        |

|             | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|-------------|---------------|---------------|---------------|---|
| 2. Vw (std) | 2.43          | 2.95          | 2.80          | = |

$$Vlc * \frac{P H20}{Mh20} * \frac{R Tstd}{Pstd} = K2 * Vlc$$

|                                                                    |   | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|--------------------------------------------------------------------|---|---------------|---------------|---------------|
| Vlc = Volume of water and silica collected.                        | = | 51.5          | 62.5          | 59.4          |
| P H20 = Density of water, 0.002201 lb/ml.                          | = | 0.002201      | 0.002201      | 0.002201      |
| M H20 = Molecular weight of water, 18.01 lb/lb-mole.               | = | 18.01         | 18.01         | 18.01         |
| R = Ideal gas constant, 21.85 in. hg - ft <sup>3</sup> /R-lb-mole. | = | 21.85         | 21.85         | 21.85         |
| Tstd = Standard absolute temperature, 528 R.                       | = | 528           | 528           | 528           |
| Pstd = Standard absolute pressure, 29.92 in. Hg.                   | = | 29.92         | 29.92         | 29.92         |
| K2 = 0.0471 ft <sup>3</sup> / ml.                                  | = | 0.0471        | 0.0471        | 0.0471        |

|        | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |
|--------|---------------|---------------|---------------|---|
| 3. Bws | 0.05334       | 0.06487       | 0.06145       | = |

$$\frac{Vw(std)}{Vm(std) + Vw(std)}$$

|                                                         |   | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|---------------------------------------------------------|---|---------------|---------------|---------------|
| Bws = Water vapor in the gas stream, proportion.        | = | 0.05334       | 0.06487       | 0.06145       |
| Vw(std) = Volume of water vapor in the gas sample, scf. | = | 2.43          | 2.95          | 2.80          |
| Vm(std) = Volume of gas sampled at meter box, scf.      | = | 43.07         | 42.45         | 42.75         |

|    |           | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                      |
|----|-----------|---------------|---------------|---------------|---|------------------------------------------------------|
| 4. | <b>Md</b> | 29.086694     | 29.056811     | 29.102617     | = | $0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2) + \%CO$ |

|      |                                                | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|------|------------------------------------------------|---------------|---------------|---------------|
| Md   | = Dry molecular weight, lb / lb-mole.          | 29.09         | 29.06         | 29.10         |
| 0.44 | = Molecular weight of CO2 divided by 100.      | 0.44          | 0.44          | 0.44          |
| 0.32 | = Molecular weight of O2 divided by 100.       | 0.32          | 0.32          | 0.32          |
| 0.28 | = Molecular weight of N2 or CO divided by 100. | 0.28          | 0.28          | 0.28          |

Co2, O2, N2, and CO are in percent by volume, dry basis.

|    |           | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                  |
|----|-----------|---------------|---------------|---------------|---|----------------------------------|
| 5. | <b>Ms</b> | 28.50         | 28.34         | 28.42         | = | $Md * (1-Bws) + M_{H2O} * (Bws)$ |

|       |                                                     | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-------|-----------------------------------------------------|---------------|---------------|---------------|
| Ms    | = Molecular weight of gas , wet basis, lb /lb-mole. | 28.50         | 28.34         | 28.42         |
| M H2O | = Molecular weight of water, 18 lb / lb-mole.       | 18            | 18            | 18            |

|    |           | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                  |
|----|-----------|---------------|---------------|---------------|---|------------------------------------------------------------------|
| 6. | <b>Vs</b> | 12.70         | 13.02         | 13.18         | = | $85.49 * C_p \sqrt{\Delta p} \sqrt{\frac{T_s + 460}{P_s * M_s}}$ |

|       |                                                     | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-------|-----------------------------------------------------|---------------|---------------|---------------|
| Vs    | = Average stack gas velocity, ft / sec.             | 12.70         | 13.02         | 13.18         |
| 85.49 | = Pitot tube constant, ft / sec.                    | 85.49         | 85.49         | 85.49         |
| Cp    | = Pitot tube coefficient, dimensionless.            | 0.84          | 0.84          | 0.84          |
| ΔP    | = Velocity head of stack gas, avg. sq rt.           | 0.13704       | 0.13847       | 0.13895       |
| Ts    | = Temperature of stack gas, + 460 (Rankine).        | 1359.625      | 1393          | 1420          |
| Ps    | = Absolute stack gas pressure, barometric + static. | 28.65         | 28.65         | 28.65         |
| Ms    | = Molecular weight of stack gas, wet basis.         | 28.50         | 28.34         | 28.42         |

|    |             | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                          |
|----|-------------|---------------|---------------|---------------|---|--------------------------|
| 7. | <b>ACFM</b> | 2393.78       | 2454.40       | 2483.86       | = | $Stack\ Area * 60 * V_s$ |

|    |                                         | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|----|-----------------------------------------|---------------|---------------|---------------|
| Vs | = Average stack gas velocity, ft / sec. | 12.70         | 13.02         | 13.18         |

|    |      | <u>RUN #1</u>                         | <u>RUN #2</u> | <u>RUN #3</u>                                     |       |                                                                                                                                                                                                                                                              |               |               |               |      |      |      |
|----|------|---------------------------------------|---------------|---------------------------------------------------|-------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|---------------|---------------|------|------|------|
| 8  | SCFH | 50567                                 | 50007         | 49802                                             | =     | <div><div><math display="block">3600 * ( 1 - Bws ) * Vs * A * \frac{Tstd}{Ts} * \frac{Ps}{Pstd}</math></div><table><tr><th><u>RUN #1</u></th><th><u>RUN #2</u></th><th><u>RUN #3</u></th></tr><tr><td>3600</td><td>3600</td><td>3600</td></tr></table></div> | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> | 3600 | 3600 | 3600 |
|    |      | <u>RUN #1</u>                         | <u>RUN #2</u> | <u>RUN #3</u>                                     |       |                                                                                                                                                                                                                                                              |               |               |               |      |      |      |
|    |      | 3600                                  | 3600          | 3600                                              |       |                                                                                                                                                                                                                                                              |               |               |               |      |      |      |
|    |      | 3600                                  | =             | Seconds per hour.                                 | =     | 3600                                                                                                                                                                                                                                                         | 3600          | 3600          |               |      |      |      |
|    |      | Bws                                   | =             | Water vapor in the gas stream, proportion.        | =     | 0.0533415                                                                                                                                                                                                                                                    | 0.0648732     | 0.0614459     |               |      |      |      |
|    |      | A                                     | =             | Area of stack in sq ft.                           | =     | 3.14                                                                                                                                                                                                                                                         | 3.14          | 3.14          |               |      |      |      |
|    |      | Tstd                                  | =             | Standard absolute temperature, 528 R.             | =     | 528                                                                                                                                                                                                                                                          | 528           | 528           |               |      |      |      |
|    |      | Pstd                                  | =             | Standard absolute pressure, 29.92 in. Hg.         | =     | 29.92                                                                                                                                                                                                                                                        | 29.92         | 29.92         |               |      |      |      |
|    |      | Ts                                    | =             | Temperature of stack gas, + 460 (Rankine).        |       | 1359.625                                                                                                                                                                                                                                                     | 1393          | 1420          |               |      |      |      |
|    |      | Ps                                    | =             | Absolute stack gas pressure, barometric + static. |       | 28.64                                                                                                                                                                                                                                                        | 28.64         | 28.64         |               |      |      |      |
| Vs | =    | Average stack gas velocity, ft / sec. |               | 12.70                                             | 13.02 | 13.18                                                                                                                                                                                                                                                        |               |               |               |      |      |      |

# CALCULATIONS

## VOC

|    |                           | <u>RUN #1</u> | <u>RUN #2</u>                        | <u>RUN #3</u> |   |                                                                        |
|----|---------------------------|---------------|--------------------------------------|---------------|---|------------------------------------------------------------------------|
| 1. | <b>Lbs/Hr<br/>Propane</b> | 0.00495       | 0.00734                              | 0.00437       | = | 0.11443 * SCFH * PPM * 10 <sup>-6</sup>                                |
|    | scfh                      | =             | Standard stack volumetric flow rate. |               |   | = <u>RUN #1</u><br>50567 <u>RUN #2</u><br>50007 <u>RUN #3</u><br>49802 |
|    | PPM                       | =             | PPM                                  |               |   | = 0.8556412 1.2832484 0.7671375                                        |

|    |                          | <u>RUN #1</u> | <u>RUN #2</u>                                    | <u>RUN #3</u> |   |                                                                        |
|----|--------------------------|---------------|--------------------------------------------------|---------------|---|------------------------------------------------------------------------|
| 2. | <b>Lbs/Hr<br/>Carbon</b> | 0.00405       | 0.00600                                          | 0.00357       | = | 0.031182 * SCFH * PPM * 3 * 10 <sup>-6</sup>                           |
|    | scfh                     | =             | Standard stack volumetric flow rate.             |               |   | = <u>RUN #1</u><br>50567 <u>RUN #2</u><br>50007 <u>RUN #3</u><br>49802 |
|    | PPM                      | =             | PPM                                              |               |   | = 0.8556412 1.2832484 0.7671375                                        |
|    | 3                        | =             | Carbon equivalent correction factor for propane. |               |   | = 3 3 3                                                                |

# CALCULATIONS

## NOX

|    |           | <u>RUN #1</u>          | <u>RUN #2</u>                                                                                  | <u>RUN #3</u>          |   |                                                                  |
|----|-----------|------------------------|------------------------------------------------------------------------------------------------|------------------------|---|------------------------------------------------------------------|
| 1. | Lbs/Hr    | 0.14956                | 0.14341                                                                                        | 0.14333                | = | 1.194 * SCFH * PPM * 10 <sup>-7</sup>                            |
|    | scfh      | =                      | Standard stack volumetric flow rate.                                                           |                        |   | = <u>RUN #1</u> <u>RUN #2</u> <u>RUN #3</u><br>50567 50007 49802 |
|    | PPM       | =                      | PPM corrected                                                                                  |                        |   | = 24.77 24.02 24.10                                              |
| 2. | PPM Corr. | <u>RUN #1</u><br>24.77 | <u>RUN #2</u><br>24.02                                                                         | <u>RUN #3</u><br>24.10 | = | Cgas = ( C - Co) $\frac{C_{ma}}{C_m - C_o}$                      |
|    | Co        | =                      | Average of initial and final system calibration bias check responses for the zero gas, ppm.    |                        |   | = <u>RUN #1</u> <u>RUN #2</u> <u>RUN #3</u><br>0.11 0.16 0.135   |
|    | C         | =                      | Effluent gas concentration, dry basis, ppm.                                                    |                        |   | = 24.73 24.35 24.2                                               |
|    | Cm        | =                      | Average of initial and final system calibration bias check responses for the upscale gas, ppm. |                        |   | = 25.255 25.64 25.395                                            |
|    | Cma       | =                      | Actual concentration of the upscale calibration gas, ppm.                                      |                        |   | = 25.3 25.3 25.3                                                 |

# CALCULATIONS

## CO

1

|               | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                                                                                      |
|---------------|---------------|---------------|---------------|---|----------------------------------------------------------------------------------------------------------------------|
| <b>Lbs/Hr</b> | 0.00          | 0.00          | 0.00          | = | <div style="border: 1px solid black; padding: 5px; display: inline-block;">.726 * SCFH * PPM * 10<sup>-7</sup></div> |

|      |   |                                      |   |               |               |               |
|------|---|--------------------------------------|---|---------------|---------------|---------------|
| scfh | = | Standard stack volumetric flow rate. | = | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|      |   |                                      |   | 50566.76      | 50007         | 49802         |
| PPM  | = | PPM                                  | = | 0.07          | 0.17          | 0.20          |

2

|                  | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                |
|------------------|---------------|---------------|---------------|---|------------------------------------------------|
| <b>PPM Corr.</b> | 0.0665        | 0.1662        | 0.2           | = | $C_{gas} = (C - C_o) \frac{C_{ma}}{C_m - C_o}$ |

|     |   |                                                                                               |   |               |               |               |
|-----|---|-----------------------------------------------------------------------------------------------|---|---------------|---------------|---------------|
| Co  | = | Average of initial and final system calibration bias check responses for the zero gas, ppm    | = | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|     |   |                                                                                               |   | -0.055        | -0.075        | -0.01         |
| C   | = | Effluent gas concentration, dry basis, ppm.                                                   | = | 0.01          | 0.09          | 0.19          |
| Cm  | = | Average of initial and final system calibration bias check responses for the upscale gas, ppm | = | 14.04         | 14.24         | 14.41         |
| Cma | = | Actual concentration of the upscale calibration gas, ppm.                                     | = | 14.42         | 14.42         | 14.42         |

# CALCULATIONS

O2

|   |         | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                |
|---|---------|---------------|---------------|---------------|---|------------------------------------------------|
| 1 | % Corr. | 14.21         | 14.76         | 14.27         | = | $C_{gas} = (C - C_o) \frac{C_{ma}}{C_m - C_o}$ |

|     |   |                                                                                      |   | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-----|---|--------------------------------------------------------------------------------------|---|---------------|---------------|---------------|
| Co  | = | Average of initial and final system calibration check responses for the zero gas     | = | 0.14          | 0.27          | 0.26          |
| C   | = | Effluent gas concentration, dry basis,                                               | = | 14.29         | 14.65         | 14.15         |
| Cm  | = | Average of initial and final system calibration bias check responses for the upscale | = | 10.095        | 10.015        | 9.995         |
| Cma | = | Actual concentration of the upscale calibration gas, ppm.                            | = | 10.00         | 10.00         | 10.00         |

# CALCULATIONS

## CO2

|   |         | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |   |                                                      |
|---|---------|---------------|---------------|---------------|---|------------------------------------------------------|
| 1 | % Corr. | 3.24          | 2.92          | 3.32          | = | $C_{gas} = \frac{(C - C_o) \cdot C_{ma}}{C_m - C_o}$ |

|     |   |                                                                                  |   | <u>RUN #1</u> | <u>RUN #2</u> | <u>RUN #3</u> |
|-----|---|----------------------------------------------------------------------------------|---|---------------|---------------|---------------|
| Co  | = | Average of initial and final system calibration check responses for the zero gas | = | -0.005        | 0.02          | 0.025         |
| C   | = | Effluent gas concentration, dry basis,                                           | = | 3.26          | 2.93          | 3.31          |
| Cm  | = | Average of initial and final system calibration check responses for the upscale  | = | 9.795         | 9.72          | 9.63          |
| Cma | = | Actual concentration of the upscale calibration gas, ppm.                        | = | 9.72          | 9.72          | 9.72          |

# **Appendix #1**

## **Test Data**

**Custom Stack Analysis, LLC.**  
**Pitot Traverse Data Sheet for Cyclonics**

Plant Meggitt Aircraft Braking

Date 4/15/2021

Location P039 Accutherm Outlet

By Jim G, Brian L, Dylan G

| Point # | Angle |
|---------|-------|
| 1       | 3     |
| 2       | 3     |
| 3       | 1     |
| 4       | 0     |
| 5       | 2     |
| 6       | 0     |
| 7       | 1     |
| 8       | 1     |
| B-1     | 2     |
| 2       | 1     |
| 3       | 3     |
| 4       | 4     |
| 5       | 2     |
| 6       | 2     |
| 7       | 1     |
| 8       | 0     |
| Avg     | 2     |

# Custom Stack Analysis, LLC.

## Pitot Traverse Data Sheet

Plant Meggitt Aircraft Braking Systems Corporation

Date 4/15/2021

Location P039 Accutherm Outlet

By Brian L

| Run No. | Pre 1     |     | Post 1    |     | Post 2    |     | Post 3    |      |
|---------|-----------|-----|-----------|-----|-----------|-----|-----------|------|
| Point # | Pitot Δ P | °F  | Pitot Δ P | °F  | Pitot Δ P | °F  | Pitot Δ P | °F   |
| A-1     | 0.022     | 878 | 0.023     | 892 | 0.019     | 921 | 0.022     | 942  |
| 2       | 0.024     | 881 | 0.023     | 895 | 0.021     | 926 | 0.025     | 948  |
| 3       | 0.019     | 882 | 0.020     | 908 | 0.022     | 935 | 0.021     | 953  |
| 4       | 0.025     | 883 | 0.023     | 915 | 0.022     | 940 | 0.024     | 958  |
| 5       | 0.018     | 884 | 0.019     | 921 | 0.020     | 947 | 0.020     | 969  |
| 6       | 0.016     | 882 | 0.018     | 926 | 0.018     | 951 | 0.017     | 974  |
| 7       | 0.015     | 880 | 0.017     | 931 | 0.016     | 958 | 0.016     | 979  |
| 8       | 0.012     | 881 | 0.015     | 933 | 0.014     | 966 | 0.014     | 985  |
| B-1     | 0.018     | 865 | 0.018     | 902 | 0.021     | 932 | 0.019     | 960  |
| 2       | 0.020     | 867 | 0.019     | 907 | 0.024     | 937 | 0.020     | 967  |
| 3       | 0.022     | 872 | 0.020     | 913 | 0.020     | 943 | 0.022     | 973  |
| 4       | 0.021     | 874 | 0.022     | 918 | 0.024     | 950 | 0.022     | 981  |
| 5       | 0.018     | 880 | 0.019     | 924 | 0.021     | 954 | 0.019     | 989  |
| 6       | 0.017     | 882 | 0.019     | 930 | 0.018     | 961 | 0.020     | 994  |
| 7       | 0.016     | 883 | 0.018     | 934 | 0.016     | 965 | 0.017     | 998  |
| 8       | 0.014     | 884 | 0.015     | 937 | 0.013     | 968 | 0.015     | 1002 |

|         |        |        |       |        |        |        |       |        |
|---------|--------|--------|-------|--------|--------|--------|-------|--------|
|         | Run #1 |        |       | Run #2 |        | Run #3 |       |        |
|         | 0.14   | 899.63 |       | 0.14   | 932.50 |        | 0.14  | 960.19 |
|         | 0.136  | 881    | 0.138 | 918    | 0.138  | 947    | 0.139 | 973    |
| Static: | 0.186  |        | 0.189 |        | 0.189  |        | 0.192 |        |

# TEST DATA

|              |                                                |
|--------------|------------------------------------------------|
| COMPANY NAME | Meggitt Aircraft Braking Systems Corporation - |
| ADDRESS      | 1204 Massillon Road                            |
| CITY         | Akron                                          |
| STATE        | OH                                             |
| ZIP          | 44306                                          |
| TEST METHODS | Methods 1-4, 3A, 7E, 10 and 25A                |
| CREW MEMBERS | Jim G, Brian L, Dylan G                        |
| LOCATION     | Outlet                                         |
| SOURCE       | P039 Accutherm                                 |
| CONTROL      |                                                |

|                     | RUN #1    | RUN #2    | RUN #3    |
|---------------------|-----------|-----------|-----------|
| DATE                | 4/15/2021 | 4/15/2021 | 4/15/2021 |
| RUN LENGTH (min)    | 60        | 60        | 60        |
| VOLUME (cubic feet) | 45.022    | 44.605    | 45.093    |
| Y FACTOR            | 1.0004    | 1.0004    | 1.0004    |
| BAROMETRIC          | 28.64     | 28.64     | 28.64     |
| METER TEMP. (R)     | 531.04    | 533.75    | 535.79    |
| STACK TEMP. (R)     | 1359.63   | 1392.50   | 1420.19   |
| AVERAGE ^P          | 0.137     | 0.138     | 0.139     |
| AVERAGE ^H          | 2.00      | 2.00      | 2.00      |
| IMPINGER VOLUME     | 51.50     | 62.50     | 59.40     |
|                     |           |           |           |
| PITOT COEF.         | 0.84      | 0.84      | 0.84      |
| STATIC PRESSURE     | 0.188     | 0.189     | 0.191     |
| STACK AREA          | 3.14      | 3.14      | 3.14      |
|                     |           |           |           |
| CARBON DIOXIDE      | 3.24      | 2.92      | 3.32      |
| OXYGEN              | 14.21     | 14.76     | 14.27     |
| NITROGEN            | 82.55     | 82.33     | 82.41     |

# TEST RESULTS

P039 Accutherm Outlet  
4/15/2021

|             | RUN #1   | RUN #2   | RUN #3   |
|-------------|----------|----------|----------|
| VM (std)    | 43.069   | 42.454   | 42.755   |
| VW (std)    | 2.427    | 2.945    | 2.799    |
| BWS         | 0.053    | 0.065    | 0.061    |
| MD          | 29.087   | 29.057   | 29.103   |
| MS          | 28.495   | 28.340   | 28.420   |
| VS (ft/sec) | 12.699   | 13.021   | 13.177   |
|             |          |          |          |
| SCFH        | 50566.76 | 50006.76 | 49802.36 |
| ACFM        | 2393.78  | 2454.40  | 2483.86  |
| DCFM        | 842.78   | 833.45   | 830.04   |

VM (std) = Volume of gas sampled at standard conditions.

Vw (std) = Volume of water vapor collected at standard conditions.

Bws = Stack moisture content.

Md = Determination of dry molecular weight of stack gas.

Ms = Determination of stack gas molecular weight.

Vs = Average gas stack velocity. (ft/sec.)

ACFM = Actual cubic feet per minute of gas velocity.

DCFM = Dry standard cubic feet per minute of gas velocity.

# TEST RESULTS

P039 Accutherm Outlet

4/15/2021

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <b>CEM MONITORING</b> |        |        |        |
| VOC (lbs/hr propane)  | 0.005  | 0.007  | 0.004  |
| VOC (lbs/hr carbon)   | 0.004  | 0.006  | 0.004  |
| NOX (lbs/hr)          | 0.150  | 0.143  | 0.143  |
| CO (lbs/hr)           | 0.000  | 0.001  | 0.001  |
| O2 %                  | 14.214 | 14.756 | 14.268 |
| CO2 %                 | 3.238  | 2.916  | 3.324  |

# TEST DATA

P039 Accutherm Outlet

4/15/2021

|                       | RUN #1 | RUN #2 | RUN #3 |
|-----------------------|--------|--------|--------|
| <b>CEM MONITORING</b> |        |        |        |
| VOC (ppm)             | 0.86   | 1.28   | 0.77   |
| NOX (ppm)             | 24.73  | 24.35  | 24.20  |
| CO (ppm)              | 0.01   | 0.09   | 0.19   |
| O2 (%)                | 14.29  | 14.65  | 14.15  |
| CO2 (%)               | 3.26   | 2.93   | 3.31   |

|                       |       |       |       |
|-----------------------|-------|-------|-------|
| <b>NOX CAL. CORR.</b> |       |       |       |
| INITIAL ZERO          | 0.04  | 0.18  | 0.14  |
| INITIAL UPSCALE       | 25.15 | 25.36 | 25.92 |
| FINAL ZERO            | 0.18  | 0.14  | 0.13  |
| FINAL UPSCALE         | 25.36 | 25.92 | 24.87 |
| ACTUAL UPSCALE        | 25.30 | 25.3  | 25.3  |
| NOX (ppm corrected)   | 24.77 | 24.02 | 24.10 |

|                      |       |       |       |
|----------------------|-------|-------|-------|
| <b>CO CAL. CORR.</b> |       |       |       |
| INITIAL ZERO         | 0.02  | -0.13 | -0.02 |
| INITIAL UPSCALE      | 14.02 | 14.06 | 14.42 |
| FINAL ZERO           | -0.13 | -0.02 | 0     |
| FINAL UPSCALE        | 14.06 | 14.42 | 14.4  |
| ACTUAL UPSCALE       | 14.42 | 14.42 | 14.42 |
| CO (ppm corrected)   | 0.07  | 0.17  | 0.20  |

|                     |       |       |       |
|---------------------|-------|-------|-------|
| <b>O2 CAL CORR.</b> |       |       |       |
| INITIAL ZERO        | 0.02  | 0.26  | 0.28  |
| INITIAL UPSCALE     | 10.07 | 10.12 | 9.91  |
| FINAL ZERO          | 0.26  | 0.28  | 0.24  |
| FINAL UPSCALE       | 10.12 | 9.91  | 10.08 |
| ACTUAL UPSCALE      | 10.00 | 10    | 10    |
| O2 (% corrected)    | 14.21 | 14.76 | 14.27 |

|                      |       |      |      |
|----------------------|-------|------|------|
| <b>CO2 CAL CORR.</b> |       |      |      |
| INITIAL ZERO         | -0.04 | 0.03 | 0.01 |
| INITIAL UPSCALE      | 9.79  | 9.8  | 9.64 |
| FINAL ZERO           | 0.03  | 0.01 | 0.04 |
| FINAL UPSCALE        | 9.80  | 9.64 | 9.62 |
| ACTUAL UPSCALE       | 9.72  | 9.72 | 9.72 |
| CO2 (% corrected)    | 3.24  | 2.92 | 3.32 |

# Custom Stack Analysis, L.L.C.

## Method 4

Plant: eggitt Aircraft Braking Systems Corporation Date : 4/15/2021

|                |       |                        |        |
|----------------|-------|------------------------|--------|
|                |       | Meter Box              |        |
| Barometer (Pg) | 28.64 | ID:                    | 1      |
| Ambient Temp   | 50    | Y                      | 1.0004 |
|                |       | $\Delta H$             | 1.986  |
|                |       | $\Delta H$ Set Point : | 2.0    |
|                | Time  | Run Time               |        |
| Start:         | 13:45 | 60                     |        |
| Stop:          | 14:45 |                        |        |

### Run #1

| Cold Box #         |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| <b>11</b>          | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| Time               |              |            |       |           |         |
| <b>0</b>           | 170.240      | 68         | 64.0  | 63        | 5       |
| <b>5</b>           | 174.012      | 71         | 66.0  | 56        | 5       |
| <b>10</b>          | 177.793      | 72         | 66.0  | 54        | 5       |
| <b>15</b>          | 181.546      | 74         | 67.0  | 53        | 5       |
| <b>20</b>          | 185.323      | 74         | 68.0  | 57        | 5       |
| <b>25</b>          | 189.058      | 75         | 68.0  | 57        | 5       |
| <b>30</b>          | 192.762      | 75         | 69.0  | 58        | 5       |
| <b>35</b>          | 196.477      | 75         | 69.0  | 60        | 5       |
| <b>40</b>          | 200.211      | 75         | 70.0  | 61        | 5       |
| <b>45</b>          | 203.991      | 76         | 70.0  | 62        | 5       |
| <b>50</b>          | 207.748      | 76         | 70.0  | 62        | 5       |
| <b>55</b>          | 211.510      | 76         | 71.0  | 63        | 5       |
| <b>60</b>          | 215.262      |            |       |           |         |
| <b>Vm</b>          | 45.022       |            |       |           |         |
|                    | AVG:         | 71         | 58.8  | 5.0       |         |
| <b>Leak Rate @</b> | 9.0          | " Hg =     | 0.000 |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 15:27 | 60       |
| Stop:  | 16:27 |          |

## Run #2

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>4</b>           | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 215.689      | 73         | 70    | 59        | 6       |
| <b>5</b>           | 219.412      | 74         | 71    | 52        | 6       |
| <b>10</b>          | 223.171      | 75         | 72    | 52        | 6       |
| <b>15</b>          | 226.841      | 75         | 71    | 52        | 6       |
| <b>20</b>          | 230.576      | 77         | 71    | 53        | 6       |
| <b>25</b>          | 234.243      | 76         | 71    | 55        | 6       |
| <b>30</b>          | 237.930      | 76         | 72    | 57        | 6       |
| <b>35</b>          | 241.628      | 77         | 70    | 56        | 6       |
| <b>40</b>          | 245.371      | 77         | 72    | 58        | 6       |
| <b>45</b>          | 249.025      | 77         | 72    | 57        | 6       |
| <b>50</b>          | 252.831      | 77         | 72    | 57        | 6       |
| <b>55</b>          | 256.558      | 77         | 75    | 58        | 6       |
| <b>60</b>          | 260.294      |            |       |           |         |
| <b>Vm</b>          | 44.605       |            |       |           |         |
|                    | AVG:         | 74         |       | 55.5      | 6.0     |
| <b>Leak Rate @</b> | 10.5         | " Hg =     | 0.004 |           |         |

|        |       |          |
|--------|-------|----------|
|        | Time  | Run Time |
| Start: | 17:04 | 60       |
| Stop:  | 18:04 |          |

### Run #3

|                    |              |            |       |           |         |
|--------------------|--------------|------------|-------|-----------|---------|
| Cold Box #         |              |            |       |           |         |
| <b>6</b>           | Meter Volume | Meter Temp |       | Cond Temp | VAC "Hg |
| <b>Time</b>        |              |            |       |           |         |
| <b>0</b>           | 264.046      | 74         | 72    | 58        | 5       |
| <b>5</b>           | 267.823      | 76         | 73    | 53        | 5       |
| <b>10</b>          | 271.548      | 77         | 73    | 53        | 5       |
| <b>15</b>          | 275.332      | 78         | 73    | 54        | 5       |
| <b>20</b>          | 279.127      | 78         | 73    | 58        | 5       |
| <b>25</b>          | 282.879      | 78         | 74    | 58        | 5       |
| <b>30</b>          | 286.626      | 78         | 74    | 57        | 5       |
| <b>35</b>          | 290.390      | 79         | 74    | 57        | 5       |
| <b>40</b>          | 294.139      | 79         | 74    | 58        | 5       |
| <b>45</b>          | 297.893      | 79         | 74    | 56        | 5       |
| <b>50</b>          | 301.663      | 79         | 75    | 53        | 5       |
| <b>55</b>          | 305.358      | 80         | 75    | 54        | 5       |
| <b>60</b>          | 309.139      |            |       |           |         |
| <b>Vm</b>          | 45.093       |            |       |           |         |
|                    | AVG:         | 76         |       | 55.8      | 5.0     |
| <b>Leak Rate @</b> | 10.0         | " Hg =     | 0.000 |           |         |

# **Appendix #2**

## **Laboratory Data**

Lab Data Sheet For: Meggitt Aircraft Braking Systems Corporation - P039 Accutherm Outlet

By: Brian L

Moisture Weights

Moisture

| RUN # 1 |  | Box ID | grams   | grams | grams | grams | grams | grams |
|---------|--|--------|---------|-------|-------|-------|-------|-------|
|         |  |        | 1       | 2     | 3     | 4     | 5     | 6     |
|         |  |        | 11      | 812.6 | 563.0 | 537.8 |       |       |
|         |  |        | Gross   | 726.3 | 610.3 | 536.6 |       |       |
|         |  |        | Tare    | 86.3  | -47.3 | 1.2   | 0.0   | 0.0   |
|         |  |        | Net     |       |       |       |       |       |
|         |  |        | Reagent | H2O   | H2O   |       |       |       |
|         |  |        | mLs     | 100.0 | 100.0 |       |       |       |

|                  |       |                  |               |                       |
|------------------|-------|------------------|---------------|-----------------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>40.2 | grams<br>Total = 51.5 |
|------------------|-------|------------------|---------------|-----------------------|

| RUN # 2 |  | Box ID | grams   | grams | grams | grams | grams | grams |
|---------|--|--------|---------|-------|-------|-------|-------|-------|
|         |  |        | 1       | 2     | 3     | 4     | 5     | 6     |
|         |  |        | 4       | 677.5 | 755.0 | 626.3 |       |       |
|         |  |        | Gross   | 628.1 | 752.7 | 625.2 |       |       |
|         |  |        | Tare    | 49.4  | 2.3   | 1.1   | 0.0   | 0.0   |
|         |  |        | Net     |       |       |       |       |       |
|         |  |        | Reagent | H2O   | H2O   |       |       |       |
|         |  |        | mLs     | 100.0 | 100.0 |       |       |       |

|                  |       |                  |               |                       |
|------------------|-------|------------------|---------------|-----------------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>52.8 | grams<br>Total = 62.5 |
|------------------|-------|------------------|---------------|-----------------------|

| RUN # 3 |  | Box ID | grams   | grams | grams | grams | grams | grams |
|---------|--|--------|---------|-------|-------|-------|-------|-------|
|         |  |        | 1       | 2     | 3     | 4     | 5     | 6     |
|         |  |        | 6       | 792.8 | 655.7 | 488.4 |       |       |
|         |  |        | Gross   | 750.5 | 650.4 | 487.0 |       |       |
|         |  |        | Tare    | 42.3  | 5.3   | 1.4   | 0.0   | 0.0   |
|         |  |        | Net     |       |       |       |       |       |
|         |  |        | Reagent | H2O   | H2O   |       |       |       |
|         |  |        | mLs     | 100.0 | 100.0 |       |       |       |

|                  |       |                  |               |                       |
|------------------|-------|------------------|---------------|-----------------------|
| Initial Imp mL = | 200.0 | Impinger Total = | grams<br>49.0 | grams<br>Total = 59.4 |
|------------------|-------|------------------|---------------|-----------------------|

Scale Serial # 1203240794

# **Appendix #3**

## **Calibration Data**



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 3415-10347847

**Traceable® Certificate of Calibration for Digital Calipers**

Manufactured for and distributed by: Control Company 12554 Galveston Rd B230, Webster, TX 77598

**Instrument Identification:**

Model: 3415,

S/N: 192125551

Manufacturer: Control Company

**Standards/Equipment:**

| Description    | Serial Number | Due Date    | NIST Traceable Reference |
|----------------|---------------|-------------|--------------------------|
| Gage Block Set | 99146223      | 06 Dec 2019 | 1000434942               |

**Certificate Information:**

Technician: 57

Procedure: CAL-05

Cal Date: 23 Apr 2019

Cal Due Date: 23 Apr 2021

Test Conditions: 57.01%RH 23.96°C 1018mBar

**Calibration Data: (New Instrument)**

| Unit(s)   | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U      | TUR    |
|-----------|---------|----------|--------|---------|---------|--------|-------|-------|---------|--------|
| in        | N.A.    | N.A.     |        | 0.1000  | 0.0995  | Y      | 0.099 | 0.101 | 0.0003  | 3.33:1 |
| in        | N.A.    | N.A.     |        | 2.0000  | 1.9985  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in        | N.A.    | N.A.     |        | 4.0000  | 3.998   | Y      | 3.996 | 4.004 | 0.0004  | >4:1   |
| in        | N.A.    | N.A.     |        | 6.0000  | 5.997   | Y      | 5.994 | 6.006 | 0.0005  | >4:1   |
| in depth  | N.A.    | N.A.     |        | 2.0000  | 1.998   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in inside | N.A.    | N.A.     |        | 1.0000  | 0.9995  | Y      | 0.999 | 1.001 | 0.00031 | 3.23:1 |
| in step   | N.A.    | N.A.     |        | 2.0000  | 2.000   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement": (GUM). The uncertainty represents an expanded uncertainty using a coverage factor  $k=2$  to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*  
Nicol Rodriguez, Quality Manager

*Aaron Justice*  
Aaron Justice, Technical Manager

Note:

**Maintaining Accuracy:**

In our opinion once calibrated your Digital Calipers should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Calipers change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

**Recalibration:**

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.control3.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (AZLA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2008 Quality Certified by DNV GL, Certificate No. CERT-01805-2008-AQ-HOU-RvA.  
International Laboratory Accreditation Cooperation (ILAC) - Multilateral Recognition Arrangement (MRA).

B 22438B



AMERICAN WELDING AND GAS  
1210 GLENDALE-MILFORD  
CINCINNATI, OH 45215  
513-772-8786

|                         |                                   |                       |                  |
|-------------------------|-----------------------------------|-----------------------|------------------|
| Cylinder Number:        | EB0052956                         | Certification Date:   | 07 April 2019    |
| Mixture Grade:          | EPA Protocol Standard Gas Mixture | Expiration Date:      | 08 April 2027    |
| Certificate Number:     | 0889C-01T5-C01                    | Lot Number:           | 0889C-01T5       |
| Cylinder Fill Pressure: | 2015 PSIG                         | Customer Part Number: | T5E 4800001-A1-2 |

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

### Certified Concentrations

| Component      | Concentration | Uncertainty          | Assay Dates |
|----------------|---------------|----------------------|-------------|
| Oxygen         | 10.0%         | +/- 0.10% (absolute) | 4/7/2019    |
| Carbon Dioxide | 9.72%         | +/- 0.04% (absolute) | 4/7/2019    |
| Nitrogen       | Balance       |                      |             |

### Analytical Instrumentation

| Component      | Analytical Principle | Make     | Model | Serial         | MPC Date  |
|----------------|----------------------|----------|-------|----------------|-----------|
| Oxygen         | GC-TCD               | Shimadzu | GC-8A | C10495021497SA | 3/25/2019 |
| Carbon Dioxide | GC-TCD               | Shimadzu | GC-8A | C10495021497SA | 3/27/2019 |

### Reference Standards

| Serial Number | Lot    | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|--------|------------|------|-----------|---------|---------------|-----------------|----------------|
| D885109       | VSL    | 9/14/2023  | PRM  | O2        | N2      | 21.00%        | 0.100           | VSL            |
| FF13624       | 9-D-37 | 3/8/2021   | SRM  | CO2       | N2      | 16.08%        | 0.124           | 2745           |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of  $k=2$  to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. Mixture stability is certified according to maximum certification periods set forth by Table 2-3 of EPA 600/R-12/531 May 2012. The listed expiration date may be extended by special request. The nitrogen used as a component or balance gas as well as the oxygen used in air mixtures meets the requirements set forth in EPA 1085.750. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025:2005

Preparer: Allison Hanover

Reviewer: Abby Helman

Production Laboratory:

Tier 5 Labs, LLC

5353 W. Southern Ave.

Indianapolis, IN 46241

PGVP Vendor ID R12019

B218561



Scott-Gross Co., Inc.  
664 Magnolia Ave.  
Lexington, KY 40505  
(859)231-0225 (888)431-5882

## Certificate of Analysis


Certification Date: 12 January 2017  
Certificate Number: 0097B-02T5-C01  
Mixture Grade: EPA Protocol Standard Gas Mixture  
Lot Number: 0097B-02T5  
Expiration Date: 12 January 2025  
Cylinder Number: EB0049442  
Part Number: T5L EPA2RATAP-14

| Mixture Components | Requested Composition | Certified Composition | U (Expanded Uncertainty, k=2) |
|--------------------|-----------------------|-----------------------|-------------------------------|
| Propane            | 43 ppm                | 47.05 PPM             | +/- 0.12 PPM (absolute)       |
| Air                | Balance               | Balance               |                               |

Cylinder Pressure: 1900 psi – Do not use below 100 psi (0.7 megapascals)  
Production Lab: Tier 5 Labs, LLC, Indianapolis, IN, PGVP Vendor ID R12017  
Procedure Used: EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012  
Analytical Method: C3H8: FTIR  
Multipoint Calibration Date: Propane: 12/29/2016

| Reference Standards |         |            |      |           |         |               |                 |                |
|---------------------|---------|------------|------|-----------|---------|---------------|-----------------|----------------|
| Serial Number       | Lot     | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
| CAL017809           | 83-J-12 | 8/17/2017  | SRM  | C3H8      | Air     | 48.83 PPM     | 0.225           | 1667b          |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025-2005.

  
Jeff Lynn



**LIQUID TECHNOLOGY CORPORATION**  
"INDUSTRY LEADER IN SPECIALTY GASES"

Certificate of Analysis  
**- EPA PROTOCOL GAS -**

Customer IE Monitoring Instruments (Worthington, OH)  
Date October 06, 2014  
Delivery Receipt DR-53322  
Gas Standard 13.8 ppm Propane/Air - EPA PROTOCOL  
Final Analysis Date October 06, 2014  
Expiration Date October 07, 2022

B21477B

Component Propane  
Balance Gas Air

Analytical Data:  
EPA Protocol, Section No. 2.2, Procedure G-1.

**DO NOT USE BELOW 100 psig**

Reported Concentrations  
**Propane: 13.7 ppm +/- 0.1 ppm**  
**Air: Balance**

Reference Standards:

SRM/GMIS: GMIS  
Cylinder Number: CC-165367  
Concentration: 20.21 ppm Propane (+/- 0.09 ppm)  
Expiration Date: 12/02/18  
NIST Sample Number: NA

GMIS Traceability

SRM-1667b  
XF-00385B  
49.54 ppm Propane (+/- 0.26 ppm)  
07/12/15  
83-I-14

Certification Instrumentation

Component: Propane  
Make/Model: Agilent 7890A  
Serial Number: CN10736166  
Principal of Measurement: GC-FID  
Last Calibration: September 28, 2014

Cylinder Data

Cylinder Serial Number: EB-0051537  
Cylinder Volume: 138 Cubic Feet  
Cylinder Outlet: CGA 590  
Cylinder Pressure: 1950 psig, 70°F

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-12/531.

Certified by:

*Cole Dylewski*  
Cole Dylewski

PGVP Vendor ID: E12014

**"UNMATCHED EXCELLENCE"**

B21925B


**GASES  
& EQUIPMENT**
**INDUSTRIAL  
MEDICAL  
SPECIALTY**

 Scott-Gross Co., Inc.  
 664 Magnolia Ave.  
 Lexington, KY 40505  
 (502) 231-6225 (502) 451-5862

 Cylinder Number: CC444889  
 Mixture Grade: EPA Protocol Standard Gas Mixture  
 Certificate Number: 1147B-02T5-C01  
 Cylinder Pressure: 2015 PSIG

 Certification Date: 28 April 2017  
 Expiration Date: 29 April 2025  
 Lot Number: 1147B-02T5  
 Customer Part Number: T5L EPA2RATAP-19

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

**Certified Concentrations**

| Component | Concentration | Uncertainty            | Assay Dates |
|-----------|---------------|------------------------|-------------|
| Propane   | 24.7 PPM      | +/- 0.2 PPM (absolute) | 4/28/2017   |
| Air       | Balance       |                        |             |

**Analytical Instrumentation**

| Component | Analytical Principle | Make   | Model       | Serial     | MPC Date  |
|-----------|----------------------|--------|-------------|------------|-----------|
| Propane   | FTIR                 | Thermo | Antaris IGS | AW21200-17 | 4/17/2017 |

**Reference Standards**

| Serial Number | Lot        | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|------------|------------|------|-----------|---------|---------------|-----------------|----------------|
| CC459851      | 2186A-01T5 | 11/10/2024 | GMIS | C3H8      | N2      | 247.7 PPM     | 0.411           | 2644a          |

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of  $k=2$  to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid.

This calibration meets the requirements of ISO/IEC 17025:2005

Analyst: Allison Hanover

Reviewer: Jeff Lynn

Production Laboratory:

Tier 5 Labs, LLC

5353 W. Southern Ave.

Indianapolis, IN 46241

PGVP Vendor ID R12017



TIER 5 LABS  
6363 W. SOUTHERN AVE.  
INDIANAPOLIS, IN 46241  
317-438-8890

6225736

Cylinder Number: CC514251  
Mixture Grade: EPA Protocol Standard Gas Mixture  
Certificate Number: 1690A-07T5-C01  
Cylinder Fill Pressure: 2015 PSIG

Certification Date: 15 July 2020  
Expiration Date: 15 July 2023  
Lot Number: 1690A-07T5  
Customer Part Number: T5E AM0001-A1-15

Do not use below 100 psi (0.7 megapascals)

EPA Traceability Protocol for Gaseous Calibration Standards Procedure G1, EPA/600/R-12/531 May 2012

### Certified Concentrations

| Component      | Concentration | Uncertainty             | Assay Dates          |
|----------------|---------------|-------------------------|----------------------|
| Sulfur Dioxide | 26.7 PPM      | +/- 0.2 PPM (absolute)  | 7/6/2020, 7/15/2020  |
| Nitric Oxide   | 25.3 PPM      | +/- 0.11 PPM (absolute) | 6/23/2020, 6/30/2020 |
| Nitrogen       | Balance       |                         |                      |

### Analytical Instrumentation

| Component      | Analytical Principle | Make   | Model   | Serial     | MPC Date  |
|----------------|----------------------|--------|---------|------------|-----------|
| Sulfur Dioxide | NDIR                 | Horiba | VA-3111 | PC062W1E   | 6/25/2020 |
| Nitric Oxide   | Chemiluminescence    | Thermo | 42iQ    | 1200906802 | 6/25/2020 |

### Reference Standards

| Serial Number | Lot        | Expiration | Type | Component | Balance | Concentration | Uncertainty (%) | NIST Reference |
|---------------|------------|------------|------|-----------|---------|---------------|-----------------|----------------|
| CC473760      | 3108A-02T5 | 1/23/2027  | GMIS | SO2       | N2      | 102.13 PPM    | 0.798           | 1694a          |
| CC480411      | 1847A-02T5 | 10/4/2025  | GMIS | NO        | N2      | 300.03 PPM    | 0.437           | 2735           |

### Notes

NOx = 25.6 ppm REFERENCE VALUE ONLY

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of k=2 to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. The nitrogen used as a component or balance gas as well as the oxygen used in air mixtures meets the requirements set forth in EPA 1065.750. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025:2005

Prepared: Christopher Haas

Reviewer: Allison Martinez

Production Laboratory:  
Tier 5 Labs, LLC  
5353 W. Southern Ave.  
Indianapolis, IN 46241  
PGVP Vendor ID R12020

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

|                  |                          |                     |                  |
|------------------|--------------------------|---------------------|------------------|
| Part Number:     | E02NI99E15A0163          | Reference Number:   | 54-401724343-1   |
| Cylinder Number: | CC265467                 | Cylinder Volume:    | 144.3 Cubic Feet |
| Laboratory:      | 124 - Chicago (SAP) - IL | Cylinder Pressure:  | 2015 PSIG        |
| PGVP Number:     | B12020                   | Valve Outlet:       | 660              |
| Gas Code:        | NO,NOX,BALN              | Certification Date: | Feb 18, 2020     |

**Expiration Date: Feb 18, 2023**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 800/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

### ANALYTICAL RESULTS

| Component    | Requested Concentration | Actual Concentration | Protocol Method | Total Relative Uncertainty | Assay Dates            |
|--------------|-------------------------|----------------------|-----------------|----------------------------|------------------------|
| NOX          | 45.00 PPM               | 46.93 PPM            | G1              | +/- 1.1% NIST Traceable    | 02/10/2020, 02/18/2020 |
| NITRIC OXIDE | 45.00 PPM               | 46.93 PPM            | G1              | +/- 1.1% NIST Traceable    | 02/10/2020, 02/18/2020 |
| NITROGEN     | Balance                 |                      |                 |                            |                        |

### CALIBRATION STANDARDS

| Type | Lot ID     | Cylinder No | Concentration                       | Uncertainty | Expiration Date |
|------|------------|-------------|-------------------------------------|-------------|-----------------|
| NTRM | 16060650   | CC442691    | 50.42 PPM NITRIC OXIDE/NITROGEN     | +/- 0.8%    | Jun 27, 2020    |
| PRM  | 12386      | D685025     | 9.91 PPM NITROGEN DIOXIDE/AIR       | +/- 2.0%    | Feb 20, 2020    |
| GMIS | 7302017104 | CC506604    | 4.426 PPM NITROGEN DIOXIDE/NITROGEN | +/- 2.1%    | Jul 03, 2022    |

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

### ANALYTICAL EQUIPMENT

| Instrument/Make/Model   | Analytical Principle | Last Multipoint Calibration |
|-------------------------|----------------------|-----------------------------|
| Nicolet 6700 AMP0900100 | FTIR                 | Feb 03, 2020                |
| Nicolet 6700 AMP0900100 | FTIR                 | Feb 03, 2020                |

Triad Data Available Upon Request



*K. V. B. J.*

Approved for Release

## CERTIFICATE OF ANALYSIS

### Grade of Product: EPA Protocol

|                  |                          |                     |                |
|------------------|--------------------------|---------------------|----------------|
| Part Number:     | E02NI99E15A1129          | Reference Number:   | 54-401830766-1 |
| Cylinder Number: | CC267139                 | Cylinder Volume:    | 144.3 CF       |
| Laboratory:      | 124 - Chicago (SAP) - IL | Cylinder Pressure:  | 2015 PSIG      |
| PGVP Number:     | B12020                   | Valve Outlet:       | 350            |
| Gas Code:        | CO,BALN                  | Certification Date: | Jun 11, 2020   |

**Expiration Date: Jun 11, 2028**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

| ANALYTICAL RESULTS |                         |                      |                 |                            |             |
|--------------------|-------------------------|----------------------|-----------------|----------------------------|-------------|
| Component          | Requested Concentration | Actual Concentration | Protocol Method | Total Relative Uncertainty | Assay Dates |
| CARBON MONOXIDE    | 15.00 PPM               | 14.42 PPM            | G1              | +/- 0.4% NIST Traceable    | 06/11/2020  |
| NITROGEN           | Balance                 |                      |                 |                            |             |

| CALIBRATION STANDARDS |        |             |                                    |             |                 |
|-----------------------|--------|-------------|------------------------------------|-------------|-----------------|
| Type                  | Lot ID | Cylinder No | Concentration                      | Uncertainty | Expiration Date |
| NTRM                  | 150102 | KAL004704   | 24.35 PPM CARBON MONOXIDE/NITROGEN | +/- 0.3%    | Sep 04, 2021    |

| ANALYTICAL EQUIPMENT             |                      |                             |
|----------------------------------|----------------------|-----------------------------|
| Instrument/Make/Model            | Analytical Principle | Last Multipoint Calibration |
| (CO-4) Thermo 48i-TLE 1406960657 | NDIR                 | Jun 01, 2020                |

Triad Data Available Upon Request



  
 Approved for Release

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

|                  |                          |                     |                |
|------------------|--------------------------|---------------------|----------------|
| Part Number:     | E02NI99E15A0497          | Reference Number:   | 54-401871452-1 |
| Cylinder Number: | XC026367B                | Cylinder Volume:    | 144.3 CF       |
| Laboratory:      | 124 - Chicago (SAP) - IL | Cylinder Pressure:  | 2015 PSIG      |
| PGVP Number:     | B12020                   | Valve Outlet:       | 350            |
| Gas Code:        | CO,BALN                  | Certification Date: | Aug 03, 2020   |

**Expiration Date: Aug 03, 2028**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

| ANALYTICAL RESULTS |                         |                      |                 |                            |             |
|--------------------|-------------------------|----------------------|-----------------|----------------------------|-------------|
| Component          | Requested Concentration | Actual Concentration | Protocol Method | Total Relative Uncertainty | Assay Dates |
| CARBON MONOXIDE    | 30.00 PPM               | 29.76 PPM            | G1              | +/- 0.6% NIST Traceable    | 08/03/2020  |
| NITROGEN           | Balance                 |                      |                 |                            |             |

| CALIBRATION STANDARDS |          |             |                                    |             |                 |
|-----------------------|----------|-------------|------------------------------------|-------------|-----------------|
| Type                  | Lot ID   | Cylinder No | Concentration                      | Uncertainty | Expiration Date |
| NTRM                  | 09010228 | KAL004841   | 98.48 PPM CARBON MONOXIDE/NITROGEN | +/- 0.5%    | Oct 16, 2024    |

| ANALYTICAL EQUIPMENT             |                      |                             |
|----------------------------------|----------------------|-----------------------------|
| Instrument/Make/Model            | Analytical Principle | Last Multipoint Calibration |
| CO-1 SIEMENS ULTRAMAT 6E N1J5700 | NDIR                 | Jul 15, 2020                |

Triad Data Available Upon Request



*[Signature]*

Approved for Release

## CONVERSION FACTORS

1 mm Hg = 0.1333 kPa  
1 inch = 0.39370 cm  
1 inch = 0.03937 mm  
1 cu ft = 28.32 liters

1 mm Hg = 0.13330 kPa

|          |            |
|----------|------------|
| 1 inch = | 0.39370 cm |
| 1 inch = | 0.0254 m   |

1 inch = 25.4 mm

1001 - 70.07 20.07 20.07

**Page** \_\_\_\_\_

Barometric Pressure: -----

**Barometric Pressure:** 1010.0 mmHg

**IMPORTANT** For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

IMPORTANT The Critical Orifice Coefficient,  $K'$ , must be entered in English units.  $(ft)^3/(deg R)^{0.5}/(in. Hg)^*(min)$ .

**Figure 1**

\_\_\_\_\_ DRY GAS METER READINGS

CRITICAL ORIFICE READINGS-

| dH<br>(in H2O) | Time<br>(min) | Volume<br>Initial<br>(ft³) | Volume<br>Final<br>(ft³) | Volume<br>Total<br>(liters) | Initial Temps.   |                   | Final Temps.     |                   | Orifice K Orifice<br>Serial#<br>(number) | Actual<br>Vacuum<br>(in Hg) | -- Ambient Temperature -- |                  | -- Average Temperatures -- |                          |                           |                            |
|----------------|---------------|----------------------------|--------------------------|-----------------------------|------------------|-------------------|------------------|-------------------|------------------------------------------|-----------------------------|---------------------------|------------------|----------------------------|--------------------------|---------------------------|----------------------------|
|                |               |                            |                          |                             | Inlet<br>(deg F) | Outlet<br>(deg F) | Inlet<br>(deg F) | Outlet<br>(deg F) |                                          |                             | Initial<br>(deg F)        | Final<br>(deg F) | Average<br>(deg F)         | DGM<br>Outlet<br>(deg R) | DGM<br>Overall<br>(deg R) | Ambient<br>Temp<br>(deg R) |
| 0.5            | 10            | 311.555                    | 315.488                  | 411.38256                   | 62               | 61                | 65               | 62                | 12                                       | 0.30390681                  | 15                        | 64               | 64                         | 521.5                    | 522.5                     | 524                        |
| 0.93           | 10            | 315.488                    | 320.61                   | 150.71904                   | 67               | 63                | 66               | 63                | 16                                       | 0.41080925                  | 15                        | 64               | 65                         | 523                      | 524.75                    | 524.5                      |
| 1.4            | 10            | 320.81                     | 327.085                  | 177.708                     | 66               | 64                | 68               | 65                | 19                                       | 0.4649779                   | 15                        | 65               | 65                         | 524.5                    | 525.75                    | 525                        |
| 2.1            | 5             | 327.085                    | 331.027                  | 111.63744                   | 68               | 65                | 69               | 66                | 23                                       | 0.50910402                  | 15                        | 66               | 66                         | 525.5                    | 527                       | 526                        |
| 3.8            | 5             | 331.027                    | 336.224                  | 147.17904                   | 68               | 66                | 70               | 67                | 31                                       | 0.80595932                  | 15                        | 66               | 66                         | 526.5                    | 527.75                    | 526                        |

## RESULTS

--- DRY GAS METER ---

--- DRY GAS METER ---

PRICE \_\_\_\_\_

[illegible]

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is  $\pm 0.02$ .

For Orifice Calibration Factor  $dH_0$ , the orifice differential pressure in inches of  $H_2O$  that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is  $\pm 0.2$ .

SIGNED: Brian Lemasters

Date: 5/7/2020



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 3415-11278230

Traceable® Certificate of Calibration for Digital Calipers

Customer :Custom Stack Analysis, LLC ,14614 Cenfield Street NE ,Alliance ,OH-44601 ,U.S.A.

Instrument Identification:

Model: 3415,

S/N: 101856179

Manufacturer: Control Company

Standards/Equipment:

| Description | Serial Number | Due Date    | NIST Traceable Reference |
|-------------|---------------|-------------|--------------------------|
| Gage Set    | 99146223      | 17 Dec 2020 | 1000449283               |

Certificate Information:

Technician: 57

Procedure: CAL-05

Cal Date: 12 May 2020

Cal Due Date: 12 May 2021

Test Conditions: 55.18%RH 22.45°C 1018mBar

Calibration Data:

| Unit(s)   | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U      | TUR    |
|-----------|---------|----------|--------|---------|---------|--------|-------|-------|---------|--------|
| in        | N.A.    | N.A.     |        | 0.1000  | 0.1005  | Y      | 0.099 | 0.101 | 0.0003  | 3.33:1 |
| in        | N.A.    | N.A.     |        | 2.0000  | 2.0005  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| in        | N.A.    | N.A.     |        | 4.0000  | 4.0005  | Y      | 3.996 | 4.004 | 0.0004  | >4:1   |
| in        | N.A.    | N.A.     |        | 6.0000  | 6.0005  | Y      | 5.994 | 6.006 | 0.0005  | >4:1   |
| In depth  | N.A.    | N.A.     |        | 2.0000  | 2.000   | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |
| In inside | N.A.    | N.A.     |        | 1.0000  | 1.0005  | Y      | 0.999 | 1.001 | 0.00031 | 3.23:1 |
| In step   | N.A.    | N.A.     |        | 2.0000  | 1.9985  | Y      | 1.998 | 2.002 | 0.00033 | >4:1   |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement": (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio;  
Accuracy= $\pm(\text{Max}-\text{Min})/2$ ; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*

Nicol Rodriguez, Quality Manager

*Marisa Elms*

Marisa Elms, Technical Manager

Note:

Maintaining Accuracy:

In our opinion once calibrated your Digital Calipers should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Calipers change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

Issue Date: 12 May 2020

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.traceable.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2015 Quality Certified by DNV GL, Certificate No. CERT-01806-2006-AQ-HOU-ANAB.  
International Laboratory Accreditation Cooperation - Multilateral Recognition Arrangement (ILAC-MRA).



Calibration complies with ISO/IEC  
17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 1870-11290275

## Traceable® Certificate of Calibration for Digital Barometer Module

Customer: Custom Slack Analysis, LLC, 14614 Cenfield Street NE, Alliance, OH 44601, U.S.A.

### Instrument Identification:

Model: 1870,

S/N: 90724105

Manufacturer: Control Company

### Standards/Equipment:

| Description               | Serial Number  | Due Date    | NIST Traceable Reference |
|---------------------------|----------------|-------------|--------------------------|
| Digital Thermometer       | 221197993      | 10 Oct 2020 | 4000-10785768            |
| Chilled Mirror Hygrometer | 31874/1H2048MR | 22 Jan 2021 | 18004                    |
| Digital Barometer         | D4540001       | 01 Nov 2020 | 1000447551               |

### Certificate Information:

Technician: 57

Procedure: CAL-31

Cal Date: 17 May 2020

Cal Due Date: 17 May 2021

Test Conditions: 57.18%RH 22.6°C 1012mBar

### Calibration Data:

| Unit(s) | Nominal | As Found | In Tol | Nominal | As Left | In Tol | Min   | Max   | ±U   | TUR  |
|---------|---------|----------|--------|---------|---------|--------|-------|-------|------|------|
| %RH     | N.A.    | N.A.     |        | 48.33   | 32      | N      | 43    | 53    | 0.74 | >4:1 |
| °C      | N.A.    | N.A.     |        | 24.29   | 24      | Y      | 23.29 | 25.29 | 0.05 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 806.00  | 812     | Y      | 795   | 817   | 0.62 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 909.98  | 914     | Y      | 899   | 921   | 0.62 | >4:1 |
| mb/hPa  | N.A.    | N.A.     |        | 1018.72 | 1022    | Y      | 1008  | 1030  | 0.62 | >4:1 |

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO 'Guide to the Expression of Uncertainty in Measurement': (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio; Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

*Nicol Rodriguez*

Nicol Rodriguez, Quality Manager

*Marisa Elms*

Marisa Elms, Technical Manager

Note:

### Maintaining Accuracy:

In our opinion once calibrated your Digital Barometer Module should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Barometer Module change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

### Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

Issue Date: 17 May 2020

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.traceable.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2015 Quality Certified by DNV GL, Certificate No. CERT-01805-2008-AQ-HOU-ANAB.  
International Laboratory Accreditation Cooperation - Multilateral Recognition Arrangement (ILAC-MRA).



**MATHESON**

"The Gas Professionals"

1650 Enterprise Parkway  
Twinsburg, OH 44087  
215-648-4000

Certificate of Analysis - EPA Protocol Mixtures

Customer: YOUNGSTOWN OXYGEN  
Cylinder Number: SD-13278  
Cylinder pressure: 2000 psig  
Last Analysis date: 4/3/2017  
Expiration Date: 4/3/2025

Protocol: Reference # Lot #  
G1 15143972 109-96-38369

DO NOT USE THIS CYLINDER WHEN THE  
PRESSURE FALLS BELOW 100 PSIG

REPLICATE RESPONSES

Component: Carbon Dioxide  
Certified Conc: 20.04%  $\pm$  0.04%

Date: 4/3/2017 Date:  
20.04%  
20.04%  
20.04%

Component: Oxygen  
Certified Conc: 20.00%  $\pm$  0.03%

Date: 4/3/2017 Date:  
20.02%  
20.00%  
19.98%

BALANCE GAS: Nitrogen

REFERENCE STANDARDS

Component: Carbon Dioxide  
SRM #: SRM-2745  
Sample #: 9-D-41  
Cylinder #: FF-13582  
Concentration: 16.080%

Oxygen  
SRM-2659a  
71-E-31  
FF-22194  
20.863%

CERTIFICATION INSTRUMENTS

Component: Carbon Dioxide  
Make/Model: Varian 3800 GC  
Serial Number: LR-92489  
Measurement Principle: TCD, FID  
Last Calibration: 3/13/2017

Oxygen  
Horiba MPA-510  
9XUJXODW  
Paramagnetic  
3/14/2017

Notes: G2695116X

The certification was performed according to EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards May 2012, using procedure G1 and/or G2. U.S EPA Vendor ID Number: D42017, PGVP Participation Date: 01/01/17, PGVP Renewal Date: 01/01/18. The expanded uncertainty listed for each component was calculated at a coverage factor of  $k=2$  and at a level of confidence of 95%.

*Philip D. Mant.*

Analyst \_\_\_\_\_ Date 4/4/2017



7410 Worthington-Galena Rd  
Worthington, Ohio 43085  
Phone: (614) 436-4933

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.icrents.com](http://www.icrents.com)

### Temperature RTD Calibrator Certificate of Calibration

Instrument: Altek Series 22 T/C  
Serial#: 243783  
Technician: Sam Shults

Date: 11/3/2020  
Due: 11/3/2021

#### Custom Stack Analysis

| <u>Left Slide</u>   |                    | <u>Right Slide</u>  |                    |
|---------------------|--------------------|---------------------|--------------------|
| <u>Lab Standard</u> | <u>UUT Reading</u> | <u>Lab Standard</u> | <u>UUT Reading</u> |
| 0.0                 | -0.5               | 100.0               | 99.7               |
| 1000.0              | 1000.6             | 1100.0              | 1099.6             |
| 2000.0              | 2000.5             | 2100.0              | 2099.2             |

Accuracy  
+/- 1.0 F

#### Reference Standards

PIE 525B sn.116763 Cal Due:9/28/2021

Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable



7410 Worthington-Galena Rd  
Worthington, Ohio 43085  
Phone: (614) 436-4933

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.iemts.com](http://www.iemts.com)

### Dwyer Digital Manometer Certificate of Calibration

Instrument: Dwyer 475 Digital Manometer  
Serial#: E46Z

Date: 11/3/2020  
Technician: Sam Shults

#### Custom Stack

##### Positive Port

| <u>Calibrated Source</u> | <u>Dwyer Mark III</u> | <u>% Accuracy</u> |
|--------------------------|-----------------------|-------------------|
| 0.500                    | 0.498                 | +/- 0.04" H2O     |
| 2.000                    | 2.005                 | 0.3               |
| 3.000                    | 3.008                 | 0.3               |
| 4.000                    | 4.009                 | 0.2               |

##### Negative Port

| <u>Calibrated Source</u> | <u>Dwyer Mark III</u> | <u>% Accuracy</u> |
|--------------------------|-----------------------|-------------------|
| 0.500                    | 0.501                 | +/- 0.04" H2O     |
| 2.000                    | 2.008                 | 0.4               |
| 3.000                    | 3.009                 | 0.3               |
| 4.000                    | 4.005                 | 0.1               |

Allowable Tolerance +/- 1.0% "H2O FS

#### Reference Standards

Druck 740 DPI sn.74001549, Cal Due: 12/13/2020

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**

**MATHESON**

ask...The Gas Professionals™

1700 Scepter Rd

Waverly, TN 37185

931-296-3357

**Certificate of Analysis - EPA Protocol Mixtures**Customer: WHS 109  
Y-TOWN

Part # G2695803

Cylinder Number: CC78213

Cylinder Pressure: 2000 psig

Last Analysis Date: 8/24/2020

Expiration Date: 8/24/2023

Protocol: Reference #: Lot#:  
G1 T270458-01 9090406167**DO NOT USE THIS CYLINDER WHEN THE  
PRESSURE FALLS BELOW 100 PSIG****REPLICATE RESPONSES**

|                                          | Date: 8/17/2020 | Date: 8/24/2020 |
|------------------------------------------|-----------------|-----------------|
| Component: Nitrogen Dioxide              | 49.4            | 49.6            |
|                                          | 49.3            | 49.5            |
| Certified Conc: 49.5 ppm +/- 0.9 ppm ABS | 49.3            | 49.7            |

BALANCE GAS: AIR

**REFERENCE STANDARDS:**Component: Nitrogen Dioxide  
Reference Standard: GMIS  
Cylinder #: E80097397  
Concentration: 47.8 +/- 0.8 ppm ABS  
Exp Date: 9/21/2021Component: Nitrogen Dioxide  
Reference Standard: PRM  
Cylinder #: D562925  
Concentration: 75.0 +/- 1.1 ppm ABS  
Exp Date: 2/2/2019  
SRM #: -  
NIST Sample #: -**CERTIFICATION INSTRUMENTS**Component: Nitrogen Dioxide  
Make/Model: CAI 600  
Serial Number: Y09003  
Measurement Principle: CHEMI  
Last Calibration: 8/24/2020**Notes:**

The certification was performed by Global Calibration Gases, LLC, Sarasota, FL and according to EPA Traceability Protocol for Assay and Certification Standards May 2012, using procedure G1 and/or G2, U.S. EPA PGVP Vendor ID number: N22020  
The expanded uncertainty listed for each component was calculated at a coverage factor of k=2 and at level of confidence of 95%

Analyst:

Date: 8/24/2020

Signature on file

QA:

Ashley Smallwood

Date: 9/1/2020



**Manufacturing Location**  
1650 ENTERPRISE PARKWAY  
TWINSBURG, OH 44087

CYLINDER NUMBER(S)  
SD012979

**Pressure:** 2000 psig @ 70°F; 13891 kPa @ 21°C

## COMMENTS

Lot No: 1099638166  
Fill Date: 02/10/2017  
Expiration Date: 02/13/2020  
Analysis Date: 02/13/2017

Unless otherwise indicated, Matheson Tri-Gas terms and conditions govern the product data contained herein. This document was issued electronically and data validated by electronic signature. For further information visit [www.matheson-trigas.com](http://www.matheson-trigas.com).

02/13/2017

Date \_\_\_\_\_

**MATHESON**

ask...The Gas Professionals®

**Certificate of Batch Analysis**

To: Matheson

Sales Order No:

Purchase Order:

Manufacturing LocationMatheson  
1055 Garden Street  
Greensburg, PA 15601

Product: Air

Grade: Ultra Zero

Part No: G2001312

Cylinder Size: 1L

Valve: CGA 580

Pressure: 2400 PSIG

**CYLINDER NUMBER(S)**748203Y  
30-872  
W-450273  
TWC-563435  
279432Y  
3041791Y  
24596  
BA-1423  
NK00455  
7899  
08572  
784182  
3887456Y  
SG904256  
935783  
46-1392

| Component       | Specification | Certified Concentration | Units | Analytical Method |
|-----------------|---------------|-------------------------|-------|-------------------|
| Oxygen          | 20 - 22       | 20.8                    | %     | J                 |
| THC             | <0.1          | 0.01                    | ppm   | E                 |
| Water           | <2            | 1.6                     | ppm   | F                 |
| Carbon Dioxide  | <1            | ND                      | ppm   | H                 |
| Carbon Monoxide | <1            | ND                      | ppm   | H                 |
|                 |               |                         |       |                   |
|                 |               |                         |       |                   |
|                 |               |                         |       |                   |
|                 |               |                         |       |                   |
|                 |               |                         |       |                   |
|                 |               |                         |       |                   |
|                 |               |                         |       |                   |
|                 |               |                         |       |                   |

**COMMENTS**

Product Composition verified by instrumentation calibrated with at least one of the following: NIST traceable weights, gas mixtures traceable to NIST weights, NIST gas standards such as NTRM's or SRM's, manufacturer NIST calibrations.

**Analytical Method Key**

|   |                                                      |   |                                                          |
|---|------------------------------------------------------|---|----------------------------------------------------------|
| A | Trace oxygen analyzer                                | G | Gas chromatograph with thermal conductivity detector     |
| B | Gas chromatograph with thermal conductivity detector | H | Gas chromatograph with mass spectrometer carbon detector |
| C | Gas chromatograph with flame ionization detector     | I | Specific carbon monoxide analyzer                        |
| D | Trace nitrogen analyzer                              | J | Permox oxygen analyzer                                   |
| E | Total hydrocarbon analyzer                           | K | Specific carbon dioxide analyzer                         |
| F | Specific moisture analyzer                           | L | Binary gas mixture analyzer                              |

Lot No: 118K41520

Fill Date: 4/28/2015

**IMPORTANT**

The information contained herein has been prepared at your request by qualified experts within Matheson. While we believe that the information is accurate within the limits of the analytical methods employed and is complex to the extent of the specified analysis performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Matheson arising out of the use of the information contained herein exceed the fee established for providing such information.

The undersigned certifies that the product(s) listed above reflect gas phase by volume (unless otherwise indicated) and meet or exceed the minimum purity specification(s).

Analyst

12/20/16

Date

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

595572

FOR Custom Stack 593P

14614 CenField St Alliance Ohio

P.O. DATE 3/12/20

☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5525 Gallileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Penimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 1001 Findlay Rd.  
 LIMA, OH 45801  
 419-228-5021  
☐ 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7180  
☐ 528 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46814  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 43089  
 513-777-5800  
☐ 100 McClunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF Ohio TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT Colam lot #3

S/N'S 1192529404

PARTS USED 2019-0187

SCALE TECHNICIAN: MR. [Signature]

ACCEPTED BY: [Signature]

| TAG NO.       | MFG           | MOD NO.          | S/N               | LOC.       | CAP.          | GRAD. SIZE  | NORM RING                     | CAL FRO       | CLEAN TEST | CAL STICK  | NEXT CAL       |
|---------------|---------------|------------------|-------------------|------------|---------------|-------------|-------------------------------|---------------|------------|------------|----------------|
|               | <u>Chaus</u>  | <u>Navigator</u> | <u>1192529404</u> | <u>Lab</u> | <u>2,100g</u> | <u>0.1g</u> | <u>HI 2000</u><br><u>LO 0</u> | <u>Months</u> | <u>YES</u> | <u>YES</u> | <u>11/2020</u> |
| WGT USED      | AS FOUND      | DEV.             | TOL. +/-          | ADJUSTED   | AS LEFT       | COMMENTS    |                               |               |            |            |                |
| 1 <u>200</u>  | <u>200.0</u>  | <u>0</u>         |                   | <u>NO</u>  | <u>200.0</u>  |             |                               |               |            |            |                |
| 2 <u>500</u>  | <u>500.0</u>  | <u>0</u>         |                   | <u>NO</u>  | <u>500.0</u>  |             |                               |               |            |            |                |
| 3 <u>1000</u> | <u>1000.0</u> | <u>0</u>         |                   | <u>NO</u>  | <u>1000.0</u> |             |                               |               |            |            |                |
| 4             |               |                  |                   |            |               |             |                               |               |            |            |                |
| 5             |               |                  |                   |            |               |             |                               |               |            |            |                |
| 6             |               |                  |                   |            |               |             |                               |               |            |            |                |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/ISO Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584495

FOR CUSTOM STACK 393P - CODI/III

14614 CENFIELD ST ALLIANCE, OH 44601

☐ 14941 Liberty Hill Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 43228  
 216-661-2660  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 5525 Galago Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 100 McJunkin Road  
 NITRO, WV 25143  
 304-755-0686  
☐ 2351 Jaclyn Court  
 SOUTH BEND, IN 46814  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5800

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 3019.0187

WEIGHT  
S/N'S

GLAM H17#3

SCALE  
TECHNICIAN: MR.

ACCEPTED BY: J. J. J. SIGNATURE  
SIGNATURE

PARTS USED

| TAG NO. | MFG    | MOD NO.    | DEV  | TOL. +/- | ADJUSTED | LOC.    | CAP.   | GRAD. SIZE | NORM RING        | CAL FRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|---------|--------|------------|------|----------|----------|---------|--------|------------|------------------|----------|------------|-----------|----------|
|         | CHALIS | ADVENTURER |      |          |          | LAB     | 4100 g | .1 g       | H# - 0<br>LO - 9 | 6 Months | YES        | NO        | 11/2020  |
| 1       | 10g    | 10.0       | 0    | +/- .2%  | YES / NO | AS LEFT | 10.0   |            |                  |          |            |           |          |
| 2       | 20g    | 20.0       | 0    | +/- .2%  | YES / NO |         | 20.0   |            |                  |          |            |           |          |
| 3       | 50g    | 50.0       | 0    | +/- .2%  | YES / NO |         | 50.0   |            |                  |          |            |           |          |
| 4       | 100g   | 100.0      | 0    | +/- .2%  | YES / NO |         | 100.0  |            |                  |          |            |           |          |
| 5       | 1kg    | 999.7      | - .3 | +/- .2%  | YES / NO |         | 1000.0 |            |                  |          |            |           |          |
| 6       | 2kg    | 1999.4     | - .6 | +/- .2%  | YES / NO |         | 2000.0 |            |                  |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584497

FOR CUSTOM STACK 593P - COD!!!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/12/20

- ☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-239-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3308 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-498-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5525 Galileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-289-7960  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-528-3006  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46614  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5900  
☐ 100 McJunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187WEIGHT  
S/N'SColan kit #3SCALE  
TECHNICIAN: M.P.

SIGNATURE

ACCEPTED BY: [Signature] SIGNATURE

PARTS USED

| TAG NO.   | MFG   | MOD NO.   | S/N        | LOC.     | CAP.    | GRAD. SIZE | NORM RNG                | CAL PRO  | CLEAN TEST | CAL STICK | NEXT CAL |
|-----------|-------|-----------|------------|----------|---------|------------|-------------------------|----------|------------|-----------|----------|
|           | OHAUS | SCOUT PRO | 7124111434 | LAB      | 2000 -- | .1 --      | HF 2000 --<br>LO 500 -- | 6 Months | YES        | YES       | 11/2020  |
| WGHT USED |       |           |            | ADJUSTED | AS LEFT | COMMENTS   |                         |          |            |           |          |
| 1         | 500   | 500.0     | 0          | YES / NO | 500.0   |            |                         |          |            |           |          |
| 2         | 1000  | 1000.0    | 0          | YES / NO | 1000.0  |            |                         |          |            |           |          |
| 3         | 1500  | 1500.0    | 0          | YES / NO | 1500.0  |            |                         |          |            |           |          |
| 4         | 2000  | 2000.0    | 0          | YES / NO | 2000.0  |            |                         |          |            |           |          |
| 5         |       |           |            | YES / NO |         |            |                         |          |            |           |          |
| 6         |       |           |            | YES / NO |         |            |                         |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechtbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584496

FOR CUSTOM STACK 593P - CODHIII

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. CODHIII

DATE 5/12/20

- ☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 424 Scale St S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8468  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5525 Galaco Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-299-7960  
☐ 1080 National Parkway  
 MAHNSFIELD, OH 44806  
 419-529-3006  
☐ 528 31<sup>st</sup> St  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 2351 Jaclyn Court  
 SOUTH BEND, IN 46614  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45089  
 513-777-5800  
☐ 100 McClunkin Road  
 NITRO, WV 25143  
 304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.

2019-0182

STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO.

WEIGHT  
S/N'S

Columbus #3

SCALE  
TECHNICIAN: M.P.

ACCEPTED BY: *[Signature]*  
SIGNATURE

PARTS USED

| TAG NO.  | MFG       | MOD NO. | S/N      | LOC.     | CAP.     | GRAD. SIZE | NORM RING        | CAL FRO  | CLEAN TEST | CAL STICK | NEXT CAL  |
|----------|-----------|---------|----------|----------|----------|------------|------------------|----------|------------|-----------|-----------|
|          | SARTORIUS | A2005   | 39080133 | LAB      | 100 GM g | 0.1 g      | HI - g<br>LO - g | 6 Months | YES<br>NO  | YES<br>NO | 11/2/2020 |
| WGT USED | AS FOUND  | DEV.    | TOL. +/- | ADJUSTED | AS LEFT  | COMMENTS   |                  |          |            |           |           |
| 1 10g    | 10000.9   | +0.9    | +/- 2%   | YES / NO | 10000.0  | CAL. BREAD |                  |          |            |           |           |
| 2 20g    | 20001.3   | +1.3    | +/- 2%   | YES / NO | 20000.0  |            |                  |          |            |           |           |
| 3 50g    | 50004.5   | +4.5    | +/- 2%   | YES / NO | 50000.0  |            |                  |          |            |           |           |
| 4 100g   | 100010.8  | +10.8   | +/- 2%   | YES / NO | 100000.0 |            |                  |          |            |           |           |
| 5 g      |           |         |          | YES / NO |          |            |                  |          |            |           |           |
| 6 g      |           |         |          | YES / NO |          |            |                  |          |            |           |           |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCCL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.



#


**BRECHBUHLER  
SCALES, INC.**

# SCALE INSPECTION REPORT

584490

FOR CUSTOM STACK 593P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/12/20

☐ 14941 Liberty Hi Rd.  
BOWLING GREEN, OH 43402  
419-354-2030

☐ 1424 Scale St. S.W.  
CANTON, OH 44706-3096  
330-453-2424

☐ 4005 South Ave.  
YOUNGSTOWN, OH 44512  
330-259-0414

☐ 7550 Jacks Lane  
CLAYTON, OH 45315  
937-832-2040

☐ 3308 Cavalier Dr.  
FORT WAYNE, IN 46808  
260-496-8469

☐ 520 Brookpark Rd.  
CLEVELAND, OH 44109-5898  
216-661-2660

☐ 5525 Galasso Court  
INDIANAPOLIS, IN 46241  
317-548-7821

☐ 4070 Perimeter Dr.  
COLUMBUS, OH 43228  
614-274-9009

☐ 5200 Grand Avenue  
PITTSBURGH, PA 15225  
412-299-7960

☐ 1001 Findlay Rd.  
LIMA, OH 45801  
419-228-5021

☐ 477 North Pike Rd.  
SARVER, PA 16055  
724-224-7180

☐ 2351 Jaclyn Court  
SOUTH BEND, IN 46814

☐ 9930 Crescent Park Drive  
WEST CHESTER, OH 45069  
513-777-5800

☐ 1080 National Parkway  
MANSFIELD, OH 44906  
419-529-3006

☐ 526 31st St.  
PARKERSBURG, WV 26101  
304-428-1792

☐ 100 McJunkin Road  
NITRO, WV 25143  
304-755-0686

TEST WEIGHTS USED ARE CERTIFIED TO COMPLY WITH STANDARD MASSES, AND ARE NIST TRACEABLE.


STATE OF OHIO TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT  
S/N'S

Glam brt #3

SCALE  
TECHNICIAN: MT.

SIGNATURE

ACCEPTED BY:  SIGNATURE

PARTS USED

| TAG NO.  | MFG      | MOD NO.  | S/N  | LOC.      | CAP.    | GRAD. SIZE | NORM. RING          | CAL. FRO | CLEAN TEST | CAL. STICK | NEXT CAL. |
|----------|----------|----------|------|-----------|---------|------------|---------------------|----------|------------|------------|-----------|
|          | US SOLID | NONE     | NONE | TRAVELLER | 500 g   | 0.001 g    | HI 200 g<br>LO 10 g | 6 Months | YES<br>YES | YES<br>NO  | 11/2020   |
| COMMENTS |          |          |      |           |         |            |                     |          |            |            |           |
| 1        | 10g      | AS FOUND | DEV  | ADJUSTED  | AS LEFT |            |                     |          |            |            |           |
| 2        | 20g      | 10.000   | 4    | YES / NO  | 10.000  |            |                     |          |            |            |           |
| 3        | 50g      | 20.000   | 4    | YES / NO  | 20.000  |            |                     |          |            |            |           |
| 4        | 100g     | 50.000   | 4    | YES / NO  | 50.000  |            |                     |          |            |            |           |
| 5        | 200g     | 100.000  | 4    | YES / NO  | 100.000 |            |                     |          |            |            |           |
| 6        | g        | 200.000  | 4    | YES / NO  | 200.000 |            |                     |          |            |            |           |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechtbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.

# BRECHBUHLER SCALES, INC.

## SCALE INSPECTION REPORT

584488

FOR CUSTOM STACK 503P - COD!!!!

14614 CENFIELD ST ALLIANCE, OH 44601

P.O. COD!!!!

DATE 5/12/20

- ☐ 14941 Liberty Hi Rd.  
 BOWLING GREEN, OH 43402  
 419-354-2030  
☐ 4005 South Ave.  
 YOUNGSTOWN, OH 44512  
 330-259-0414  
☐ 1424 Scale St. S.W.  
 CANTON, OH 44706-3096  
 330-453-2424  
☐ 490 S. Mapleton St.  
 COLUMBUS, IN 47201  
 812-372-8374  
☐ 7550 Jacks Lane  
 CLAYTON, OH 45315  
 937-832-2040  
☐ 3306 Cavalier Dr.  
 FORT WAYNE, IN 46808  
 260-496-8469  
☐ 520 Brookpark Rd.  
 CLEVELAND, OH 44109-5898  
 216-661-2660  
☐ 5525 Galileo Court  
 INDIANAPOLIS, IN 46241  
 317-548-7821  
☐ 4070 Perimeter Dr.  
 COLUMBUS, OH 43228  
 614-274-9009  
☐ 5200 Grand Avenue  
 PITTSBURGH, PA 15225  
 412-298-7860  
☐ 477 North Pike Rd.  
 SARVER, PA 16055  
 724-224-7180  
☐ 526 31st St.  
 PARKERSBURG, WV 26101  
 304-428-1792  
☐ 1080 National Parkway  
 MANSFIELD, OH 44906  
 419-529-3006  
☐ 9930 Crescent Park Drive  
 WEST CHESTER, OH 45069  
 513-777-5900  
☐ 2351 Jacyln Court  
 SOUTH BEND, IN 46614  
☐ 100 McLunkin Road  
 NITRO, WV 25143  
 304-755-0686

STATE OF Ohio TRACEABLE TO NIST CALIBRATION LAB TEST REPORT NO. 2019-0187

WEIGHT GRAM  
S/N'S bit #3

SCALE TECHNICIAN: M.P.

ACCEPTED BY: [Signature]  
SIGNATURE

PARTS USED

| TAG NO. | MFG   | MOD NO. | S/N     | LOC | CAP.   | GRAD. SIZE | NORM RING             | CAL FRQ  | CLEAN TEST | CAL STICK | NEXT CAL |
|---------|-------|---------|---------|-----|--------|------------|-----------------------|----------|------------|-----------|----------|
| 1       | 200g  | 200.00  | 1463225 | LAB | 1210 g | 0.01 g     | HI 1000 g<br>LO 200 g | 6 Months | YES        | YES       | 11-2020  |
| 2       | 500g  | 500.00  |         |     |        |            |                       |          |            |           |          |
| 3       | 1000g | 1000.00 |         |     |        |            |                       |          |            |           |          |
| 4       | g     |         |         |     |        |            |                       |          |            |           |          |
| 5       | g     |         |         |     |        |            |                       |          |            |           |          |
| 6       | g     |         |         |     |        |            |                       |          |            |           |          |

PARTS USED

The above indicated equipment has been tested/calibrated by Brechbuhler Scales, Inc. in conformance to ISO 9001 and ANSI/NCSL Z540.

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL FROM BRECHBUHLER SCALES, INC.



7410 Worthington-Galena Road  
Worthington, Ohio 43085  
Phone: (614) 436-4933  
Fax: (614) 436-9144

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.iereents.com](http://www.iereents.com)

### Temperature Calibration Certificate

Instrument: H-B Thermometer  
Serial #: 4A6108

Date: 4/6/2020  
Technician: Sam Shults

| <u>Lab Standard</u> | <u>Thermometer Mark</u> |
|---------------------|-------------------------|
| 169.9               | 170.0                   |
| 190.0               | 190.0                   |
| 204.8               | 205.0                   |
| 214.6               | 215.0                   |

Accuracy = 1 F

#### Reference Standards

PIE 525B sn. 116765 Cal Due: 9/6/2020  
Hart 9103 Temp Dry Well

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**



7410 Worthington-Galena Road  
Worthington, Ohio 43085  
Phone: (614) 436-4933  
Fax: (614) 436-9144

Industrial Environmental Monitoring Instruments, Inc.

Website: [www.ierevents.com](http://www.ierevents.com)

### Temperature Calibration Certificate

Instrument: H-B Thermometer  
Serial #: 485200

Date: 4/6/2020  
Technician: Sam Shults

| <u>Lab Standard</u> | <u>Thermometer Mark</u> |
|---------------------|-------------------------|
| 30.1                | 30.0                    |
| 50.1                | 50.0                    |
| 70.0                | 70.0                    |
| 88.0                | 88.0                    |

Accuracy = 1 F

#### Reference Standards

PIE 525B sn. 116765 Cal Due: 9/6/2020  
Hart 9103 Temp Dry Well

**Instrument must be calibrated and operated according to manufacturers specifications  
The calibration standards used are NIST traceable**

# THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/28/2020 BY Matt Ashbrook Pb 28,73

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| <u>ICE WATER</u>           |                  | <u>BOILING WATER</u> |                  |            |
|----------------------------|------------------|----------------------|------------------|------------|
| <u>TC</u>                  | <u>PRECISION</u> | <u>TC</u>            | <u>PRECISION</u> | <u>TC</u>  |
| <u>OVEN THERMOCOUPLES</u>  |                  |                      |                  |            |
| <u>O-1</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-2</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-3</u>                 | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-4</u>                 | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-5</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-6</u>                 | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-7</u>                 | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-8</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-9</u>                 | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-10</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>O-11</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>O-12</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>STACK THERMOCOUPLES</u> |                  |                      |                  |            |
| <u>2S-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>2S-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>2S-3</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>3S-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3S-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>3S-3</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3S-4</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3S-5</u>                | 32               | <u>33</u>            | 212              | <u>313</u> |
| <u>4S-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4S-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4S-3</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4S-4</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>4S-5</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4S-6</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>5S-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>5S-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>5S-3</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>6S-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6S-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6S-3</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>6S-4</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>8S-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>8S-2</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>10S-1</u>               | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>10S-2</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>12S-1</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |

# **THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS**

CALIBRATION DATE 12/28/2020 BY Matt Ashbrooke PB 28.73

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| <u>ICE WATER</u>               |                  | <u>BOILING WATER</u> |                  |            |
|--------------------------------|------------------|----------------------|------------------|------------|
| <u>TC</u>                      | <u>PRECISION</u> | <u>TC</u>            | <u>PRECISION</u> | <u>TC</u>  |
| <u>CONDENSOR THERMOCOUPLES</u> |                  |                      |                  |            |
| <u>C-1</u>                     | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>C-2</u>                     | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>C-3</u>                     | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>C-4</u>                     | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>C-5</u>                     | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>C-6</u>                     | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>C-7</u>                     | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>C-8</u>                     | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>C-9</u>                     | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>PROBE THERMOCOUPLES</u>     |                  |                      |                  |            |
| <u>2P-1</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>2P-2</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>2P-3</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>3P-1</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>3P-2</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>3P-3</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3P-4</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3P-5</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>4P-1</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4P-2</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4P-3</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4P-4</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4P-5</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4P-6</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>5P-1</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>5P-2</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>5P-3</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6P-1</u>                    | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6P-2</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>6P-3</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>6P-4</u>                    | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>8P-1</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>8P-2</u>                    | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>10P-1</u>                   | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>10P-2</u>                   | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>12P-1</u>                   | 32               | <u>32</u>            | 212              | <u>212</u> |

## THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS

CALIBRATION DATE 12/28/2020 BY Matt Ashbrode Pb 28.73

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 485200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

[illegible]

# **THERMOCOUPLE CALIBRATIONS FOR SOURCE SAMPLING APPARATUS**

CALIBRATION DATE 12/28/2020 BY MTT Ashbrook Pb 28,73

CALIBRATIONS IN ICE WATER AND BOILING WATER USING A H-B PRECISION GLASS THERMOMETER  
No. 4B5200, ASTM NO. 63F FOR ICE WATER AND H-B NO. 4A6108, ASTM NO. 66F FOR BOILING WATER.

| <u>ICE WATER</u>           |                  | <u>BOILING WATER</u> |                  |            |
|----------------------------|------------------|----------------------|------------------|------------|
| <u>TC</u>                  | <u>PRECISION</u> | <u>TC</u>            | <u>PRECISION</u> | <u>TC</u>  |
| <u>METER THERMOCOUPLES</u> |                  |                      |                  |            |
| <u>1M-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>1M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>2M-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>2M-2</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>3M-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>3M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>4M-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>4M-2</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>5M-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>5M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6M-1</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>6M-2</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>7M-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>7M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>8M-1</u>                | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>8M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>9M-1</u>                | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>9M-2</u>                | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>10M-1</u>               | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>10M-2</u>               | 32               | <u>31</u>            | 212              | <u>211</u> |
| <u>15M-1</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>15M-2</u>               | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>17M-1</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>17M-2</u>               | 32               | <u>32</u>            | 212              | <u>212</u> |
| <u>18M-1</u>               | 32               | <u>33</u>            | 212              | <u>213</u> |
| <u>18M-2</u>               | 32               | <u>31</u>            | 212              | <u>211</u> |

THERMOCOUPLE TEMPERATURES ARE READ ON THE DTI DURING TEST.  
DTI CALIBRATED BY ALTEK 22 TC SOURCE S# 148946 OR S# 243783 PRIOR TO TC CAL.

Client: Megs:77

## Pitot Tube Inspection


Date: 4-14-22

|                                               |      |                            |       |
|-----------------------------------------------|------|----------------------------|-------|
| Probe/Pitot Number                            | 6P-4 | A (Pa + Pb)                | 1.027 |
| Level and Perpendicular                       | yes  | Zs = A tan Y (< 0.125")    | 0     |
| Obstruction?                                  | no   | Ws = A tan 0 (< 0.03125")  | 0     |
| Damaged?                                      | no   | Dt (0.1875" < Dt < 0.375") | 0.375 |
| a <sub>1</sub> (-10° < a <sub>1</sub> < +10°) | 0    | Pa (1.05 Dt < Pa < 1.5 Dt) | 511   |
| a <sub>2</sub> (-10° < a <sub>2</sub> < +10°) | 0    | Pb (1.05 Dt < Pb < 1.5 Dt) | 516   |
| b <sub>1</sub> (-5° < b <sub>1</sub> < +5°)   | 0    | Pa = Pb ± 0.063"           | 0.05  |
| b <sub>2</sub> (-5° < b <sub>2</sub> < +5°)   | 0    |                            |       |
|                                               | 0    |                            |       |

## Probe Minimum Interferences

|              |  |                            |  |
|--------------|--|----------------------------|--|
| Y (>= 3.0")  |  | D <sub>n</sub>             |  |
| X (> .75")   |  | X/D <sub>n</sub> (>= 1.5") |  |
| Zp (>= .75") |  |                            |  |

- Pa Distance between where pitots adjoin to tip of pitot (Must be between 1.05 & 1.50 times O.D. of tubing)  
 Pb Distance between where pitots adjoin to tip of pitot (Must be between 1.05 & 1.50 times O.D. of tubing)  
 Dt Diameter of pitot tube (0.375 inches on all pitots)  
 Zs Distance between the tip of the impact and static line along the length of the pitot (Must be < 1/8 inch (0.1250))  
 Ws Spacing between Pitot tubes where welded together (Must be < 1/32 inch (0.0313))  
 a<sub>1</sub> Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 10 Deg)  
 a<sub>2</sub> Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 10 Deg)  
 b<sub>1</sub> Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 5 Deg)  
 b<sub>2</sub> Angle across opening of Pitot tube from side to side or perpendicular to length of probe (Must be < 5 Deg)  
 X Distance between side of nozzle and side of pitot tube (Must be > 3/4 inch)  
 Zp Distance from center of pitot opening back to tip of thermal couple (Must be >= 3/4 inch (0.75))  
 Y Distance from center of pitot opening back to probe (Must be >= 3 inches)



# **Appendix #4**

## **Monitoring Data**

Meggitt Aircraft Braking Systems Corporation  
P039 Accutherm Outlet

| Nox  | Gas   | Cal   | O2   | Gas   | Cal  |
|------|-------|-------|------|-------|------|
| High | 46.93 | 47.20 | High | 20    | 20   |
| Mid  | 25.30 | 25.10 | Mid  | 10    | 10.1 |
| Zero | 0.00  | 0.40  | Zero | 0     | 0.1  |
| NO2  | Gas   | Cal   | CO2  | Gas   | Cal  |
|      | 49.50 | 48.70 | High | 20.04 | 20   |
|      |       |       | Mid  | 9.72  | 9.8  |
|      |       |       | Zero | 0     | 0    |
| VOC  | Gas   |       | CO   | Gas   | Cal  |
| High | 47.05 |       | High | 29.76 | 30   |
| Mid  | 24.70 |       | Mid  | 14.42 | 14.6 |
| Low  | 13.70 |       | Zero | 0     | 0    |
| Zero | 0.00  |       |      |       |      |

| CO2   | O2    | CO    | VOC   | NOx   | Time Stamp                                 |
|-------|-------|-------|-------|-------|--------------------------------------------|
| -0.03 | 0.04  | -0.01 | 0.14  | 25.15 | 4/15/2021 11:43:53 AM Nox Bias VOC Zero    |
| -0.04 | 0.41  | -0.02 | 0.57  | 25.12 | 4/15/2021 11:44:53 AM                      |
| -0.01 | 11.35 | -0.02 | 2.22  | 22.73 | 4/15/2021 11:45:53 AM                      |
| 0.02  | 15.53 | 0.04  | 44.22 | 12.51 | 4/15/2021 11:46:54 AM                      |
| -0.02 | 20.96 | 0.03  | 47.13 | 0.58  | 4/15/2021 11:47:54 AM                      |
| -0.03 | 20.91 | -0.02 | 47.42 | 0.04  | 4/15/2021 11:48:55 AM VOC High             |
| -0.03 | 20.91 | 0.00  | 46.91 | 0.04  | 4/15/2021 11:49:55 AM                      |
| -0.03 | 20.92 | -0.01 | 46.96 | 0.04  | 4/15/2021 11:50:55 AM                      |
| -0.03 | 18.42 | 0.13  | 4.36  | 0.04  | 4/15/2021 11:51:56 AM                      |
| -0.04 | 0.75  | 6.99  | 0.33  | 0.04  | 4/15/2021 11:52:56 AM                      |
| -0.04 | 0.17  | 13.92 | 0.27  | 0.04  | 4/15/2021 11:53:57 AM                      |
| -0.04 | 0.02  | 14.02 | 0.24  | 0.04  | 4/15/2021 11:54:57 AM Co Bias CO2 O2 Zero  |
| -0.04 | 0.02  | 13.97 | 0.23  | 0.04  | 4/15/2021 11:55:58 AM                      |
| -0.04 | 0.02  | 13.96 | 0.18  | 0.04  | 4/15/2021 11:56:58 AM                      |
| -0.03 | 4.09  | 13.93 | 4.77  | 0.04  | 4/15/2021 11:57:58 AM                      |
| -0.02 | 13.18 | 6.60  | 13.08 | 0.04  | 4/15/2021 11:58:59 AM                      |
| -0.04 | 20.81 | 0.26  | 13.19 | 0.04  | 4/15/2021 11:59:59 AM VOC Low              |
| -0.03 | 20.93 | 0.10  | 10.59 | 0.04  | 4/15/2021 12:01:00 PM                      |
| -0.02 | 20.93 | 0.10  | 6.79  | 0.04  | 4/15/2021 12:02:00 PM                      |
| -0.01 | 20.97 | 0.10  | 24.55 | 0.04  | 4/15/2021 12:03:00 PM                      |
| -0.04 | 21.05 | 0.02  | 24.62 | 0.04  | 4/15/2021 12:04:01 PM VOC Bias CO Zero     |
| -0.04 | 21.04 | 0.04  | 18.16 | 0.04  | 4/15/2021 12:05:01 PM                      |
| -0.02 | 20.99 | 0.00  | 1.89  | 0.04  | 4/15/2021 12:06:02 PM                      |
| 0.13  | 20.72 | 0.01  | 2.44  | 0.04  | 4/15/2021 12:07:02 PM                      |
| 8.34  | 11.94 | -0.05 | 0.32  | 0.04  | 4/15/2021 12:08:03 PM                      |
| 9.79  | 10.07 | -0.20 | 0.25  | 0.04  | 4/15/2021 12:09:03 PM O2 CO2 Bias Nox Zero |
| 9.80  | 10.09 | -0.15 | 0.48  | 0.04  | 4/15/2021 12:10:03 PM                      |
| 5.51  | 14.40 | -0.23 | 0.65  | 0.04  | 4/15/2021 12:11:04 PM                      |
| 0.38  | 20.91 | -0.07 | 0.80  | 0.04  | 4/15/2021 12:12:04 PM                      |
| 0.09  | 20.93 | 0.01  | 0.81  | 0.04  | 4/15/2021 12:13:05 PM                      |
| 0.07  | 20.93 | 0.00  | 0.79  | 0.04  | 4/15/2021 12:14:05 PM                      |
| 0.06  | 20.93 | 0.03  | 0.72  | 0.04  | 4/15/2021 12:15:05 PM                      |
| 0.05  | 20.93 | 0.01  | 0.72  | 0.04  | 4/15/2021 12:16:06 PM                      |
| 0.04  | 20.93 | 0.03  | 0.71  | 0.04  | 4/15/2021 12:17:06 PM                      |
| 0.04  | 20.93 | 0.02  | 0.72  | 0.04  | 4/15/2021 12:18:07 PM                      |
| 0.04  | 20.93 | 0.03  | 0.72  | 0.04  | 4/15/2021 12:19:07 PM                      |
| 0.03  | 20.93 | 0.07  | 0.72  | 0.04  | 4/15/2021 12:20:08 PM                      |
| 0.03  | 20.93 | 0.00  | 0.72  | 0.04  | 4/15/2021 12:21:08 PM                      |
| 0.04  | 20.93 | -0.01 | 0.68  | 0.04  | 4/15/2021 12:22:08 PM                      |
| 0.04  | 20.93 | 0.01  | 0.71  | 0.04  | 4/15/2021 12:23:09 PM                      |
| 0.04  | 20.93 | -0.02 | 0.64  | 0.04  | 4/15/2021 12:24:09 PM                      |
| 0.03  | 20.93 | -0.04 | 0.61  | 0.04  | 4/15/2021 12:25:10 PM                      |
| 0.04  | 20.93 | 0.02  | 0.65  | 0.04  | 4/15/2021 12:26:10 PM                      |
| 0.04  | 20.93 | 0.00  | 0.66  | 0.04  | 4/15/2021 12:27:11 PM                      |

|      |       |       |      |      |                       |
|------|-------|-------|------|------|-----------------------|
| 0.04 | 20.93 | -0.01 | 0.68 | 0.04 | 4/15/2021 12:28:11 PM |
| 0.04 | 20.93 | 0.01  | 0.69 | 0.04 | 4/15/2021 12:29:11 PM |
| 0.04 | 20.93 | 0.01  | 0.65 | 0.04 | 4/15/2021 12:30:12 PM |
| 0.04 | 20.93 | -0.01 | 0.67 | 0.04 | 4/15/2021 12:31:12 PM |
| 0.04 | 20.93 | 0.06  | 0.71 | 0.04 | 4/15/2021 12:32:13 PM |
| 0.04 | 20.93 | 0.01  | 0.71 | 0.04 | 4/15/2021 12:33:13 PM |
| 0.04 | 20.93 | 0.01  | 0.71 | 0.04 | 4/15/2021 12:34:14 PM |
| 0.05 | 20.93 | 0.04  | 0.71 | 0.04 | 4/15/2021 12:35:14 PM |
| 0.05 | 20.93 | 0.02  | 0.68 | 0.04 | 4/15/2021 12:36:14 PM |
| 0.04 | 20.93 | -0.03 | 0.68 | 0.04 | 4/15/2021 12:37:15 PM |
| 0.04 | 20.93 | 0.00  | 0.70 | 0.04 | 4/15/2021 12:38:15 PM |
| 0.05 | 20.93 | -0.01 | 0.70 | 0.04 | 4/15/2021 12:39:16 PM |
| 0.05 | 20.94 | -0.01 | 0.65 | 0.04 | 4/15/2021 12:40:16 PM |
| 0.05 | 20.94 | -0.02 | 0.64 | 0.04 | 4/15/2021 12:41:17 PM |
| 0.05 | 20.94 | -0.01 | 0.70 | 0.04 | 4/15/2021 12:42:17 PM |
| 0.05 | 20.94 | 0.00  | 0.69 | 0.04 | 4/15/2021 12:43:17 PM |
| 0.05 | 20.94 | 0.01  | 0.69 | 0.04 | 4/15/2021 12:44:18 PM |
| 0.05 | 20.93 | 0.02  | 0.66 | 0.04 | 4/15/2021 12:45:18 PM |
| 0.05 | 20.93 | 0.02  | 0.64 | 0.04 | 4/15/2021 12:46:19 PM |
| 0.06 | 20.93 | 0.02  | 0.70 | 0.04 | 4/15/2021 12:47:19 PM |
| 0.06 | 20.93 | 0.00  | 0.69 | 0.04 | 4/15/2021 12:48:19 PM |
| 0.06 | 20.93 | 0.02  | 0.71 | 0.04 | 4/15/2021 12:49:20 PM |
| 0.06 | 20.93 | -0.02 | 0.71 | 0.05 | 4/15/2021 12:50:20 PM |
| 0.06 | 20.93 | 0.01  | 0.72 | 0.04 | 4/15/2021 12:51:21 PM |
| 0.06 | 20.93 | 0.01  | 0.70 | 0.05 | 4/15/2021 12:52:21 PM |
| 0.06 | 20.93 | 0.00  | 0.69 | 0.06 | 4/15/2021 12:53:22 PM |
| 0.06 | 20.93 | -0.03 | 0.70 | 0.06 | 4/15/2021 12:54:22 PM |
| 0.06 | 20.94 | 0.01  | 0.74 | 0.04 | 4/15/2021 12:55:22 PM |
| 0.07 | 20.94 | 0.00  | 0.72 | 0.04 | 4/15/2021 12:56:23 PM |
| 0.07 | 20.93 | 0.00  | 0.77 | 0.04 | 4/15/2021 12:57:23 PM |
| 0.07 | 20.93 | 0.03  | 0.72 | 0.04 | 4/15/2021 12:58:24 PM |
| 0.07 | 20.93 | 0.03  | 0.75 | 0.04 | 4/15/2021 12:59:24 PM |
| 0.07 | 20.93 | 0.02  | 0.73 | 0.04 | 4/15/2021 1:00:25 PM  |
| 0.08 | 20.93 | 0.03  | 0.71 | 0.05 | 4/15/2021 1:01:25 PM  |
| 0.08 | 20.93 | 0.02  | 0.71 | 0.06 | 4/15/2021 1:02:25 PM  |
| 0.08 | 20.93 | 0.01  | 0.71 | 0.05 | 4/15/2021 1:03:26 PM  |
| 0.08 | 20.93 | 0.02  | 0.71 | 0.06 | 4/15/2021 1:04:26 PM  |
| 0.08 | 20.93 | -0.02 | 0.73 | 0.05 | 4/15/2021 1:05:27 PM  |
| 0.08 | 20.93 | 0.02  | 0.72 | 0.06 | 4/15/2021 1:06:27 PM  |
| 0.08 | 20.93 | 0.00  | 0.70 | 0.06 | 4/15/2021 1:07:27 PM  |
| 0.08 | 20.93 | -0.02 | 0.68 | 0.06 | 4/15/2021 1:08:28 PM  |
| 0.08 | 20.93 | -0.02 | 0.72 | 0.04 | 4/15/2021 1:09:28 PM  |
| 0.09 | 20.93 | -0.02 | 0.76 | 0.04 | 4/15/2021 1:10:29 PM  |
| 0.09 | 20.93 | -0.02 | 0.75 | 0.04 | 4/15/2021 1:11:29 PM  |
| 0.09 | 20.93 | -0.02 | 0.72 | 0.04 | 4/15/2021 1:12:30 PM  |
| 0.09 | 20.93 | 0.00  | 0.72 | 0.04 | 4/15/2021 1:13:30 PM  |
| 0.09 | 20.93 | -0.02 | 0.73 | 0.04 | 4/15/2021 1:14:30 PM  |
| 0.09 | 20.93 | -0.03 | 0.76 | 0.05 | 4/15/2021 1:15:31 PM  |
| 0.09 | 20.93 | -0.01 | 0.74 | 0.05 | 4/15/2021 1:16:31 PM  |
| 0.09 | 20.93 | 0.02  | 0.74 | 0.04 | 4/15/2021 1:17:32 PM  |
| 0.09 | 20.93 | -0.01 | 0.75 | 0.05 | 4/15/2021 1:18:32 PM  |
| 0.09 | 20.93 | -0.01 | 0.69 | 0.05 | 4/15/2021 1:19:32 PM  |
| 0.10 | 20.93 | 0.00  | 0.72 | 0.04 | 4/15/2021 1:20:33 PM  |
| 0.09 | 20.93 | -0.01 | 0.74 | 0.04 | 4/15/2021 1:21:33 PM  |
| 0.10 | 20.93 | 0.00  | 0.72 | 0.04 | 4/15/2021 1:22:34 PM  |
| 0.10 | 20.93 | 0.01  | 0.72 | 0.04 | 4/15/2021 1:23:34 PM  |
| 0.10 | 20.93 | 0.00  | 0.73 | 0.06 | 4/15/2021 1:24:35 PM  |
| 0.10 | 20.93 | -0.02 | 0.74 | 0.05 | 4/15/2021 1:25:35 PM  |
| 0.10 | 20.93 | 0.00  | 0.77 | 0.06 | 4/15/2021 1:26:35 PM  |
| 0.11 | 20.93 | -0.06 | 0.79 | 0.04 | 4/15/2021 1:27:36 PM  |
| 0.11 | 20.93 | -0.03 | 0.80 | 0.04 | 4/15/2021 1:28:36 PM  |
| 0.11 | 20.93 | -0.02 | 0.80 | 0.04 | 4/15/2021 1:29:37 PM  |
| 0.11 | 20.93 | -0.05 | 0.77 | 0.04 | 4/15/2021 1:30:37 PM  |

|      |       |       |      |       |                                  |
|------|-------|-------|------|-------|----------------------------------|
| 0.11 | 20.93 | -0.06 | 0.80 | 0.04  | 4/15/2021 1:31:38 PM             |
| 0.11 | 20.93 | -0.05 | 0.81 | 0.04  | 4/15/2021 1:32:38 PM             |
| 0.11 | 20.93 | -0.03 | 0.81 | 0.04  | 4/15/2021 1:33:38 PM             |
| 0.11 | 20.93 | -0.05 | 0.80 | 0.04  | 4/15/2021 1:34:39 PM             |
| 0.11 | 20.93 | -0.03 | 0.79 | 0.04  | 4/15/2021 1:35:39 PM             |
| 0.11 | 20.93 | -0.04 | 0.76 | 0.04  | 4/15/2021 1:36:40 PM             |
| 0.10 | 20.94 | -0.06 | 0.79 | 0.04  | 4/15/2021 1:37:40 PM             |
| 0.09 | 20.94 | -0.10 | 0.76 | 0.04  | 4/15/2021 1:38:40 PM             |
| 0.11 | 20.93 | -0.02 | 1.49 | 0.04  | 4/15/2021 1:39:41 PM             |
| 1.25 | 17.26 | -0.04 | 1.54 | 13.12 | 4/15/2021 1:40:41 PM             |
| 2.80 | 15.06 | 0.60  | 1.18 | 22.64 | 4/15/2021 1:41:42 PM             |
| 2.94 | 14.85 | 0.62  | 0.96 | 23.14 | 4/15/2021 1:42:42 PM             |
| 3.32 | 14.31 | 0.42  | 0.88 | 24.48 | 4/15/2021 1:43:43 PM             |
| 3.50 | 14.05 | 0.53  | 0.82 | 25.35 | 4/15/2021 1:44:43 PM             |
| 3.52 | 14.03 | 0.34  | 0.82 | 25.65 | 4/15/2021 1:45:43 PM Start Run 1 |
| 3.49 | 14.08 | 0.19  | 0.82 | 25.44 | 4/15/2021 1:46:44 PM             |
| 3.51 | 14.06 | 0.07  | 0.82 | 25.33 | 4/15/2021 1:47:44 PM             |
| 3.57 | 13.99 | 0.13  | 0.82 | 25.47 | 4/15/2021 1:48:45 PM             |
| 3.54 | 14.04 | 0.09  | 0.81 | 25.24 | 4/15/2021 1:49:45 PM             |
| 3.54 | 14.04 | 0.09  | 0.82 | 25.26 | 4/15/2021 1:50:46 PM             |
| 3.55 | 14.02 | 0.06  | 0.82 | 25.32 | 4/15/2021 1:51:46 PM             |
| 3.57 | 13.98 | 0.05  | 0.82 | 25.47 | 4/15/2021 1:52:46 PM             |
| 3.56 | 14.00 | 0.09  | 0.82 | 25.46 | 4/15/2021 1:53:47 PM             |
| 3.53 | 14.03 | 0.04  | 0.82 | 25.34 | 4/15/2021 1:54:47 PM             |
| 3.54 | 14.03 | 0.08  | 0.82 | 25.25 | 4/15/2021 1:55:48 PM             |
| 3.56 | 14.00 | 0.05  | 0.82 | 25.42 | 4/15/2021 1:56:48 PM             |
| 3.57 | 14.00 | 0.04  | 0.82 | 25.43 | 4/15/2021 1:57:48 PM             |
| 3.55 | 14.02 | 0.05  | 0.82 | 25.20 | 4/15/2021 1:58:49 PM             |
| 3.52 | 14.07 | 0.04  | 0.82 | 25.21 | 4/15/2021 1:59:49 PM             |
| 3.55 | 14.03 | -0.01 | 0.82 | 25.28 | 4/15/2021 2:00:50 PM             |
| 3.48 | 14.13 | 0.02  | 0.82 | 25.04 | 4/15/2021 2:01:50 PM             |
| 3.54 | 14.03 | 0.01  | 0.82 | 25.21 | 4/15/2021 2:02:51 PM             |
| 3.52 | 14.05 | 0.07  | 0.82 | 25.37 | 4/15/2021 2:03:51 PM             |
| 3.53 | 14.03 | 0.07  | 0.82 | 25.29 | 4/15/2021 2:04:51 PM             |
| 3.56 | 13.99 | 0.04  | 0.82 | 25.37 | 4/15/2021 2:05:52 PM             |
| 3.53 | 14.06 | 0.05  | 0.82 | 25.44 | 4/15/2021 2:06:52 PM             |
| 3.55 | 14.02 | 0.05  | 0.82 | 25.39 | 4/15/2021 2:07:53 PM             |
| 3.42 | 14.07 | 0.04  | 0.82 | 25.23 | 4/15/2021 2:08:53 PM             |
| 3.49 | 14.06 | 0.02  | 0.80 | 25.15 | 4/15/2021 2:09:54 PM             |
| 3.49 | 14.06 | 0.02  | 0.82 | 25.07 | 4/15/2021 2:10:54 PM             |
| 3.45 | 14.07 | 0.02  | 0.82 | 25.08 | 4/15/2021 2:11:54 PM             |
| 3.20 | 14.32 | 0.00  | 0.83 | 24.76 | 4/15/2021 2:12:55 PM             |
| 3.03 | 14.53 | -0.06 | 0.82 | 24.25 | 4/15/2021 2:13:55 PM             |
| 2.91 | 14.56 | -0.02 | 0.84 | 23.96 | 4/15/2021 2:14:56 PM             |
| 2.87 | 14.69 | -0.05 | 0.85 | 23.85 | 4/15/2021 2:15:56 PM             |
| 2.74 | 14.82 | -0.03 | 0.87 | 23.30 | 4/15/2021 2:16:56 PM             |
| 2.61 | 14.89 | -0.04 | 0.84 | 23.18 | 4/15/2021 2:17:57 PM             |
| 2.62 | 14.84 | -0.05 | 0.85 | 23.15 | 4/15/2021 2:18:57 PM             |
| 2.86 | 14.69 | -0.04 | 0.82 | 23.27 | 4/15/2021 2:19:58 PM             |
| 2.97 | 14.50 | -0.03 | 0.82 | 23.91 | 4/15/2021 2:20:58 PM             |
| 2.95 | 14.46 | -0.05 | 0.82 | 24.09 | 4/15/2021 2:21:59 PM             |
| 2.94 | 14.45 | -0.02 | 0.82 | 24.11 | 4/15/2021 2:22:59 PM             |
| 3.05 | 14.49 | -0.05 | 0.81 | 24.15 | 4/15/2021 2:23:59 PM             |
| 3.07 | 14.50 | -0.04 | 0.79 | 23.90 | 4/15/2021 2:25:00 PM             |
| 3.48 | 14.12 | -0.12 | 0.78 | 25.37 | 4/15/2021 2:26:00 PM             |
| 3.28 | 14.25 | -0.05 | 0.80 | 25.13 | 4/15/2021 2:27:01 PM             |
| 3.23 | 14.39 | -0.09 | 0.82 | 24.54 | 4/15/2021 2:28:01 PM             |
| 3.04 | 14.53 | -0.06 | 0.78 | 24.27 | 4/15/2021 2:29:02 PM             |
| 3.06 | 14.55 | -0.08 | 0.79 | 23.98 | 4/15/2021 2:30:02 PM             |
| 3.05 | 14.49 | -0.05 | 0.79 | 23.98 | 4/15/2021 2:31:03 PM             |
| 3.03 | 14.56 | -0.05 | 0.81 | 24.12 | 4/15/2021 2:32:03 PM             |
| 3.05 | 14.60 | -0.08 | 0.80 | 23.76 | 4/15/2021 2:33:03 PM             |

|      |       |       |       |       |                                           |
|------|-------|-------|-------|-------|-------------------------------------------|
| 3.07 | 14.57 | -0.05 | 0.80  | 23.91 | 4/15/2021 2:34:04 PM                      |
| 3.07 | 14.52 | -0.06 | 0.78  | 23.90 | 4/15/2021 2:35:04 PM                      |
| 2.74 | 14.82 | -0.06 | 1.32  | 23.84 | 4/15/2021 2:36:05 PM                      |
| 3.05 | 14.49 | -0.05 | 0.76  | 23.85 | 4/15/2021 2:37:05 PM                      |
| 3.38 | 14.18 | -0.11 | 0.81  | 24.60 | 4/15/2021 2:38:06 PM                      |
| 3.24 | 14.33 | -0.08 | 0.80  | 25.24 | 4/15/2021 2:39:06 PM                      |
| 3.14 | 14.35 | -0.05 | 0.77  | 25.15 | 4/15/2021 2:40:06 PM                      |
| 3.14 | 14.34 | -0.06 | 0.67  | 25.13 | 4/15/2021 2:41:07 PM                      |
| 3.05 | 14.47 | -0.09 | 0.70  | 25.16 | 4/15/2021 2:42:07 PM                      |
| 3.07 | 14.47 | 0.05  | 0.66  | 24.79 | 4/15/2021 2:43:07 PM                      |
| 3.32 | 14.21 | 0.23  | 0.67  | 25.18 | 4/15/2021 2:44:08 PM                      |
| 3.28 | 14.30 | 0.05  | 0.67  | 24.76 | 4/15/2021 2:45:08 PM Stop Run 1           |
| 3.26 | 14.29 | 0.01  | 0.81  | 24.73 | Avg                                       |
| 3.25 | 14.35 | 0.00  | 0.63  | 24.58 | 4/15/2021 2:46:09 PM                      |
| 3.21 | 14.30 | -0.02 | 0.62  | 24.62 | 4/15/2021 2:47:09 PM                      |
| 3.23 | 14.34 | -0.02 | 0.92  | 24.64 | 4/15/2021 2:48:10 PM                      |
| 1.29 | 16.64 | -0.08 | 0.65  | 22.90 | 4/15/2021 2:49:10 PM                      |
| 0.05 | 20.93 | -0.12 | 0.68  | 13.62 | 4/15/2021 2:50:10 PM                      |
| 0.05 | 20.94 | -0.09 | 0.74  | 0.15  | 4/15/2021 2:51:11 PM                      |
| 0.85 | 17.70 | -0.08 | 0.80  | 0.18  | 4/15/2021 2:52:11 PM                      |
| 9.49 | 10.39 | -0.20 | 0.72  | 0.35  | 4/15/2021 2:53:12 PM                      |
| 9.80 | 10.12 | -0.31 | 0.67  | 0.18  | 4/15/2021 2:54:12 PM O2 CO2 Bias Nox Zero |
| 9.76 | 10.14 | -0.31 | 0.67  | 0.13  | 4/15/2021 2:55:13 PM                      |
| 8.85 | 10.87 | -0.32 | 0.98  | 0.14  | 4/15/2021 2:56:13 PM                      |
| 0.10 | 5.50  | 1.29  | 0.80  | 0.13  | 4/15/2021 2:57:13 PM                      |
| 0.04 | 0.44  | 13.98 | 0.73  | 0.12  | 4/15/2021 2:58:14 PM                      |
| 0.03 | 0.26  | 14.06 | 0.72  | 0.13  | 4/15/2021 2:59:14 PM Co Bias CO2 O2 Zero  |
| 0.03 | 0.26  | 14.12 | 0.88  | 0.13  | 4/15/2021 3:00:15 PM                      |
| 0.02 | 9.54  | 12.06 | 15.26 | 0.13  | 4/15/2021 3:01:15 PM                      |
| 0.04 | 19.83 | 1.79  | 23.83 | 0.14  | 4/15/2021 3:02:16 PM                      |
| 0.05 | 20.93 | -0.10 | 24.08 | 0.14  | 4/15/2021 3:03:16 PM                      |
| 0.05 | 20.94 | -0.13 | 24.17 | 0.14  | 4/15/2021 3:04:16 PM VOC Bias CO Zero     |
| 0.04 | 20.94 | -0.11 | 20.11 | 0.14  | 4/15/2021 3:05:17 PM                      |
| 0.05 | 13.11 | -0.13 | 0.92  | 12.95 | 4/15/2021 3:06:17 PM                      |
| 0.05 | 0.46  | -0.14 | 0.81  | 23.29 | 4/15/2021 3:07:18 PM                      |
| 0.05 | 0.30  | -0.14 | 0.81  | 25.42 | 4/15/2021 3:08:18 PM                      |
| 0.04 | 0.30  | -0.19 | 0.80  | 25.36 | 4/15/2021 3:09:18 PM Nox Bias VOC Zero    |
| 0.05 | 1.30  | -0.16 | 1.06  | 25.18 | 4/15/2021 3:10:19 PM                      |
| 0.05 | 11.67 | -0.16 | 0.80  | 22.94 | 4/15/2021 3:11:19 PM                      |
| 0.05 | 20.72 | -0.06 | 0.73  | 12.62 | 4/15/2021 3:12:20 PM                      |
| 0.05 | 20.92 | -0.03 | 0.81  | 0.13  | 4/15/2021 3:13:20 PM                      |
| 0.05 | 20.92 | -0.06 | 0.81  | 0.13  | 4/15/2021 3:14:21 PM                      |
| 0.05 | 20.92 | -0.08 | 0.81  | 0.13  | 4/15/2021 3:15:21 PM                      |
| 0.05 | 20.92 | -0.05 | 0.81  | 0.13  | 4/15/2021 3:16:21 PM                      |
| 0.05 | 20.92 | -0.05 | 0.80  | 0.13  | 4/15/2021 3:17:22 PM                      |
| 0.05 | 20.92 | -0.03 | 0.81  | 0.13  | 4/15/2021 3:18:22 PM                      |
| 0.05 | 20.92 | -0.08 | 0.81  | 0.13  | 4/15/2021 3:19:23 PM                      |
| 0.05 | 20.92 | -0.09 | 0.81  | 0.13  | 4/15/2021 3:20:23 PM                      |
| 0.05 | 20.92 | -0.05 | 0.82  | 0.13  | 4/15/2021 3:21:23 PM                      |
| 0.05 | 20.92 | -0.06 | 0.81  | 0.13  | 4/15/2021 3:22:24 PM                      |
| 0.05 | 20.91 | -0.05 | 1.10  | 0.13  | 4/15/2021 3:23:24 PM                      |
| 2.55 | 14.96 | 0.07  | 0.89  | 17.86 | 4/15/2021 3:24:25 PM                      |
| 3.15 | 14.38 | 0.40  | 0.71  | 23.84 | 4/15/2021 3:25:25 PM                      |
| 3.63 | 13.89 | 0.39  | 0.70  | 25.15 | 4/15/2021 3:26:26 PM                      |
| 3.48 | 13.97 | 0.35  | 0.63  | 25.13 | 4/15/2021 3:27:26 PM Start Run 2          |
| 3.52 | 13.96 | 0.26  | 0.63  | 24.87 | 4/15/2021 3:28:27 PM                      |
| 3.45 | 14.00 | 0.23  | 0.63  | 24.72 | 4/15/2021 3:29:27 PM                      |
| 3.65 | 14.06 | 0.20  | 0.63  | 24.54 | 4/15/2021 3:30:27 PM                      |
| 3.47 | 14.11 | 0.17  | 0.64  | 24.34 | 4/15/2021 3:31:28 PM                      |
| 3.40 | 14.17 | 0.20  | 0.66  | 24.24 | 4/15/2021 3:32:28 PM                      |
| 3.30 | 14.27 | 0.17  | 0.64  | 24.03 | 4/15/2021 3:33:29 PM                      |

|      |       |       |      |       |                      |
|------|-------|-------|------|-------|----------------------|
| 3.33 | 14.16 | 0.17  | 0.64 | 24.07 | 4/15/2021 3:34:29 PM |
| 3.30 | 14.24 | 0.18  | 0.67 | 24.25 | 4/15/2021 3:35:29 PM |
| 3.35 | 14.22 | 0.19  | 0.65 | 23.97 | 4/15/2021 3:36:30 PM |
| 3.36 | 14.18 | 0.18  | 0.66 | 24.31 | 4/15/2021 3:37:30 PM |
| 3.32 | 14.16 | 0.20  | 0.65 | 24.29 | 4/15/2021 3:38:31 PM |
| 3.33 | 14.17 | 0.17  | 0.67 | 24.37 | 4/15/2021 3:39:31 PM |
| 3.25 | 14.27 | 0.15  | 0.72 | 24.20 | 4/15/2021 3:40:32 PM |
| 3.21 | 14.37 | 0.17  | 0.74 | 23.93 | 4/15/2021 3:41:32 PM |
| 3.09 | 14.53 | 0.17  | 0.74 | 23.45 | 4/15/2021 3:42:32 PM |
| 3.05 | 14.49 | 0.19  | 0.78 | 23.44 | 4/15/2021 3:43:33 PM |
| 2.83 | 14.74 | 0.14  | 0.81 | 23.16 | 4/15/2021 3:44:33 PM |
| 2.62 | 14.90 | 0.15  | 0.83 | 22.67 | 4/15/2021 3:45:34 PM |
| 2.52 | 15.03 | 0.14  | 0.89 | 23.34 | 4/15/2021 3:46:34 PM |
| 3.03 | 14.42 | 0.14  | 0.94 | 23.74 | 4/15/2021 3:47:34 PM |
| 3.07 | 14.43 | 0.12  | 0.99 | 24.04 | 4/15/2021 3:48:35 PM |
| 2.87 | 14.67 | 0.11  | 1.02 | 24.10 | 4/15/2021 3:49:35 PM |
| 3.05 | 14.95 | 0.09  | 1.07 | 24.29 | 4/15/2021 3:50:36 PM |
| 3.48 | 15.08 | 0.08  | 1.06 | 23.71 | 4/15/2021 3:51:36 PM |
| 3.48 | 15.09 | 0.05  | 1.14 | 23.83 | 4/15/2021 3:52:37 PM |
| 3.05 | 14.51 | 0.08  | 1.18 | 24.28 | 4/15/2021 3:53:37 PM |
| 2.90 | 14.69 | 0.09  | 1.26 | 24.63 | 4/15/2021 3:54:37 PM |
| 2.48 | 15.02 | 0.03  | 1.25 | 24.89 | 4/15/2021 3:55:38 PM |
| 3.50 | 14.92 | 0.02  | 1.25 | 24.68 | 4/15/2021 3:56:38 PM |
| 2.48 | 14.99 | 0.07  | 1.32 | 24.84 | 4/15/2021 3:57:39 PM |
| 3.21 | 14.32 | 0.05  | 1.35 | 24.26 | 4/15/2021 3:58:39 PM |
| 3.03 | 14.46 | 0.04  | 1.34 | 24.57 | 4/15/2021 3:59:39 PM |
| 3.11 | 14.41 | 0.05  | 1.29 | 24.65 | 4/15/2021 4:00:40 PM |
| 3.33 | 14.12 | 0.04  | 1.32 | 25.06 | 4/15/2021 4:01:40 PM |
| 3.02 | 14.47 | 0.04  | 1.39 | 24.89 | 4/15/2021 4:02:41 PM |
| 2.97 | 14.68 | 0.02  | 1.41 | 25.07 | 4/15/2021 4:03:41 PM |
| 2.97 | 14.68 | 0.01  | 1.44 | 24.82 | 4/15/2021 4:04:42 PM |
| 2.85 | 14.77 | 0.04  | 1.49 | 24.90 | 4/15/2021 4:05:42 PM |
| 2.66 | 14.82 | 0.06  | 1.43 | 24.46 | 4/15/2021 4:06:43 PM |
| 2.73 | 14.78 | 0.09  | 1.53 | 24.71 | 4/15/2021 4:07:43 PM |
| 2.54 | 15.04 | 0.07  | 1.53 | 25.24 | 4/15/2021 4:08:43 PM |
| 2.53 | 15.03 | 0.06  | 1.56 | 25.09 | 4/15/2021 4:09:44 PM |
| 2.42 | 15.10 | 0.02  | 1.57 | 24.95 | 4/15/2021 4:10:44 PM |
| 2.38 | 15.17 | 0.01  | 1.53 | 24.64 | 4/15/2021 4:11:45 PM |
| 2.33 | 15.09 | 0.02  | 1.57 | 24.95 | 4/15/2021 4:12:45 PM |
| 2.23 | 15.29 | 0.02  | 1.62 | 24.67 | 4/15/2021 4:13:45 PM |
| 2.11 | 15.41 | 0.03  | 1.57 | 24.14 | 4/15/2021 4:14:46 PM |
| 2.27 | 15.25 | 0.02  | 1.61 | 24.48 | 4/15/2021 4:15:46 PM |
| 2.51 | 15.14 | 0.02  | 1.60 | 24.26 | 4/15/2021 4:16:47 PM |
| 2.51 | 14.94 | -0.02 | 1.61 | 24.24 | 4/15/2021 4:17:47 PM |
| 2.60 | 14.84 | -0.02 | 1.62 | 24.13 | 4/15/2021 4:18:48 PM |
| 2.71 | 14.84 | 0.01  | 1.62 | 24.09 | 4/15/2021 4:19:48 PM |
| 2.62 | 14.84 | 0.00  | 1.65 | 24.19 | 4/15/2021 4:20:48 PM |
| 2.62 | 14.85 | 0.00  | 1.73 | 24.22 | 4/15/2021 4:21:49 PM |
| 2.82 | 14.66 | 0.00  | 1.78 | 24.61 | 4/15/2021 4:22:49 PM |
| 2.64 | 14.84 | 0.01  | 1.78 | 24.20 | 4/15/2021 4:23:50 PM |
| 2.73 | 14.79 | 0.00  | 1.79 | 24.13 | 4/15/2021 4:24:50 PM |
| 2.71 | 14.78 | 0.01  | 1.76 | 24.03 | 4/15/2021 4:25:51 PM |
| 2.73 | 14.76 | 0.04  | 1.81 | 24.29 | 4/15/2021 4:26:51 PM |
| 2.52 | 14.95 | -0.01 | 1.79 | 24.86 | 4/15/2021 4:27:51 PM |
| 2.93 | 14.65 | 0.09  | 1.20 | 24.35 | Stop Run 2<br>Avg    |
| 2.54 | 14.93 | 0.01  | 1.79 | 24.79 | 4/15/2021 4:28:52 PM |
| 2.57 | 14.89 | 0.01  | 1.80 | 24.78 | 4/15/2021 4:29:52 PM |
| 2.60 | 14.88 | 0.00  | 1.79 | 24.93 | 4/15/2021 4:30:53 PM |
| 2.64 | 14.83 | 0.00  | 1.77 | 24.96 | 4/15/2021 4:31:53 PM |
| 2.84 | 14.74 | 0.01  | 1.78 | 24.22 | 4/15/2021 4:32:53 PM |
| 2.75 | 14.79 | 0.02  | 1.81 | 24.26 | 4/15/2021 4:33:54 PM |
| 1.05 | 18.93 | -0.02 | 9.26 | 12.87 | 4/15/2021 4:34:54 PM |

|      |       |       |       |       |                                           |
|------|-------|-------|-------|-------|-------------------------------------------|
| 0.03 | 20.92 | 0.01  | 24.74 | 0.46  | 4/15/2021 4:35:55 PM                      |
| 0.02 | 20.93 | -0.02 | 24.73 | 0.13  | 4/15/2021 4:36:55 PM VOC Bias CO Zero     |
| 0.01 | 20.93 | -0.06 | 20.93 | 0.13  | 4/15/2021 4:37:56 PM                      |
| 0.01 | 14.60 | 0.23  | 0.67  | 0.13  | 4/15/2021 4:38:56 PM                      |
| 0.01 | 1.44  | 6.43  | 0.63  | 0.13  | 4/15/2021 4:39:56 PM                      |
| 0.01 | 0.27  | 14.41 | 0.59  | 0.13  | 4/15/2021 4:40:57 PM                      |
| 0.01 | 0.28  | 14.42 | 0.53  | 0.14  | 4/15/2021 4:41:57 PM Co Bias CO2 O2 Zero  |
| 0.00 | 0.31  | 14.23 | 0.61  | 0.14  | 4/15/2021 4:42:58 PM                      |
| 0.86 | 7.00  | 11.15 | 0.46  | 0.14  | 4/15/2021 4:43:58 PM                      |
| 9.02 | 9.90  | 0.23  | 0.44  | 0.14  | 4/15/2021 4:44:58 PM                      |
| 9.64 | 9.91  | -0.44 | 0.43  | 0.14  | 4/15/2021 4:45:59 PM O2 CO2 Bias Nox Zero |
| 9.63 | 9.91  | -0.44 | 0.42  | 0.15  | 4/15/2021 4:46:59 PM                      |
| 9.22 | 9.23  | -0.45 | 0.72  | 1.06  | 4/15/2021 4:48:00 PM                      |
| 1.40 | 1.98  | -0.37 | 0.54  | 21.83 | 4/15/2021 4:49:00 PM                      |
| 0.05 | 0.22  | -0.20 | 0.52  | 25.86 | 4/15/2021 4:50:01 PM                      |
| 0.05 | 0.21  | -0.22 | 0.50  | 25.92 | 4/15/2021 4:51:01 PM Nox Bias VOC Zero    |
| 0.05 | 0.34  | -0.18 | 0.79  | 25.79 | 4/15/2021 4:52:01 PM                      |
| 0.05 | 12.28 | -0.17 | 0.85  | 22.64 | 4/15/2021 4:53:02 PM                      |
| 0.05 | 20.72 | -0.09 | 0.84  | 1.52  | 4/15/2021 4:54:02 PM                      |
| 0.05 | 20.92 | -0.14 | 0.81  | 0.13  | 4/15/2021 4:55:03 PM                      |
| 0.05 | 20.92 | -0.09 | 0.81  | 0.13  | 4/15/2021 4:56:03 PM                      |
| 0.05 | 20.92 | -0.08 | 0.81  | 0.13  | 4/15/2021 4:57:03 PM                      |
| 0.05 | 20.92 | -0.05 | 0.81  | 0.13  | 4/15/2021 4:58:04 PM                      |
| 0.05 | 20.92 | -0.12 | 0.79  | 0.13  | 4/15/2021 4:59:04 PM                      |
| 1.22 | 17.50 | -0.04 | 0.85  | 1.59  | 4/15/2021 5:00:05 PM                      |
| 3.74 | 13.81 | 0.57  | 0.82  | 23.73 | 4/15/2021 5:01:05 PM                      |
| 3.75 | 13.71 | 2.68  | 0.79  | 26.16 | 4/15/2021 5:02:06 PM                      |
| 3.75 | 13.76 | 3.44  | 0.72  | 26.14 | 4/15/2021 5:03:06 PM                      |
| 3.81 | 13.71 | 2.30  | 0.72  | 25.90 | 4/15/2021 5:04:07 PM Start Run 3          |
| 3.80 | 13.74 | 1.41  | 0.72  | 25.76 | 4/15/2021 5:05:07 PM                      |
| 3.80 | 13.72 | 0.96  | 0.72  | 25.67 | 4/15/2021 5:06:07 PM                      |
| 3.80 | 13.72 | 0.69  | 0.71  | 25.35 | 4/15/2021 5:07:08 PM                      |
| 3.81 | 13.71 | 0.53  | 0.71  | 25.32 | 4/15/2021 5:08:08 PM                      |
| 3.79 | 13.72 | 0.54  | 0.71  | 25.20 | 4/15/2021 5:09:09 PM                      |
| 3.77 | 13.72 | 0.42  | 0.69  | 25.10 | 4/15/2021 5:10:09 PM                      |
| 3.77 | 13.73 | 0.38  | 0.68  | 24.96 | 4/15/2021 5:11:10 PM                      |
| 3.80 | 13.72 | 0.29  | 0.72  | 24.85 | 4/15/2021 5:12:10 PM                      |
| 3.80 | 13.72 | 0.31  | 0.70  | 24.89 | 4/15/2021 5:13:10 PM                      |
| 3.75 | 13.70 | 0.25  | 0.71  | 24.81 | 4/15/2021 5:14:11 PM                      |
| 3.79 | 13.70 | 0.25  | 0.71  | 24.92 | 4/15/2021 5:15:11 PM                      |
| 3.85 | 13.68 | 0.22  | 0.71  | 24.77 | 4/15/2021 5:16:11 PM                      |
| 3.78 | 13.73 | 0.25  | 0.71  | 24.86 | 4/15/2021 5:17:12 PM                      |
| 3.77 | 13.72 | 0.25  | 0.71  | 24.73 | 4/15/2021 5:18:12 PM                      |
| 3.78 | 13.72 | 0.17  | 0.72  | 24.90 | 4/15/2021 5:19:13 PM                      |
| 3.84 | 13.68 | 0.15  | 0.72  | 24.92 | 4/15/2021 5:20:13 PM                      |
| 3.80 | 13.73 | 0.17  | 0.71  | 24.86 | 4/15/2021 5:21:14 PM                      |
| 3.80 | 13.75 | 0.15  | 0.71  | 24.76 | 4/15/2021 5:22:14 PM                      |
| 3.73 | 13.75 | 0.16  | 0.69  | 24.73 | 4/15/2021 5:23:15 PM                      |
| 3.65 | 13.75 | 0.14  | 0.72  | 24.71 | 4/15/2021 5:24:15 PM                      |
| 3.62 | 13.77 | 0.15  | 0.71  | 24.86 | 4/15/2021 5:25:15 PM                      |
| 3.63 | 13.81 | 0.12  | 0.70  | 24.81 | 4/15/2021 5:26:16 PM                      |
| 3.50 | 13.84 | 0.15  | 0.72  | 24.82 | 4/15/2021 5:27:16 PM                      |
| 3.50 | 13.85 | 0.13  | 0.72  | 24.73 | 4/15/2021 5:28:17 PM                      |
| 3.61 | 13.84 | 0.10  | 0.70  | 24.80 | 4/15/2021 5:29:17 PM                      |
| 3.49 | 13.85 | 0.12  | 0.67  | 24.80 | 4/15/2021 5:30:18 PM                      |
| 3.57 | 13.92 | 0.05  | 0.67  | 24.75 | 4/15/2021 5:31:18 PM                      |
| 3.54 | 13.87 | 0.05  | 0.69  | 24.70 | 4/15/2021 5:32:18 PM                      |
| 3.51 | 13.96 | 0.11  | 0.70  | 24.73 | 4/15/2021 5:33:19 PM                      |
| 3.53 | 13.93 | 0.07  | 0.68  | 24.63 | 4/15/2021 5:34:19 PM                      |
| 3.53 | 13.92 | 0.12  | 0.68  | 24.76 | 4/15/2021 5:35:20 PM                      |
| 3.51 | 13.99 | 0.11  | 0.67  | 24.55 | 4/15/2021 5:36:20 PM                      |
| 3.52 | 13.94 | 0.09  | 0.71  | 24.66 | 4/15/2021 5:37:20 PM                      |

|      |       |       |       |       |                                           |
|------|-------|-------|-------|-------|-------------------------------------------|
| 3.44 | 13.96 | 0.08  | 0.67  | 24.70 | 4/15/2021 5:38:21 PM                      |
| 3.52 | 14.00 | 0.08  | 0.69  | 24.59 | 4/15/2021 5:39:21 PM                      |
| 3.40 | 14.03 | 0.09  | 0.65  | 24.55 | 4/15/2021 5:40:22 PM                      |
| 3.42 | 14.04 | 0.04  | 0.65  | 24.43 | 4/15/2021 5:41:22 PM                      |
| 3.41 | 14.07 | 0.05  | 0.67  | 24.53 | 4/15/2021 5:42:22 PM                      |
| 3.40 | 14.17 | 0.01  | 0.69  | 24.34 | 4/15/2021 5:43:23 PM                      |
| 3.29 | 14.21 | 0.04  | 0.71  | 24.20 | 4/15/2021 5:44:23 PM                      |
| 3.03 | 14.40 | 0.02  | 0.70  | 23.84 | 4/15/2021 5:45:24 PM                      |
| 3.15 | 14.40 | 0.00  | 0.71  | 23.86 | 4/15/2021 5:46:24 PM                      |
| 2.87 | 14.57 | -0.02 | 0.71  | 23.38 | 4/15/2021 5:47:25 PM                      |
| 2.83 | 14.59 | -0.03 | 0.72  | 23.39 | 4/15/2021 5:48:25 PM                      |
| 2.81 | 14.60 | -0.02 | 0.73  | 23.25 | 4/15/2021 5:49:25 PM                      |
| 2.82 | 14.63 | -0.03 | 0.72  | 23.15 | 4/15/2021 5:50:26 PM                      |
| 2.71 | 14.75 | -0.01 | 0.68  | 23.17 | 4/15/2021 5:51:26 PM                      |
| 2.83 | 14.60 | 0.00  | 0.74  | 22.97 | 4/15/2021 5:52:27 PM                      |
| 2.60 | 14.82 | -0.03 | 0.76  | 23.03 | 4/15/2021 5:53:27 PM                      |
| 2.59 | 14.82 | -0.04 | 0.74  | 22.63 | 4/15/2021 5:54:28 PM                      |
| 2.53 | 14.81 | -0.03 | 0.76  | 22.87 | 4/15/2021 5:55:28 PM                      |
| 2.55 | 14.86 | -0.03 | 0.79  | 22.69 | 4/15/2021 5:56:28 PM                      |
| 2.55 | 14.89 | -0.04 | 0.77  | 22.45 | 4/15/2021 5:57:29 PM                      |
| 2.55 | 14.90 | 0.00  | 0.77  | 22.83 | 4/15/2021 5:58:29 PM                      |
| 2.53 | 14.81 | -0.03 | 0.77  | 22.54 | 4/15/2021 5:59:30 PM                      |
| 2.57 | 14.78 | 0.00  | 0.82  | 22.99 | 4/15/2021 6:00:30 PM                      |
| 2.43 | 14.99 | -0.03 | 0.81  | 22.45 | 4/15/2021 6:01:31 PM                      |
| 2.46 | 15.02 | -0.01 | 0.87  | 22.55 | 4/15/2021 6:02:31 PM                      |
| 2.11 | 15.43 | -0.03 | 0.88  | 21.67 | 4/15/2021 6:03:32 PM                      |
| 2.09 | 15.35 | -0.02 | 0.83  | 21.34 | 4/15/2021 6:04:32 PM Stop Run 3           |
| 3.31 | 14.15 | 0.19  | 0.72  | 24.20 | Avg                                       |
| 2.31 | 15.03 | -0.02 | 0.84  | 21.85 | 4/15/2021 6:05:32 PM                      |
| 2.15 | 15.29 | -0.03 | 0.89  | 22.32 | 4/15/2021 6:06:33 PM                      |
| 1.89 | 15.58 | -0.06 | 1.10  | 21.16 | 4/15/2021 6:07:33 PM                      |
| 0.87 | 16.90 | -0.05 | 2.02  | 20.38 | 4/15/2021 6:08:34 PM                      |
| 0.05 | 20.81 | -0.05 | 1.99  | 1.13  | 4/15/2021 6:09:34 PM                      |
| 0.05 | 17.69 | -0.09 | 1.07  | 0.36  | 4/15/2021 6:10:34 PM                      |
| 0.05 | 5.50  | -0.11 | 0.81  | 8.81  | 4/15/2021 6:11:35 PM                      |
| 0.05 | 0.53  | -0.10 | 0.81  | 24.51 | 4/15/2021 6:12:35 PM                      |
| 0.05 | 0.35  | -0.10 | 0.81  | 24.92 | 4/15/2021 6:13:36 PM                      |
| 0.05 | 0.28  | -0.10 | 0.74  | 24.87 | 4/15/2021 6:14:36 PM Nox Bias VOC Zero    |
| 0.05 | 0.21  | -0.10 | 0.92  | 24.91 | 4/15/2021 6:15:37 PM                      |
| 0.05 | 6.85  | -0.09 | 0.63  | 24.03 | 4/15/2021 6:16:37 PM                      |
| 1.22 | 10.27 | -0.15 | 0.63  | 14.15 | 4/15/2021 6:17:37 PM                      |
| 9.61 | 10.15 | -0.31 | 0.63  | 0.22  | 4/15/2021 6:18:38 PM                      |
| 9.62 | 10.14 | -0.25 | 0.63  | 0.20  | 4/15/2021 6:19:38 PM                      |
| 9.62 | 10.08 | -0.29 | 0.63  | 0.13  | 4/15/2021 6:20:38 PM O2 CO2 Bias Nox Zero |
| 9.62 | 10.07 | -0.24 | 0.70  | 0.13  | 4/15/2021 6:21:39 PM                      |
| 8.48 | 10.75 | 0.16  | 1.69  | 0.15  | 4/15/2021 6:22:39 PM                      |
| 0.05 | 19.55 | 0.60  | 24.83 | 0.15  | 4/15/2021 6:23:40 PM                      |
| 0.05 | 20.92 | 0.00  | 24.87 | 0.13  | 4/15/2021 6:24:40 PM                      |
| 0.05 | 20.92 | 0.00  | 24.92 | 0.13  | 4/15/2021 6:25:41 PM VOC Bias CO Zero     |
| 0.05 | 20.92 | 0.09  | 24.91 | 0.19  | 4/15/2021 6:26:41 PM                      |
| 0.05 | 20.93 | 0.10  | 24.86 | 0.17  | 4/15/2021 6:27:42 PM                      |
| 0.05 | 11.73 | 6.06  | 1.87  | 0.13  | 4/15/2021 6:28:42 PM                      |
| 0.04 | 0.45  | 14.40 | 0.97  | 0.13  | 4/15/2021 6:29:42 PM                      |
| 0.04 | 0.24  | 14.40 | 0.90  | 0.14  | 4/15/2021 6:30:43 PM Co Bias CO2 O2 Zero  |
| 0.05 | 0.24  | 14.40 | 0.90  | 0.14  | 4/15/2021 6:31:43 PM                      |
| 0.04 | 0.23  | 14.40 | 0.91  | 0.14  | 4/15/2021 6:32:44 PM                      |
| 0.04 | 8.46  | 6.02  | 0.93  | 0.14  | 4/15/2021 6:33:44 PM                      |
| 0.04 | 20.17 | 0.02  | 0.92  | 0.14  | 4/15/2021 6:34:45 PM                      |
| 0.04 | 20.92 | 0.00  | 0.91  | 0.14  | 4/15/2021 6:35:45 PM                      |
| 0.04 | 20.92 | -0.05 | 0.90  | 0.14  | 4/15/2021 6:36:45 PM                      |


## **Appendix #5**

### **Process Data**

# ACCUTHERM RAMP CHART

Run Start Date: 4/13/2021

Run # CB1-10321



**Public Notice**  
**Ohio Environmental Protection Agency**  
**Draft State Implementation Plan**  
**VOC Reasonably Available Control Technology (RACT)**  
**for Meggitt Aircraft Braking Systems Corp. (Facility ID1677010999)**

**Summit County**

Notice is hereby given that the Director of the Ohio Environmental Protection Agency, (Ohio EPA) is submitting to the United States Environmental Protection Agency (U.S. EPA) Reasonably Available Control Technology (RACT) for Meggitt Aircraft Braking Systems Corp, LLC (Facility ID 1677010999) for approval into Ohio's state implementation plan (SIP) for the 2015 ozone National Ambient Air Quality Standard (NAAQS).

On March 17, 2025, Ohio submitted a revision to Ohio's SIP to address RACT requirements for the 2015 8-hour ozone NAAQS. As noted in this submittal, Ohio Administrative Code (OAC) rule 3745-21-11(B) requires facilities that have the potential to emit of fifty tons per year or more, but less than one hundred tons per year of volatile organic compounds (VOC) and are located in nonattainment counties to submit a RACT study for sources not controlled by Ohio's Control Technique Guideline (CTG) regulations in OAC Chapter 3745-21 or by categorical non-CTG RACT in OAC rules 3745-21-12, 3745-21-14, 3745-21-16, 3745-21-21 and 3745-21-25.

Ohio is now submitting source-specific VOC RACT for Meggitt Aircraft Braking Systems Corp (Facility ID 1677010999) for approval into Ohio's SIP. This facility is located in the Cleveland 2015 ozone maintenance area and has no prior existing source-specific RACT established in OAC rule 3745-21-09.

The updated RACT Study was submitted per OAC rule 3745-21-11(B). Ohio has determined that the updated RACT study, along with supplemental information submitted subsequently, is sufficient to justify the continued use of the existing thermal oxidizer with an overall control efficiency of at least 99% pursuant to OAC rule 3745-31-05(D) proposed by the facility to act as RACT for the carbon furnaces under the 2015 ozone standard.

Ohio EPA is now requesting approval of the proposed RACT for Meggitt Aircraft Braking Systems Corp into Ohio's SIP.

Ohio EPA is seeking public comment to satisfy U.S. EPA requirements for public involvement in SIP related activities in accordance with 40 CFR 51.102.

The public comment period will run until October 12, 2026. Written comments should be submitted at: <https://ohioepa.commentinput.com> - Search by entering the permit # (P0141227 for Meggitt Aircraft Braking Systems Corp) in the "Search Projects" search box.

A public hearing on this action may be requested by contacting Kathryn Jobe at 614-728-0671 or [kathryn.jobe@epa.ohio.gov](mailto:kathryn.jobe@epa.ohio.gov) no later than 30 days from the draft public notice. If a public hearing is requested, a new notification will be published to identify the time and location of the public hearing. The public hearing will be held at least 30 days after the date of the new notification.

All interested persons are entitled to comment on these changes. All comments submitted to the above address by the close of business 30 days from when the draft public notice is issued will be considered by Ohio EPA prior to final action on this action. Written statements submitted after this time period may be considered as time and circumstances permit but will not be part of the official record.

Questions or comments about this document should be directed to Kathryn Jobe at 614-728-0671 or [kathryn.jobe@epa.ohio.gov](mailto:kathryn.jobe@epa.ohio.gov).



**DATE**

Ms. Anne Vogel  
Regional Administrator  
U.S. EPA, Region 5  
77 West Jackson Blvd.  
Chicago, Illinois 60604

**Re: Revision to Ohio's Reasonably Available Control Technology (RACT) State Implementation Plan for the 2015 Ozone National Ambient Air Quality Standards – Source-Specific Volatile Organic Compound (VOC) RACT for Meggitt Aircraft Braking Systems Corp. (Facility ID 1677010999)**

Dear Administrator Vogel:

On March 17, 2025, Ohio submitted a revision to Ohio's State Implementation Plan (SIP) to address Reasonably Available Control Technology (RACT) requirements for the 2015 8-hour ozone National Ambient Air Quality Standards (NAAQS) for areas classified as serious. As noted in this submittal, Ohio EPA adopted requirements in Ohio Administrative Code (OAC) rule 3745-21-11 for facilities in the nonattainment areas that emit fifty tons per year or more, but less than one hundred tons per year of volatile organic compounds (VOC) from sources not controlled by Ohio's CTG regulations in OAC Chapter 3745-21 or by categorical non-CTG RACT in OAC rules 3745-21-12, 3745-21-14, 3745-21-16, 3745-21-21 and 3745-21-25 to submit an updated RACT study within one year of the effective date of the rule. Upon review of the RACT study, Ohio EPA evaluated if the RACT proposed by the facility is appropriate to satisfy RACT requirements under the 2015 ozone standard.

Ohio is now submitting source-specific VOC RACT for Meggitt Aircraft Braking Systems Corp. (Facility ID 1677010999) for approval into Ohio's SIP. This facility is located in the Cleveland 2015 ozone maintenance area and has no prior existing source-specific RACT established in OAC rule 3745-21-09.

The updated VOC RACT Study was submitted per OAC rule 3745-21-11. Ohio has determined that the updated RACT study, along with supplemental information submitted subsequently, is sufficient to justify the continued use of the existing thermal oxidizer with an overall control efficiency of at least 99% pursuant to OAC rule 3745-31-05(D) proposed by the facility to act as RACT for the carbon furnaces under the 2015 ozone standard. The RACT study is provided in Appendix A, and the permit that incorporated RACT is provided as Appendix B. Within the permit, we have

highlighted the terms and conditions associated with RACT and request only those provisions are subject to this SIP revision request. Appendix C provides the permit strategy write-up for the permit.

Ohio held a public comment period on Ohio's RACT determination from September 10 to October 12, 2026. Appendix D contains the public notice. ***[Ohio's response to comments received during the public comment period is in Appendix E/No comments were received during the public comment period].***

This SIP does not include the relaxation of any existing requirements and therefore will not interfere with the attainment or maintenance of the NAAQS in accordance with section 110(l) of the CAA.

Ohio EPA is now requesting approval of the proposed RACT for Meggitt Aircraft Braking Systems Corp. into Ohio's SIP.

Ohio EPA is submitting this SIP via U.S. EPA's State Planning Electronic Collaboration System (SPECS). If you have questions, please contact Jennifer Van Vlerah in our Division of Air Pollution Control at (614) 644-3696.

Sincerely,

John Logue  
Director

Cc: Bob Hodanbosi, Chief, Division of Air Pollution Control, Ohio EPA

Enclosures