

Joe's Hardware (Joe Kennedy)

This is my comment.

U.S. Department of Homeland Security
FEMA Region IX
1111 Broadway, Suite 1200
Oakland, CA. 94607-4052



FEMA

April 27, 2017

Greg Nakai, Planner
PBR Hawaii & Associates, Inc.
1001 Bishop Street, Suite 650
Honolulu, Hawaii 96813

Dear Mr. Nakai:

This is in response to your request for comments regarding a Draft Environmental Assessment (DEA) for The Kahala Hotel I& Resort Beach Enhancements, Tax Map Key: (1) 3-5-023:039 por. And 041.

Please review the current effective countywide Flood Insurance Rate Maps (FIRMs) for the City and County of Honolulu (Community Number 150001), Maps revised November 5, 2014. Please note that the City and County of Honolulu, Hawaii is a participant in the National Flood Insurance Program (NFIP). The minimum, basic NFIP floodplain management building requirements are described in Vol. 44 Code of Federal Regulations (44 CFR), Sections 59 through 65.

A summary of these NFIP floodplain management building requirements are as follows:

- All buildings constructed within a riverine floodplain, (i.e., Flood Zones A, AO, AH, AE, and A1 through A30 as delineated on the FIRM), must be elevated so that the lowest floor is at or above the Base Flood Elevation level in accordance with the effective Flood Insurance Rate Map.
- If the area of construction is located within a Regulatory Floodway as delineated on the FIRM, any *development* must not increase base flood elevation levels. **The term *development* means any man-made change to improved or unimproved real estate, including but not limited to buildings, other structures, mining, dredging, filling, grading, paving, excavation or drilling operations, and storage of equipment or materials.** A hydrologic and hydraulic analysis must be performed *prior* to the start of development, and must demonstrate that the development would not cause any rise in base flood levels. No rise is permitted within regulatory floodways.

- All buildings constructed within a coastal high hazard area, (any of the "V" Flood Zones as delineated on the FIRM), must be elevated on pilings and columns, so that the lowest horizontal structural member, (excluding the pilings and columns), is elevated to or above the base flood elevation level. In addition, the posts and pilings foundation and the structure attached thereto, is anchored to resist flotation, collapse and lateral movement due to the effects of wind and water loads acting simultaneously on all building components.
- Upon completion of any development that changes existing Special Flood Hazard Areas, the NFIP directs all participating communities to submit the appropriate hydrologic and hydraulic data to FEMA for a FIRM revision. In accordance with 44 CFR, Section 65.3, as soon as practicable, but not later than six months after such data becomes available, a community shall notify FEMA of the changes by submitting technical data for a flood map revision. To obtain copies of FEMA's Flood Map Revision Application Packages, please refer to the FEMA website at <http://www.fema.gov/business/nfip/forms.shtm>.

Please Note:

Many NFIP participating communities have adopted floodplain management building requirements which are more restrictive than the minimum federal standards described in 44 CFR. Please contact the local community's floodplain manager for more information on local floodplain management building requirements. The Honolulu City and County floodplain manager can be reached by calling Mario Siu-Li, NFIP Coordinator, at ((808) 768-8098.

If you have any questions or concerns, please do not hesitate to call Sarah Owen of the Mitigation staff at (510) 627-7050.

Sincerely,


Gregor Blackburn, CFM, Branch Chief
Floodplain Management and Insurance Branch

cc:

Mario Siu-Li, NFIP Coordinator, City and County of Honolulu, Hawaii
Carol Tyau-Beam, NFIP State Coordinator, HI Department of Land & Natural Resources,
Division of Water Resources
Sarah Owen, NFIP Compliance Officer, DHS/FEMA Region IX
Alessandro Amaglio, Environmental Officer, DHS/FEMA Region IX